




31761 05478917



Digitized by the Internet Archive
in 2007 with funding from
Microsoft Corporation

WORKS OF
PROFESSOR CECIL H. PEABODY
PUBLISHED BY
JOHN WILEY & SONS.

Thermodynamics of the Steam-engine and other Heat-engines.

This work is intended for the use of students in technical schools, and gives the theoretical training required by engineers. Fifth Edition, Rewritten, vi+533 pages, 117 figures. 8vo, cloth, \$5.00.

Tables of the Properties of Steam and other Vapors, and Temperature-Entropy Table.

These tables were prepared for the use of students in technical schools and colleges, and of engineers in general. Seventh Edition, Rewritten. 8vo, vi+130 pages, cloth, \$1.00.

Valve-gears for Steam-engines.

This book is intended to give engineering students instruction in the theory and practice of designing valve-gears for steam-engines. Second Edition, Revised and Enlarged. 8vo, v+142 pages, 33 folding-plates, cloth, \$2.50.

Steam-boilers.

By Prof. Cecil H. Peabody and Prof. Edward F. Miller. Nearly 400 pages; 142 illustrations. 8vo, cloth, \$4.00.

Manual of the Steam-engine Indicator.

154 pages; 98 figures, 12mo, cloth, \$1.50.

Naval Architecture.

v+616 pages; 217 figures. 8vo, cloth, \$7.50.

School of Science

TABLES OF
THE PROPERTIES OF STEAM
AND OTHER VAPORS
AND
TEMPERATURE-ENTROPY
TABLE

BY

CECIL H. PEABODY

PROFESSOR OF NAVAL ARCHITECTURE AND MARINE ENGINEERING
MASSACHUSETTS INSTITUTE OF TECHNOLOGY

SEVENTH EDITION. REWRITTEN
FIRST THOUSAND

NEW YORK

JOHN WILEY & SONS

LONDON: CHAPMAN & HALL, LIMITED

1907

COPYRIGHT, 1888, 1907,

BY

CECIL H. PEABODY



Stanhope Press
F. H. GILSON COMPANY
BOSTON, U.S.A.

P R E F A C E.

THE Tables of the Properties of Steam were calculated twenty years ago to accompany the author's Thermodynamics of the Steam Engine; since that time important experimental investigations have been made by Callendar, Barnes, Knoblauch and Thomas. The tables have been recomputed, introducing this information and with certain changes which will be found to facilitate their use. All the tables for saturated steam have columns of entropy due to vaporization; and the table in metric units has been made into a conversion table by aid of which properties can be found in either metric or English units or a combination of the two systems may be used.

The development of the steam-turbine has given prominence to adiabatic computations for steam and has emphasized the facts that the usual methods are tedious and cannot be worked inversely. To meet this difficulty various diagrams have been devised, all of which have certain inconveniences; if they have a convenient scale, they are so large as to be awkward to carry or to use; all have important problems represented by curves which render interpolation troublesome.

To facilitate the solution of all adiabatic problems (and many others) a Temperature-Entropy Table has been constructed for saturated and superheated steam. For engineering purposes the answers for such problems may be read directly from the table; greater refinement can be had by interpolation when that is thought desirable. That part of the table which refers to saturated steam may be relied upon to give the nearest unit in the last place of significant figures; the degree of accuracy to be attributed to the several properties of saturated steam can be determined from the statements of experimental data and derivation of formulæ given in the Introduction. The properties of superheated steam are given with as much accuracy as conditions warrant. This part of the table offers solutions of problems that cannot be readily obtained otherwise.

Original data are given in the Introduction so far as possible, and computations and transformations of equations are set down at length

so that each one may decide for himself what degree of accuracy he shall attribute to the properties and methods presented.

The actual work of recomputing the Tables of Properties of Steam and of constructing the Temperature-Entropy Table has been done by Mr. Harold A. Everett, S.B., who has also read the proofs. How much that means can be appreciated by those familiar with such undertakings.

C. H. P.

SEPTEMBER, 1907.

CONTENTS.

	Page
INTRODUCTION	3
Table I. STEAM, ENGLISH UNITS, DEGREES	33
Table II. STEAM, ENGLISH UNITS, POUNDS	43
Table III. STEAM, FRENCH AND ENGLISH UNITS	52
Table IV. ETHER	64
Table V. ALCOHOL	65
Table VI. CHLOROFORM	66
Table VII. CARBON BISULPHIDE	67
Table VIII. CARBON TETRACHLORIDE	68
Table IX. ACETON	69
Table X. AMMONIA	70
Table XI. SULPHUR DIOXIDE	71
Table XII. SPECIFIC VOLUMES OF LIQUIDS	72
Table XIII. VOLUMES OF HOT WATER	72
Table XIV. INCHES OF MERCURY AND POUNDS	73
Table XV. CORRECTIVE FACTORS, SUPERHEATED STEAM	74
TEMPERATURE-ENTROPY TABLE	75
NAPERIAN LOGARITHMS	128
FOUR-PLACE LOGARITHMS	130

PROPERTIES OF STEAM AND OTHER VAPORS.

INTRODUCTION.

FOR engineering purposes steam is generated in a boiler which is partially filled with water, and arranged to receive heat from the fire in the furnace.

The ebullition is usually energetic, and more or less water is mingled with the steam; but if there is a fair allowance of steam space over the water, and if proper arrangements are provided for withdrawing the steam, it will be found when tested to contain a small amount of water, usually between half a per cent and a per cent and a half. Steam which contains a considerable percentage of water is passed through a separator which removes almost all of it. Such steam is considered to be approximately dry.

If the steam is quite free from water it is said to be dry and saturated; steam from a boiler with a large steam space and which is making steam very slowly is nearly if not quite dry.

Steam which is withdrawn from the boiler may be heated to a higher temperature than that found in the boiler, and is then said to be superheated.

Saturated Steam.—Our knowledge of the properties of saturated steam and other vapors is due mainly to the experiments of Regnault,* who determined the relations of the temperature and pressure, the total heat of vaporization, and the heat of the liquid for many volatile liquids. Since his time, Rowland's determination of the mechanical equivalent of heat has given a more exact determination of the specific heat of water at low temperatures, and recently Dr. Barnes has given a very precise determination of that property for water. Again, certain work by Knoblauch, Linde and Klebe, has given us a good knowledge of the properties of superheated steam which can be extended to give the specific volumes of saturated steam over a considerable range of temperature; in the proper place a comparison will be made with the usual theoretical computations for volumes.

* *Mémoires de l' Institut de France, etc., tome xxvi.*

Pressure of Saturated Steam. — As a conclusion from all the experiments on the tension of saturated steam, Regnault * gives the following data:—

TEMPERATURE C.	PRESSURE MM. OF MERCURY.
- 32	0.32
- 16	1.29
0	4.60
25	23.55
50	91.98
75	288.50
100	760.00
130	2030.0
160	4651.6
190	9426.
220	17390.
- 20	0.91
+ 40	54.91

From these data he calculated, by the aid of seven-place logarithms, the following formulæ, which give the pressure in millimetres of mercury for any temperature in degrees Centigrade:—

A. For steam from - 32° to 0° C,

$$p = a + b\alpha^n.$$

$$a = - 0.08038.$$

$$\log b = 9.6024724 - 10.$$

$$\log \alpha = 0.033398.$$

$$n = 32^\circ - t.$$

B. For steam from 0° to 100° C,

$$\log p = a - b\alpha^n + c\beta^n.$$

$$a = 4.7384380.$$

$$\log b = 0.6116485.$$

$$\log c = 8.1340339 - 10.$$

$$\log \alpha = 9.9967249 - 10.$$

$$\log \beta = 0.006865036.$$

$$n = t.$$

* *Mémoires de l' Institut de France, etc., tome xxi.*

C. For steam from 100° to 220° C.,
 $\log p = a - ba^n + c\beta^n$.

$$a = 5.4583895.$$

$$\log b = 0.4121470.$$

$$\log c = 7.7448901 - 10.$$

$$\log \alpha = 9.997412127 - 10.$$

$$\log \beta = 0.007590697.$$

$$n = l = 100.$$

D. For steam from -20° to 220° C.,
 $\log p = a - ba^n - c\beta^n$,

$$a = 6.2640348.$$

$$\log b = 0.1397743.$$

$$\log c = 0.6924351.$$

$$\log \alpha = 9.994049292 - 10.$$

$$\log \beta = 9.998343862 - 10.$$

$$n = l + 20.$$

By aid of the formulæ A and B, Regnault calculated and recorded tables of the pressures of saturated steam for temperatures from -32° to 100° C. The formula D was calculated from the data given above for the temperatures -20° , $+40^{\circ}$, 100° , 160° , and 220° C., and was intended to represent the whole range of experiments. By this formula, instead of formula C, he calculated the pressures set down in his tables for temperatures from 100° C. to 220° C. In the calculations of the constants and in their application to computations of pressures at given temperatures, there is an inevitable loss of accuracy so that the results do not agree satisfactorily with the original data.

Equations for the Pressure of Steam at Paris. — In view of the preceding statements, it appeared desirable to re-calculate the constants for Equations B and C, with a degree of accuracy that should exclude any doubt as to the reliability of the results. Accordingly, the logarithms required were taken from Vega's ten-place table, and then the remainder of the calculations were carried on with natural numbers, checking by independent methods, with the following results: —

B. For steam from 0° to 100° C.,

$$\log p = a - ba^n + c\beta^n.$$

$$a = 4.7393622142.$$

$$\log b = 0.6117400190.$$

$$\log c = 8.1320378383 - 10.$$

$$\log \alpha = 9.996725532820 - 10.$$

$$\log \beta = 0.000864675924.$$

$$n = l.$$

PROPERTIES OF STEAM AND OTHER VAPORS.

C. For steam from 100° to 220° C,
 $\log p = a - b\alpha^n + c\beta^n$.

$$a = 5.4574301234 \cdot$$

$$\log b = 0.4119787931 \cdot$$

$$\log c = 7.7417476470 - 10.$$

$$\log \alpha = 9.99741106346 - 10.$$

$$\log \beta = 0.007642489113.$$

$$n = t - 100.$$

To show the degree of accuracy attained, the following tables are given:—

EQUATION B.

<i>t.</i>	<i>p.</i>	LOG \bar{p} FROM TABLE OF LOGARITHMS.	LOG \bar{p} CALCULATED BY EQUATION.
0	4.60	0.6627578317
25	23.55	1.3719909115	1.37199097
50	91.98	1.9636934052	1.96369346
75	288.50	2.4601458175	2.46014587
100	760	2.8808135923	2.88081356

EQUATION C.

<i>t.</i>	<i>p.</i>	LOG \bar{p} FROM TABLE OF LOGARITHMS.	LOG \bar{p} CALCULATED BY EQUATION.
100	760.00	2.8808135923
130	2030.0	3.3074960379	3.307496036
160	4651.6	3.6676023618	3.667602359
190	9426	3.9743274354	3.974327428
220	17390	4.2402995820	4.240299575

The results from Equation C are quite satisfactory; for the errors come in the ninth place of decimals, and one place of decimals is unavoidably lost in the application of the formula. Equation B was calculated after Equation C and the numerical work was not carried to so large a number of decimal places. For the calculation of tables, the constants are carried to seven places of significant figures only; this gives six significant figures in the result, of which five are recorded in the tables.

Pressure of Steam at Latitude 45° . — French System. — It is customary to reduce all measurements to the latitude of 45° , and to sea-level. The standard thermometer should then have its boiling and freezing points

determined under, or reduced to such conditions. The value of g , the acceleration due to gravity, is, at Paris, latitude $48^{\circ} 50' 14''$ and 60 metres above sea-level, 9.809218 metres; and at 45° , and at sea-level, it is 9.806056 metres. Consequently, 760 mm. of mercury at 45° gives a pressure equal to that of 759.755 mm. at Paris; and this corresponds to a temperature of 99.991°C .

In other words, the thermometer which is standard at 45° has each degree 0.99991 of the length of the degree of a thermometer standard at Paris.

To reduce Equation *B* to 45° latitude, we have

$$\log p = a + \log \frac{980.9218}{980.6056} - b\alpha^{0.00001t} + c\beta^{0.00001t};$$

and for Equation *C*,

$$\begin{aligned} \log p &= a + \log \frac{980.9218}{980.6056} - b\alpha^{0.00001(t-100)} + c\beta^{0.00001(t-100)} \\ &= a + \log \frac{980.9218}{980.6056} - b\alpha - 0.009 \alpha^{0.00001(t-100)} + c\beta - 0.009 \beta^{0.00001(t-100)}. \end{aligned}$$

The resulting equations which were used in calculating Table III are

B. For steam from 0° to 100° C. at 45° latitude,

$$\log p = a_1 - b\alpha_1^n + c\beta_1^n.$$

$$a_1 = 4.739502.$$

$$\log b = 0.6117400.$$

$$\log c = 8.13204 - 10.$$

$$\log \alpha_1 = 9.996725828 - 10.$$

$$\log \beta_1 = 0.0068641.$$

$$n = l.$$

C. For steam from 100° to 220° C. at 45° latitude,

$$\log p = a_1 - b_1\alpha_1^n + c_1\beta_1^n.$$

$$a_1 = 5.457570.$$

$$\log b_1 = 0.4120021.$$

$$\log c_1 = 7.74168 - 10.$$

$$\log \alpha_1 = 9.997411296 - 10.$$

$$\log \beta_1 = 0.0076418.$$

$$n = l - 100.$$

Pressure of Steam at Latitude 45°.—English System.—To reduce the equations for the pressure of steam, so that they will give the pressures in pounds on the square inch for degrees Fahrenheit, there are required the comparison of measures of length, and of weight, the comparison of the scales of the thermometers, and the specific gravity of mercury.

Professor Rogers * gives for the length of the metre, 39.3702 inches.

Professor Miller † gives for the weight of one kilogram, 2.20462125 pounds.

Regnault gives, for the weight of one litre of mercury, 13.5959 kilograms.

The degree Fahrenheit is $\frac{5}{9}$ of the length of the degree Centigrade.

Let

$$k = \frac{13.5959 \times 2.204621}{39.3702^2};$$

then the equations *B* and *C* have for the reduction to degrees Fahrenheit, and pounds on the square inch,

$$\begin{aligned}\log p &= a_1 + \log k - b\alpha_1^n + c\beta_1^n, \\ \log p &= a_1 + \log k - b_1\alpha_1^n + c_1\beta_1^n.\end{aligned}$$

The resulting equations, which were used in calculating Table I, are :—

B. For steam from 32° to 212° F., in pounds on the square inch,

$$\log p = a_2 - b\alpha_2^n + c\beta_2^n.$$

$$a_2 = 3.025908.$$

$$\log b = 0.6117400.$$

$$\log c = 8.13204 - 10.$$

$$\log \alpha_2 = 9.998181015 - 10.$$

$$\log \beta_2 = 0.0038134.$$

$$n = t - 32.$$

C. For steam from 212° to 428° F., in pounds on the square inch,

$$\log p = a_2 - b_1\alpha_2^n + c_1\beta_2^n.$$

$$a_2 = 3.743976.$$

$$\log b_1 = 0.4120021.$$

$$\log c_1 = 7.74168 - 10.$$

$$\log \alpha_2 = 9.998561831 - 10.$$

$$\log \beta_2 = 0.0042454.$$

$$n = t - 212.$$

* *Proceedings of the Am. Acad. of Arts and Sciences*, 1882-83, also *Additional Observations*, etc.

† *Phil. Transactions*, cxlii., 1856.

All of the foregoing equations make the pressure a function of the temperature on the scale of the air-thermometer. It will be assumed that the difference between that scale and the absolute scale may be neglected.

Pressure of Other Vapors. — Regnault determined also the pressure of a large number of saturated vapors at various temperatures, and deduced equations for each. The equations and the constants as determined by him for the commoner vapors are given in the following table:

	$\log p$	a	b	c
Alcohol	$a - b\alpha^n + c\beta^n$	5.4562028	4.9809960	0.04853397
Ether	$a + b\alpha^n - c\beta^n$	5.0286208	0.0002284	3.1906380
Chloroform	$a - b\alpha^n - c\beta^n$	5.2253893	2.9531281	0.0668673
Carbon bisulphide	$a - b\alpha^n - c\beta^n$	5.4011662	3.4405663	0.2857386
Carbon tetrachloride	$a - b\alpha^n - c\beta^n$	12.0962331	9.1375180	1.9674860

	$\log a$	$\log b$	n	Limits
Alcohol	1.99708557	1.9409485	$t + 20$	$-20^\circ, + 150^\circ \text{ C.}$
Ether	0.0145775	1.996877	$t + 20$	$-20^\circ, + 120^\circ \text{ C.}$
Chloroform	1.9074144	1.9868176	$t - 20$	$+20^\circ, + 164^\circ \text{ C.}$
Carbon bisulphide	1.99777628	1.9911997	$t + 20$	$-20^\circ, + 140^\circ \text{ C.}$
Carbon tetrachloride	1.9997120	1.9949780	$t + 20$	$-20^\circ, + 188^\circ \text{ C.}$

Zeuner * states that there is a slight error in Regnault's calculation of the constants for acetone, and gives instead

$$\begin{aligned} \log p &= a - b\alpha^n + c\beta^n; \\ a &= 5.3085419; \\ \log b\alpha^n &= +0.5312766 - 0.0026148t; \\ \log c\beta^n &= -0.9645222 - 0.0215592t. \end{aligned}$$

Differential Coefficient $\frac{dp}{dt}$. — As will be seen later, the differential coefficient $\frac{dp}{dt}$ is used in calculating the volume and density of saturated vapors.

From the general equation of the form,

$$\log p = a + b\alpha^n + c\beta^n,$$

differentiation gives

$$\frac{1}{p} \frac{dp}{dt} = \frac{1}{M^2} b \log \alpha \cdot \alpha^n + \frac{1}{M^2} c \log \beta \cdot \beta^n,$$

in which M is the modulus of the common system of logarithms.

* Mechanische Warmetheorie.

The equation may be written,

$$\frac{1}{\rho} \frac{dp}{dt} = A\alpha^n + B\beta^n.$$

The calculation of the values of the constants gives the following results for latitude 45° :—

French units.

B. For 0° to 100° C., mm. of mercury,

$$\log A = 8.8512729 - 10.$$

$$\log B = 6.69305 - 10.$$

$$\log \alpha_1 = 9.996725828 - 10.$$

$$\log \beta_1 = 0.0068641.$$

C. For 100° to 220° C., mm. of mercury,

$$\log A = 8.5495158 - 10.$$

$$\log B = 6.34931 - 10.$$

$$\log \alpha_1 = 9.997411296 - 10.$$

$$\log \beta_1 = 0.0076418.$$

English units.

B. For 32° to 212° F., pounds on the square inch,

$$\log A = 8.5960005 - 10.$$

$$\log B = 6.43778 - 10.$$

$$\log \alpha_2 = 9.998181015 - 10.$$

$$\log \beta_2 = 0.0038134.$$

C. For 212° to 428° F., pounds on the square inch,

$$\log A = 8.2942434 - 10.$$

$$\log B = 6.09403 - 10.$$

$$\log \alpha_2 = 9.998561831 - 10.$$

$$\log \beta_2 = 0.0042454.$$

The following table gives values for several other vapors:

	SIGN.		Log (Aα ⁿ)	Log (Bβ ⁿ)
	Aα ⁿ	Bβ ⁿ		
Alcohol	+	-	-1.1720041 - 0.0029143 t	-2.9992701 - 0.0590515 t
Ether	+	+	-1.3396624 - 0.0031223 t	-4.4616396 + 0.0145775 t
Chloroform	+	+	-1.3410130 - 0.0025856 t	-2.0667124 - 0.0131824 t
Carbon bisulphide .	+	+	-1.4339778 - 0.0022372 t	-2.0511078 - 0.0088003 t
Carbon tetrachloride	+	+	-1.8611078 - 0.0002880 t	-1.3812195 - 0.0050220 t
Aceton	+	+	-1.3268535 - 0.0026148 t t, temperature C.	-1.9064582 - 0.0215592 t

Standard Temperature. — It is customary to refer all calculations for gases to the standard conditions of the pressure of the atmosphere (760 mm. of mercury) and to the freezing-point of water. Formerly the freezing-point was taken as the standard temperature for water and steam as even now it is the initial point for tables of the properties of saturated vapors. But the investigation of the mechanical equivalent of heat by Rowland resulted in a determination of the specific heat of water with much greater delicacy than is possible by Regnault's method of mixtures, and showed that the freezing-point is not well adapted for the standard temperature for water. It has been the habit of many physicists for many years to take 15° C. as the standard temperature, and this corresponds substantially with 62° F., at which the English units of measure are standard.

Mechanical Equivalent of Heat. — The most authoritative determination of the mechanical equivalent of heat appears to be that by Rowland,* from which the work required to raise the temperature of one pound of water from 62° to 63° F. is

778 foot-pounds.

This is equivalent to

427 metre kilograms

in the metric system. Since his experiments were made this important physical constant has been investigated by several experimenters, and also a recomputation of his results has been made after a recomparison of his thermometers. The conclusion appears to be that his results may be a little small, but the differences are not important, and it is not certain that the conclusion is valid. There seems, therefore, no sufficient reason for changing the accepted values given above.

Specific Heat of Water. — The most reliable determination of the specific heat of water is that by Dr. Barnes,[†] who used an electrical method devised by Professor Callendar and himself, and who extended the method to and below freezing-point by carefully cooling water without the formation of ice to -5° C. This method gives relative results with great refinement, and gives also a good confirmation of Rowland's determination of the mechanical equivalent of heat. Dr. Barnes reports values of the specific heat of water up to 95° C. In the following table his results are quoted from 0° to 55° C.; from 55° to 95° his results have

* *Proc. Am. Acad.*, vol. xv. (N. S. vii), 1879.

† *Physical Review*, vol. xv, p. 71, 1902..

been slightly increased to join with results determined by recomputing Regnault's experiments on the heat of the liquid for water (which experiments range from 110° C. to 180° C.) by allowing for the true specific heat at low temperature from Dr. Barnes's experiments. The maximum effect of modifying Dr. Barnes's results is to increase the heat of the liquid at 95° by one-tenth of one per cent.

Temperature.		Specific Heat.	Temperature.		Specific Heat.	Temperature.		Specific Heat.
C.	F.		C.	F.		C.	F.	
0	32	1.0094	45	113	0.99760	90	194	1.00705
5	41	1.00530	50	122	0.99800	95	103	1.00855
10	50	1.00230	55	131	0.99850	100	212	1.01010
15	59	1.00030	60	140	0.99940	120	248	1.01620
20	68	0.99895	65	149	1.00040	140	284	1.02230
25	77	0.99806	70	158	1.00150	160	320	1.02850
30	86	0.99759	75	167	1.00275	180	356	1.03475
35	95	0.99735	80	176	1.00415	200	392	1.04100
40	104	0.99735	85	188	1.00557	220	428	1.04760

Heat of the Liquid. — The heat required to raise one unit of weight of any liquid from freezing-point to a given temperature is called the heat of the liquid at that temperature; and also at the corresponding pressure. Since the specific heat for water varies we may obtain the heat of the liquid by integration as indicated by the equation

$$q = \int c dt.$$

In order to use this equation it would be necessary to obtain an empirical equation connecting the specific heat with the temperature; such an equation has not been proposed and would probably be complex. Another method is to draw a curve with temperatures as abscissæ and specific heats as ordinates and integrate graphically. The fact that the specific heat is nearly equal to unity at all temperatures and that consequently the heat of the liquid for the Centigrade thermometer is not very different from the temperature suggests the following method :

Let

$$c = 1 + k$$

where k is the difference between the specific heat and unity at any temperature, k being positive or negative as the case may be.

Then

$$q = t + \int k dt,$$

which may be obtained by plotting values of k as ordinates and integrating graphically, which will have the advantage that the required curve may be drawn to a large scale and give correspondingly accurate results. The values for the heat of the liquid for water in the tables were obtained in this way.

The following table gives equations for the heats of the liquid for various substances as determined by Regnault:

HEAT OF THE LIQUID.

Alcohol	$q = 0.54754t + 0.0011218t^2 + 0.000002206t^3$
Ether	$q = 0.52901t + 0.0002959t^2$
Chloroform	$q = 0.23235t + 0.0000507t^2$
Carbon bisulphide	$q = 0.23523t + 0.0000815t^2$
Carbon tetrachloride	$q = 0.19798t + 0.00001906t^2$
Aceton	$q = 0.50643t + 0.0003965t^2$

Total Heat. — This term is defined as the heat required to raise a unit of weight of water from freezing-point to a given temperature, and to entirely evaporate it at that temperature. The experiments made by Regnault were in the reverse order; that is, steam was led from a boiler into the calorimeter and there condensed. Knowing the initial and final weights of the calorimeter, the temperature of the steam, and the initial and final temperatures of the water in the calorimeter, he was able, after applying the necessary corrections, to calculate the total heats for the several experiments.

As a conclusion of the work, he gives the following values for the total heats:—

10°	610	By equation, 609.6
63°	625	625.2
100°	637	
195°	666	

Assuming an equation of the form

$$H = A + Bt,$$

Regnault calculated the constants from the values given for 100° and 195°, and gives the equation

$$H = 606.5 + 0.305t.$$

For the Fahrenheit scale the equation becomes

$$H = 1091.7 + 0.305(t - 32).$$

An investigation of the original experimental results, allowing for the true specific heat of the water in the calorimeter, showed that the probable errors of the method of determining the total heat were larger than the deviations of the true specific heats from unity, the value assumed by Regnault; and, further, it appeared that his equation represents our best knowledge of the total heat of steam. There appears to be no reason for changing this equation till new experimental values shall be supplied. The deviation of individual experimental results from corresponding computations by the equation is likely to be one in five hundred. There is further some uncertainty whether the method of drawing steam from the boiler did not involve some error due to entrained moisture. The best check upon Regnault's results is a comparison with Knoblauch's work on superheated steam.

The total heats for various fluids are given by the following equations:

Ether	$H = 94$	$+ 0.45t - 0.00055556t^2$
Chloroform	$H = 67$	$+ 0.1375t$
Carbon bisulphide . . .	$H = 90$	$+ 0.14601t - 0.0004123t^2$
Carbon tetrachloride . .	$H = 52$	$+ 0.14625t - 0.000172t^2$
Aceton	$H = 140.5$	$+ 0.36644t - 0.000516t^2$

Specific Volume of Liquids. — The coefficient of expansion of most liquids is large as compared with that of solids, but it is small as compared with that of gases or vapors. Again, the specific volume of a vapor is large compared with that of the liquid from which it is formed. Consequently the error of neglecting the increase of volume of a liquid with the rise of temperature is small in equations relating to the thermodynamics of a saturated vapor, or of a mixture of a liquid and its vapor when a considerable part by weight of the mixture is vapor. It is, therefore, customary to consider the specific volume of a liquid to be constant.

Table XII, giving the specific volumes of various liquids, was taken from the *Phys.-Chem. Tabellen* of Landolt and Börnstein.

Volume of Water. — Table XIII gives the volumes of water compared with its volume at 4° . From 0° to 100° C., the values are those given by

Rossetti. Above 100° , the values are those calculated by the equations given by Hirn.*

Volumes of Liquids. — The volumes of liquids at high temperatures, compared with the volume at freezing-point, are represented by the following equations given by Hirn:—

Water 100° C. to 200° C. (vol. at 4° C. = unity)	$v = 1 + 0.00010867875t$	Logs.
	$+ 0.0000030073653t^2$	6 .0361445 - 10
	$+ 0.0000000028730422t^3$	4 .4781862 - 10
	$- 0.0000000000066457031t^4$	1 .4583419 - 10
		8 .8225409 - 20
Alcohol 30° C. to 160° C. (vol. at 0° C. = unity)	$v = 1 + 0.00073892285t$	Logs.
	$+ 0.0001055235t^2$	6 .8685791 - 10
	$- 0.00000092480842t^3$	3 .0223482 - 10
	$+ 0.0000000040413567t^4$	2 .9660517 - 10
		0 .5662578 - 10
Ether 30° C. to 130° C. (vol. at 0° C. = unity)	$v = 1 + 0.0013489059t$	Logs.
	$+ 0.000065537t^2$	7 .1209817 - 10
	$- 0.000000344907756t^3$	4 .8194886 - 10
	$+ 0.0000000033772062t^4$	2 .5377028 - 10
		0 .5284571 - 10
Carbon bisulphide 30° to 160° C. (vol. at 0° C. = unity)	$v = 1 + 0.0011680559t$	Logs.
	$+ 0.0000016489598t^2$	7 .0674636 - 10
	$- 0.000000081110062t^3$	4 .2172103 - 10
	$+ 0.00000000060946589t^4$	0 .9091229 - 10
		8 .7849494 - 20
Carbon tetrachloride 30° to 160° C. (vol. at 0° C. = unity)	$v = 1 + 0.0010671883t$	Logs.
	$+ 0.0000035651378t^2$	7 .0282400 - 10
	$- 0.00000014949281t^3$	4 .5520763 - 10
	$+ 0.0000000085182318t^4$	2 .1740202 - 10
		9 .9333494 - 20

Heat of Vaporization. — If the heat of the liquid be subtracted from the total heat, the remainder is called the heat of vaporization, and is represented by r , so that

$$r = H - q.$$

Internal and External Latent Heat. — The heat of vaporization overcomes external pressure, and changes the state from liquid to vapor at constant temperature and pressure. Let the specific volume of the saturated vapor be s , and that of the liquid be σ , then the change of volume is $s - \sigma = u$, on passing from the liquid to the vaporous state. The external work is

$$p(s - \sigma) = pu,$$

and the corresponding amount of heat, or the external latent heat, is

$$A p(s - \sigma) = A pu,$$

A being the reciprocal of the mechanical equivalent of heat.

* *Annales de Chimie et de Physique.*, 1867.

The heat required to do the disgregation work, or the internal latent heat, is

$$\rho = r - A p u.$$

Specific Volume and Density of Steam. — On account of the great difficulty of direct determination of the weight of saturated steam, it is customary to calculate the specific volume of steam by aid of the following equation, derived by the application of the principles of thermodynamics to the general equation representing the properties of saturated vapor: —

$$s = \frac{r}{AT} \cdot \frac{\frac{1}{dp}}{dt} + \sigma,$$

in which A is the reciprocal of the mechanical equivalent of heat, T is the temperature from the absolute zero, and σ is the volume of one unit of weight of the liquid from which the vapor is formed. The differential coefficient $\frac{dp}{dt}$ can be calculated by aid of the equations on page 8.

The absolute temperature is obtained by adding 273 to the temperature in degrees Centigrade, or 459.5 to the temperature in degrees Fahrenheit.

The volumes and densities of saturated steam given in Tables I and III were calculated by this method.

It is of interest to consider the degree of accuracy that may be expected from this method of calculating the density of saturated vapor. The value of r depends on H and q , the total heat and the heat of the liquid; the latter is now well known, but the total heat is probably in doubt to the extent of $\pm 5\%$ and may be more. The absolute temperature T appears to be better known and may be subject to an error of no more than ± 0.05 or ± 0.10 ; and the mechanical equivalent $\frac{1}{A}$ of heat is perhaps as well determined as the absolute temperature. The least satisfactory factor in the expression is the differential coefficient $\frac{dp}{dt}$, which is derived by differentiating one of the empirical equations on pages 5 and 6. It is true that the resulting equations on page 8 afford a ready means of computing values of the coefficient with great apparent accuracy, but some idea of the essential vagueness of the method may be obtained by comparing computations of the specific volume of saturated steam at $212^{\circ}\text{C}.$, a point for which

either equation B_1 or equation C_1 will give the pressure as 14,6967 pounds per square inch. The specific volume by aid of equation on page 14, using equation B_1 for determining the differential coefficient, is 26.62, while the differential coefficient from equation C_1 gives 26.71; the discrepancy is about $\frac{1}{3}\%$; or if the mean 26.66 be taken as the probable value, either computed value is subject to an error of $\pm \frac{1}{2}\%$.

Quality or Dryness Factor. — All the properties of saturated steam, such as pressure, volume, and heat of vaporization, depend on the temperature only, and are determinable either by direct experiment or by computation, and are commonly taken from tables calculated for the purpose.

Many of the problems met in engineering deal with mixtures of liquid and vapor, such as water and steam. In such problems it is convenient to represent the proportions of water and steam by a variable known as the quality or the dryness factor; this factor, x , is defined as that portion of each pound of the mixture which is steam; the remnant, $1 - x$, is consequently water.

Specific Volume of Wet Steam. — If a pound of a homogeneous mixture of water and steam is x part steam, then the specific volume may be represented by

$$v = xs + (1 - x)\sigma = xu + \sigma$$

where u is the increase of volume due to vaporization.

Intrinsic Energy. — It has been shown that the heat of vaporization can be broken into the two parts $A \rho u$ and ρ , the first being required to do external work and the second internal work; the latter part together with the heat of the liquid form the heat equivalent of the intrinsic energy so that

$$E = \frac{1}{A}(\rho + q),$$

or if only x part is vaporized

$$E = \frac{1}{A}(x\rho + q).$$

Entropy. — In the discussion of steam-engines or other heat engines, it is convenient to begin by considering the way in which steam (or other working substance) would behave if the cylinder were made of non-conducting material. Afterwards the effect of the actual material can

be investigated. The expansion line which an indicator would draw under such conditions is called an adiabatic line. Calculations for adiabatic changes of steam can be made by aid of a special function devised for the purpose and called entropy. A discussion of adiabatic actions and of entropy can be found in any text-book on Thermodynamics; for example, on pages 17 and 31 of the *Thermodynamics of the Steam Engine* by the author. It is sufficient for our present purpose to consider that entropy can be expressed numerically and that the numerical values enter into the calculation of certain engineering problems.

It is customary to represent entropy in general by ϕ , but entropy may be represented by θ in dealing with a liquid like water.

The second law of thermodynamics enables us to deduce the equation

$$d\phi = \frac{dQ}{T},$$

in which dQ is an infinitesimal amount of heat added at the absolute temperature T . This equation is the basis of the calculation of entropy.

Entropy of Vaporization. — If a pound of steam at the temperature t (or absolute temperature T) is partially vaporized, the heat expended for that purpose is xr ; the temperature being constant the above equation may be directly integrated giving

$$\phi - \phi_0 = \frac{xr}{T} = x \frac{r}{T}.$$

In Tables I, II, and III values of $\frac{r}{T}$ are given for each degree or each pound as the case may be.

Entropy of the Liquid. — The increase of entropy due to heating water from freezing-point to any temperature t may be represented by the equation

$$\theta = \int \frac{dq}{T} = \int \frac{cdt}{T}.$$

Inspection of the table on page 10 shows that the specific heat of water is but little larger than unity; it is convenient to represent it by the expression

$$c = 1 + k;$$

and this expression introduced in the preceding equation gives

$$\theta = \int \frac{dt}{T} + \int \frac{kdt}{T} = \log \frac{T}{T_0} + \int_{t_0}^t k \frac{dt}{T},$$

in which t_0 and T_0 are the temperature by the thermometer of freezing, and the corresponding absolute temperature. The first part of the above expression for the entropy of the liquid can be computed readily, and the second part (which is small) can be determined graphically with great precision. This method was used for the tables of the properties of saturated steam.

To obtain the entropy of any liquid named on page 11, we may first differentiate the proper equation to obtain dq and then integrate as indicated by the equation

$$\theta = \int \frac{dq}{T}.$$

The values given in Tables IV to IX were determined in this way, and those for the two following tables were computed in the same manner.

Entropy of a Mixture of a Liquid and its Vapor. — The increase in entropy due to heating a unit of weight of a liquid from freezing-point to the temperature t and then vaporizing x portion of it is

$$\theta + \frac{xr}{T},$$

where θ is the entropy of the liquid, r is the heat of vaporization, and T is the absolute temperature. For steam $\frac{r}{T}$ may be taken from the tables; for other vapors it must usually be calculated.

For any other state determined by x_1 and t_1 , we shall have, for the increase of entropy above that of the liquid at freezing-point,

$$\frac{x_1 r_1}{T_1} + \theta_1.$$

The change of entropy in passing from one state to another is

$$\phi - \phi_1 = \frac{xr}{T} + \theta - \frac{x_1 r_1}{T_1} - \theta_1.$$

When the condition of the mixture of a liquid and its vapor is given by the pressure and value of x , then a table giving the properties at each pound may be conveniently used for this work.

Adiabatic Equation for a Liquid and its Vapor. — During an adiabatic change the entropy is constant, so that the preceding equation gives

$$\frac{x_1 r_1}{T_1} + \theta_1 = \frac{x_2 r_2}{T_2} + \theta_2.$$

When the initial state, determined by x_1 and t_1 or p_1 , is known and the final temperature t_2 , or the final pressure p_2 , the final value x_2 may be found by this equation. The initial and final volumes may be calculated by the equations

$$v_1 = x_1 u_1 + \sigma \text{ and } v_2 = x_2 u_2 + \sigma.$$

Tables of the properties of saturated vapor commonly give the specific volume s but

$$s = u + \sigma.$$

The value of σ for water is 0.016, and for other liquids will be found in Table XII.

For example, one pound of dry steam at 100 pounds absolute has the following properties found in Table II:

$$t_1 = 327^{\circ}.6 \text{ F.} \quad \frac{r_1}{T_1} = 1.1228 \quad \theta_1 = 0.4743 \quad s_1 = 4.409 \quad x_1 = 1$$

If the final pressure is 15 pounds absolute, we have

$$t_2 = 213^{\circ}.0 \text{ F.} \quad \frac{r_2}{T_2} = 1.4358 \quad \theta_2 = 0.3141 \quad s_2 = 26.21$$

whence

$$1.5971 = 1.4358 x + 0.3141 \\ \therefore x_2 = .8935$$

The initial and final volumes are

$$v_1 = s_1 = 4.409$$

$$v_2 = x_2 u_2 + \sigma = 23.40$$

Such a problem cannot be solved inversely, that is we cannot assume a final volume and determine directly the temperature and pressure corresponding. The Temperature-Entropy Table to be explained later

will, however, give an approximate solution directly, and an exact solution by interpolation.

External Work during Adiabatic Expansion. — Since no heat is transmitted during an adiabatic expansion, all of the intrinsic energy lost is changed into external work, so that

$$W = E_1 - E_2 = \frac{1}{A} (q_1 - q_2 + x_1 \rho_1 - x_2 \rho_2)$$

For example, the external work of one pound of dry steam in expanding adiabatically from 100 pounds to 15 pounds absolute is

$$W = 778 (298.1 - 181.3 + 1 \times 802.4 - 0.8935 \times 89.30)$$

$$W = 121.3 \times 778 = 94,370 \text{ foot-pounds.}$$

Attention should be called to the unavoidable defect of this method of calculation of external work during adiabatic expansion, in that it depends on taking the difference of quantities which are of the same order of magnitude. For example, the above calculation appears to give four places of significant figures, while, as a matter of fact, the total heat H from which ρ is derived is affected by a probable error of $\frac{1}{500}$ or perhaps more. Both the quantities

$$q_1 + x_1 \rho_1 \text{ and } q_2 + x_2 \rho_2$$

have a numerical value somewhere near 1000, and an error of $\frac{1}{500}$ is nearly equivalent to two thermal units, so that the probable error of the above calculation is nearly two per cent. For a wider range of temperature the error is less, and for a narrower range it is of course larger. This matter should be borne in mind in considering the use of approximate methods of calculation, for example, by aid of a diagram like the temperature-entropy diagram.

Heat Contents. — The heat required to raise one pound of water from freezing-point to a given temperature t corresponding to a pressure p , and to vaporize a part x at that pressure is represented by

$$xr + q;$$

this quantity may be called the heat contents.

Rankine's Cycle. — An important investigation for the steam-engine may be made by aid of the accompanying figure which represents the




FIG. 1

indicator diagram from a steam-engine without clearance and with a nonconducting cylinder. Steam is admitted at an absolute pressure p_1 from a to b ; adiabatic expansion follows from b to c ; finally the steam is exhausted from c to d at the pressure p_2 . The external work during admission for one pound of steam having the quality x_1 is

$$p_1 v_1 = p_1 (x_1 u_1 + \sigma);$$

the external work during expansion is

$$E_1 - E_2 = \frac{I}{A} (q_1 - q_2 + x_1 \rho_1 - x_2 \rho_2);$$

and the external work during exhaust is

$$p_2 v_2 = p_2 (x_2 u_2 + \sigma)$$

which must be subtracted since it is done by the piston on the steam. The effective work of the cycle is

$$p_1 v_1 + E_1 - E_2 - p_2 v_2$$

or substituting the proper values

$$W = \frac{I}{A} (q_1 + x_1 \rho_1 + A p_1 x_1 u_1 - q_1 - x_2 \rho_2 - A p_2 x_2 u_2) + (p_1 + p_2) \sigma;$$

the last term is small and may be dropped.

Remembering that

$$r = \rho + A p u,$$

we have

$$W = \frac{I}{A} (q_1 + x_1 r_1 - q_2 - x_2 r_2).$$

The values of r and q may be taken from Tables I, II, or III, and the value of x_2 can be determined by aid of the equation

$$\frac{x_1 r_1}{T_1} + \theta_1 = \frac{x_2 r_2}{T_2} + \theta_2.$$

By the first law of thermodynamics the difference between the heat supplied to an engine and the heat rejected, is equivalent to the work done, provided there are no losses; therefore,

$$Q_1 - Q_2 = x_1 r_1 + q_1 - (x_2 r_2 + q_2).$$

This most important conclusion can be stated as follows: the heat changed into work by a steam-engine working on Rankine's cycle, is equal to the difference in the heat contents of the steam supplied to and exhausted by the engine.

This same expression is found in the discussion of steam-turbines.

Problems of this nature can be solved immediately by aid of the Temperature-Entropy Table.

Superheated Steam. — A dry and saturated vapor, not in contact with the liquid from which it is formed, may be heated to a temperature greater than that corresponding to the given pressure for the same vapor when saturated; such a vapor is said to be superheated. When far removed from the temperature of saturation, such a vapor follows the laws of perfect gases very nearly, but near the temperature of saturation the departure from those laws is too great to allow of calculations by them for engineering purposes.

All the characteristic equations that have been proposed have been derived from the equation

$$pv = RT,$$

which is very nearly true for the so-called perfect gases at moderate temperatures and pressures; it is, however, well known that the equation does not give satisfactory results at very high pressures or very low temperatures. To adapt this equation to represent superheated gas, a corrective term is added to the right-hand side which may most conveniently be assumed to be a function of the temperature and pressure, so that calculations by it may be made to join on to those for saturated steam.

The most satisfactory characteristic equation of this sort is that given by Knoblauch,* Linde, and Klebe,

$$pv = BT - p(1 + ap) \left[C \left(\frac{373}{T} \right)^3 - D \right]$$

p the pressure is in kilograms per square metre, v is in cubic metres, and T is the absolute temperature by the Centigrade thermometer. The constants have the following values:

$$B = 47.10, \quad a = 0.000002, \quad C = 0.031, \quad D = 0.0052.$$

In the English system of units, the pressures being in pounds per

* *Mitteilungen über Forschungsarbeiten, etc., Heft 21, S. 33, 1905.*

square foot, the volumes in cubic feet per pound, and the temperatures in the Fahrenheit scale, we have

$$pv = 85.85 T - p(1 + 0.00000976 p) \left(\frac{150,300,000}{T^3} - 0.0833 \right)$$

The following equation may be used with the pressure in pounds per square inch:

$$pv = 0.5962 T - p(1 + 0.0014 p) \left(\frac{150,300,000}{T^3} - 0.0833 \right).$$

The labor of calculation is principally in reducing the corrective term, and especially in the computation of the factor containing the temperature. Table XV gives values of this factor for each five degrees from 100° to 600° F.; the maximum error in the calculation of volume by aid of the table is about 0.4 of one per cent at 336 pounds pressure and 428° F.; that is at the upper limit of our table for saturated steam. At 150 pounds and 358° F., which is about the middle range of our table for saturated steam, the error is not more than 0.2 of one per cent, which is not greater than the probable error of the equation itself under those conditions. At lower pressures and at higher temperatures the error tends to diminish.

The following simple equation is proposed by Tumlrz* based on experiments by Battelli.

$$pv = BT - C_p,$$

where p is the pressure in kilograms per square metre, v the specific volume in cubic metres, and T the absolute temperature Centigrade. The constants to agree with Knoblauch's work should be

$$B = 47.10, \quad C = 0.016.$$

In the English system with the pressure in pounds per square foot and the volumes in cubic feet, for absolute temperatures Fahrenheit,

$$pv = 85.85 T - 0.256 p.$$

This equation has a maximum error of 0.8 of one per cent as compared with Knoblauch's equation.

Specific Heat. — Two investigations have been made of the specific heat of superheated steam at constant pressure, one by Professor Knoblauch † and Dr. Jakob and the other by Professor Thomas

* *Math. Naturw. Kl. Wien*, 1809, IIa S. 1058.

† *Mitteilungen über Forschungsarbeiten* Heft 36, p. 109.

and Mr. Short;* the results of the latter's investigation have been communicated for use in this book in anticipation of the publication of the completed report.

Professor Knoblauch's report gives the results of the investigations made under his direction in the form of a table giving specific heats at various temperatures and pressures and in a diagram, which can be found in the original memoir, and he also gives a table of mean specific heats from the temperature of saturation to various temperatures at several pressures. This latter table is given here in both the metric system and in the English system of units.

SPECIFIC HEAT OF SUPERHEATED STEAM.

Knoblauch and Jakob.

	1	2	4	6	8	10	12	14	16	18	20
<i>p</i> Kg. per Sq. Cm.	14.2	28.4	56.9	85.3	113.8	142.2	170.6	199.1	227.5	156.0	284.4
<i>p</i> Lbs. per Sq. In.	99°	120°	143°	158°	169°	179°	187°	194°	200°	206°	211°
<i>t</i> , Cent.											
<i>t</i> , Fahr.	210°	248°	289°	316°	336°	350°	368°	381°	392°	403°	412°
Fahr.	Cent.										
212°	100°	0.463									
302°	150°	0.462	0.478	0.515							
302°	200°	0.462	0.475	0.502	0.530	0.560	0.597	0.635	0.677		
482°	250°	0.463	0.474	0.495	0.514	0.532	0.552	0.570	0.588	0.609	0.635
572°	300°	0.464	0.475	0.492	0.505	0.517	0.530	0.541	0.550	0.561	0.572
662°	350°	0.468	0.477	0.492	0.503	0.512	0.522	0.529	0.536	0.543	0.550
752°	400°	0.473	0.481	0.494	0.504	0.512	0.520	0.526	0.531	0.537	0.542

The construction of this table is readily understood from the following example: — *Required* the heat needed to superheat a kilogram of steam at 4 kilograms per square centimetre from saturation to 300° C. The saturation temperature (to the nearest degree) is 143° C.; so that the steam at 300° is superheated 157°, and for this is required the heat

$$157 \times 0.492 = 77.2 \text{ calories.}$$

The experiments of Professor Knoblauch were made at 2, 4, 6, and 8 kilograms per square centimetre; the remainder of the table was obtained from the diagram which was extended by aid of cross-curves to the extent indicated. Within the limits of the experimental work the table may be used with confidence, the greatest error being probably not more than

* Thesis by Mr. Short, Cornell University.

one third of one per cent. Exterpolated results are probably less reliable than those obtained directly by Professor Thomas.

The following table gives the mean specific heat of superheated steam as measured on a facsimile of Professor Thomas's original diagram without extrapolation.

SPECIFIC HEAT OF SUPERHEATED STEAM.

Thomas and Short.

Degrees of Superheat Fahr.	Pressure Lbs. per Sq. In. (Absolute.)						
	6	15	30	50	100	200	400
20°	0.536	0.547	0.558	0.571	0.593	0.621	0.649
50°	0.522	0.532	0.542	0.555	0.575	0.600	0.621
100°	0.503	0.512	0.524	0.537	0.557	0.581	0.599
150°	0.486	0.496	0.508	0.522	0.544	0.567	0.585
200°	0.471	0.480	0.424	0.509	0.533	0.556	0.574
250°	0.456	0.466	0.481	0.496	0.522	0.546	0.564
300°	0.442	0.453	0.468	0.484	0.511	0.537	0.554

Here again the arrangement of the table can be made evident by an example:— *Required* the heat needed to superheat steam 100 degrees at 200 pounds per square inch absolute. The mean specific heat from saturation is 0.557, so that the heat required is ~~557~~ 557 thermal units.

Total Heat.—In the solution of problems that arise in engineering it is convenient to use the total amount of heat required to raise one pound of water from freezing-point to the temperature of saturated steam at the given pressure and to vaporize it and to superheat it at that pressure to the given temperature. This total heat may be represented by the expression

$$H = q + r + c_p(t - t_s)$$

where t is the temperature of the superheated steam, t_s is the temperature of saturated steam at the given pressure p , and q and r are the corresponding heat of the liquid and heat of vaporization. The mean specific heat c_p may usually be selected from one of the given tables without interpolation, as a small variation does not have a very large effect.

The total heats or heat contents of superheated steam in the temperature-entropy table were obtained by the following method. From Pro-

fessor Thomas's diagram giving mean specific heats, specific heats at various temperatures and at a given pressure were obtained, and the curves thus obtained were faired after a comparison with curves constructed with Professor Knoblauch's specific heats at those temperatures. These curves were then integrated graphically and the results checked by comparison with his mean specific heats.

Entropy. — By the entropy of superheated steam is meant the increase of entropy due to heating water from freezing-point to the temperature of saturated steam at the given pressure, to the vaporization and to the superheating at that pressure. This operation may be represented as follows:

$$\theta + \frac{r}{T_s} + \int_{T_s}^r \frac{c_p dt}{T}$$

in which T is the absolute temperature of the superheated steam, and T_s is the temperature of the saturated steam at the given pressure; θ and $\frac{r}{T}$ can be taken from Table I. The last term was obtained for the temperature-entropy table by graphical integration of curves plotted with values of $\frac{c_2}{T}$ derived from the curves of specific heats at various temperatures just described under the previous section.

Properties of Sulphur Dioxide. — One of the most interesting and important applications of the theory of superheated vapors is found in the approximate calculation of properties of certain volatile liquids which are used in refrigerating-machines, and for which we have not sufficient experimental data to construct tables in the manner followed for the fluids already discussed.

All attempts in this line have followed the example of Ledoux, who made the first attempt and who naturally took for the basis of his investigations the form of equation proposed by Zeuner for superheated steam, namely,

$$pv = BT - Cp^a.$$

Investigations by Knoblauch already discussed show that this equation can be considered only a crude approximation for steam, and consequently less confidence can be placed on investigations by its aid than we formerly thought. Nevertheless, in our present condition and until more complete experimental data are available we are constrained to

use some such approximate method, and it does not appear profitable to recompute tables at this time.

Fortunately Regnault determined the relation of temperature and pressure, and gave the following equations for pressure in millimetres of mercury, the temperature being on the Centigrade thermometer.

SULPHUR DIOXIDE.

$$\log p = a - b\alpha^n - c\beta^n$$

$$a = 5.6663790$$

$$b = 3.0146890$$

$$c = 0.1465400$$

$$\log \alpha = 9.9972989 - 10$$

$$\log \beta = 9.9872900 - 10$$

$$n = t + 28$$

$$\text{Limits, } -28, +62.$$

AMMONIA.

$$\log p = a - b\alpha^n - c\beta^n$$

$$a = 11.5043330$$

$$b = 7.4503520$$

$$c = 0.9499674$$

$$\log \alpha = 9.9996014 - 10$$

$$\log \beta = 9.9939729 - 10$$

$$n = t + 22$$

$$\text{Limits, } -22, +82.$$

The corresponding equations for pressures in pounds per square inch for temperatures Fahrenheit are:

SULPHUR DIOXIDE.

$$\log p = a - b\alpha^n - c\beta^n$$

$$a = 3.9527847$$

$$\log b = 0.4792425$$

$$\log c = 9.1659562 - 10$$

$$\log \alpha = 9.9984994 - 10$$

$$\log \beta = 9.99293890 - 10$$

$$n = t + 18^{\circ}.4 \text{ F.}$$

AMMONIA.

$$\log p = a - b\alpha^n - c\beta^n$$

$$a = 9.7907380$$

$$\log b = 0.8721769 - 10$$

$$\log c = 9.9777087 - 10$$

$$\log \alpha = 9.9997786 - 10$$

$$\log \beta = 9.9966516 - 10$$

$$n = t + 7.6^{\circ} \text{ F.}$$

In the *Thermodynamics of the Steam-engine* by the author, pages 117 to 126, this calculation has been carried out with the best ascertained properties of the superheated vapors of sulphur dioxide and ammonia with the following results:

SULPHUR DIOXIDE.

$$\text{French units, } pv = 14.5 T - 48 p^{0.22}$$

$$\text{English units, } pv = 26.4 T - 184 p^{0.22}$$

AMMONIA.

$$pv = 54.3 T - 142 p^{\frac{1}{3}}$$

$$pv = 99 T - 710 p^{\frac{1}{3}}$$

The application of these equations to the vapors when saturated gives the following results:

HEAT OF VAPORIZATION.

SULPHUR DIOXIDE.

French units, $r = 98 - 0.27t$ English units, $r = 176 - 0.27(t - 32)$

AMMONIA.

 $r = 300 - 0.8t$ $r = 540 - 0.8(t - 32)$

SPECIFIC HEAT OF THE LIQUID.

SULPHUR DIOXIDE.

 $c = 0.4$

AMMONIA.

 $c = 1.1$

Tables X and XI were calculated by aid of the equations written, and may be of use for approximate calculations, in default of more reliable tables.

Other Data. — For convenience the following data are assembled: —

Length of the metre in inches	39.37.
Weight of the kilogram in pounds	2.2046.
Weight of 1 litre (1 cu. decimetre) of mercury	13.5959 kilos.
One horse power, in foot pounds per second	550.
<i>Cheval à vapeur</i> , in kilogrammetres per second	75.
Normal pressure of the atmosphere	760 mm. of mercury. 10,333 kilos per sq. m. 14.7 lbs. per sq. in. 2116 lbs. per sq. ft. 29.921 in. of mercury.
One inch of mercury is equivalent to	0.4912 pound.
Absolute temperature of freezing-point	{ 273° C. { 491°.5 F.
Mechanical equivalent of heat	{ 427 meter-kilograms. { 778 foot-pounds,

Explanation of Tables. — Table I, which in a sense is the fundamental table for English units, has been computed by the proper equations and methods as already explained, for each degree Fahrenheit; and may be relied upon to have no errors of calculation greater than half a unit in the last significant figure. The proper degree of accuracy to be attributed to any property may be judged from the preceding statements of data and transformations. In general, attention has been given to this matter, each property being stated with the degree of accuracy considered proper, avoiding superfluous figures; an exception will be found in the earlier

parts of Tables I and II where the heat of vaporization is stated to five significant figures, while the data may appear to warrant only four; but there are conveniences in keeping one decimal place throughout these tables for this property.

Table II is made by interpolation from Table I, but the work has been carried on in such a manner that it has practically the same degree of accuracy.

Table III was computed directly from the proper equation for each degree Centigrade. English equivalents are added so that ready conversions can be made from one system to the other or a combination of the two systems may be used.

Tables IV to IX were taken from "Zeuner's Mechanische Wärmetheorie," making a correction for the true value of the mechanical equivalent of heat, instead of Joule's earlier value, and adding columns of entropy of the liquid.

Tables X and XI for sulphur dioxide and ammonia were calculated by the approximate method described earlier; though open to a considerable degree of error they may be used till better information can be obtained.

Tables XII and XIII do not appear to call for comment.

Table XIV has been computed to aid in reducing data from tests where pressures are recorded in inches of mercury. Pressures measured in inches of mercury are usually less than that of the atmosphere and the reading gives the vacuum, which is to be subtracted from the barometric reading to find the absolute pressure in inches of mercury. The table then gives the pressure in pounds per square inch which can be taken to Table II to find the properties of steam.

Table XV has been computed to reduce the labor of calculating the volume of superheated steam. It gives the value of the factor

$$\frac{150,300,000}{T^3} - 0.0833,$$

in Knoblauch's equation on page 21 for English units. By aid of this table the volume for a given temperature and pressure can be readily computed. The inverse calculation assuming the volume cannot be made directly, but such problems can be resolved by trial without much labor. If the pressure and volume are assumed the temperature can be found neglecting the correction term, and this will enable us to enter the table at nearly the right place.

TEMPERATURE-ENTROPY TABLE.

This table has been made to facilitate the solution of problems involving adiabatic action for steam and some other problems.

It gives for each degree Fahrenheit and for each hundredth of a unit of entropy, the quality, heat contents and specific volume, both for moist and for superheated steam. For convenience the pressures corresponding to the temperatures are also given.

The properties named may be more exactly stated as follows:—

Moist Steam

Quality, x ; the portion of a pound which is steam.

Heat contents, $xr + q$.

Specific volume, $v = xu + \sigma$.

Superheated Steam

Quality, $t - t_{sat}$; the number of degrees of superheating.

Heat contents, $r + q + c_p(t - t_{sat})$.

Specific volume, v .

The table is arranged in groups of eight triple columns, four on each of two pages, which face each other. Such a group is continued from the highest to the lowest temperature; then comes the next group of eight triple columns, etc. Commonly the solution of a given problem may be found in a single group or in two successive groups. It is important to note this feature of arrangement to avoid aimless search.

For engineering purposes it will be found sufficient to take the nearest temperature of saturated steam and the nearest column of entropy, and to take from the corresponding place in the table the required quantities. At the highest temperature (420° F.), the error of half a degree of temperature corresponds to an error of a pound and a half in pressure; the other properties have the following errors: heat contents 0.15 of a B.T.U., and specific volume 0.008 of a cubic foot, which latter amounts to half of one per cent. At lower temperature the variation of pressure is progressively less, but the other two properties named are affected to about the same degree. Such errors if they were carried into computations and united with other errors in such a way as to occasion greater uncertainties would be liable to be inconvenient; but when found in the

final results of computations and their limits known, are not likely to cause trouble.

On the other hand the error of half a hundredth of a unit of entropy will at 400° correspond to 0.51 of a per cent of priming or moisture in the steam, and will carry a like error into all of the work. This uncertainty of using the table without interpolation will be nearly the same throughout the table.

Should the errors named be considered to be too large in any case, greater accuracy can be had by interpolation. Direct interpolation for temperature or for entropy can be made with facility; cross-interpolation will be somewhat more troublesome.

The use of the tables can best be illustrated by a few examples.

Example 1. — Given the pressure by the gauge 150.3 pounds (165 absolute) and the priming 2.0 per cent ($x = 0.980$) to find the entropy, heat contents and specific volume. This condition is found most nearly on page 78 and gives

$$\phi = 1.54 \quad xr + q = 1176.8 \quad v = 2.699.$$

Example 2. — Given the pressure 150.3 pounds by the gauge and the temperature 508° F., to find the entropy, heat contents and specific volume. The superheating is 142° and the temperature of saturated steam corresponding to 165 pounds absolute is 366° F. These conditions are found on page 93 and give

$$\phi = 1.65 \quad r + q + c_p(t - t_s) = 1274 \quad v = 3.395.$$

Example 3. — Required the amount of heat changed into work per pound of steam for Rankine's cycle, the initial pressure being 150.3 pounds by the gauge and the exhaust being under a vacuum of 26 inches of mercury. The steam initially has 1.0 per cent of priming, and the barometer stands at 30 inches of mercury.

The exhaust pressure is 4 inches of mercury which by Table XIV corresponds to 1.96 pound. The initial absolute pressure is found by adding the equivalent of 30 inches of mercury or

$$14.7 \text{ pounds to } 150.3 \text{ giving } 165.0.$$

The solution of this problem is found in the column for entropy 1.55.

	p	t	x	$xx + q$	v
Initial	165	366	.990	1185.0	2.726
Final	2	126	.784	899.1	137.4
Heat changed into work B.T.U.				285.9	

Example 4. — Required the velocity of discharge from a nozzle which takes steam at 150° F. pounds by the gauge and expands down to 26 inches of vacuum; the initial priming being .01 and the barometer being at 30 inches.

The available heat is the same as that for the previous problem, namely, 285.9 B.T.U. for an adiabatic expansion. The velocity without friction would be

$$V = \sqrt{2 \times 32.2 \times 778 \times 285.9} = 3786.$$

If an allowance of ten per cent be made for friction the velocity will be

$$V = \sqrt{2 \times 32.2 \times 778 \times 0.90 \times 285.9} = 3590.$$

The specific volume at exit can be found as follows: — The heat that would be changed into work with an allowance of ten per cent for friction will be

$$0.90 \times 285.9 = 257.2 \text{ B.T.U.}$$

Subtracting from the initial heat contents leaves

$$1185 - 257 = 928 \text{ B.T.U.}$$

for the heat contents at 126° F. at the discharge, and this property is found for the entropy 1.60; the corresponding specific volume is 142 cubic feet.

Example 5. — Suppose that the conditions of example 3 are applied to a steam-turbine which has four pressure stages. For adiabatic expansion the available heat per stage will be

$$285.9 \div 4 = 71.4 \text{ B.T.U.}$$

This quantity may be subtracted four times successively from the initial heat contents and the results will be the heat contents for the

PROPERTIES OF STEAM AND OTHER VAPORS.

intermediate and final pressures. All the properties are to be located in the columns for entropy 1.55. The results are as follows:—

	INITIAL STAGE.	SECOND STAGE.	THIRD STAGE.	FOURTH STAGE.	DISCHARGE.
Heat contents	1185.0	1113.5	1042.1	970.6	899.1
Temperatures	366	299	237	180	126
Pressures	165	66.2	23.7	7.50	1.99

A full discussion of this method with allowance for friction and other losses together with its limitations will be found in the author's "Thermodynamics of the Steam Engine."

TABLE I.
SATURATED STEAM.

ENGLISH UNITS

Temperature Degrees Fahr.	Pressure Pounds Per Square Inch.	Heat of Vap- orization Liquid	Heat of Vap- orization	Heat Equiva- lent of Inter- nal Work	Heat Equiva- lent of Inter- nal Work	Entropy of the Liquid	Entropy of Vaporiza- tion	Specific Volume	Density	Temperature Degrees Fahr.
t	P	q	r	p	Aps	s	$\frac{r}{T}$	s	w	t
32	0.080036	0.0	1091.7	1035.8	55.9	0.0000	2.2211	3395.127	0.0002945115	32
33	0.092637	1.0	1092.0	1035.0	56.0	0.0021	2.2152	3268.123	0.0003086120	33
34	0.096339	2.0	1090.3	1034.2	56.1	0.0041	2.2094	3145.116	0.0003180121	34
35	0.100240	3.0	1089.6	1033.5	56.1	0.0061	2.2035	3029.112	0.0003301127	35
36	0.104241	4.0	1088.9	1032.7	56.2	0.0082	2.1975	2917.107	0.0003428131	36
37	0.108343	5.0	1088.2	1031.9	56.3	0.0102	2.1916	2810.104	0.0003559136	37
38	0.112644	6.1	1087.4	1031.1	56.3	0.0122	2.1855	2706.99	0.0003695138	38
39	0.117046	7.1	1086.7	1030.3	56.4	0.0142	2.1800	2607.95	0.0003836141	39
40	0.121648	8.1	1086.0	1028.5	56.5	0.0163	2.1741	2512.91	0.0003981150	40
41	0.126449	9.1	1085.3	1028.7	56.6	0.0183	2.1684	2421.87	0.0004131154	41
42	0.131351	10.1	1084.7	1028.0	56.7	0.0203	2.1628	2334.85	0.0004285161	42
43	0.136453	11.1	1084.0	1027.2	56.8	0.0223	2.1572	2249.80	0.0004446164	43
44	0.141754	12.1	1083.3	1026.4	56.9	0.0243	2.1516	2169.77	0.0004610170	44
45	0.147157	13.1	1082.6	1025.7	56.9	0.0262	2.1450	2092.74	0.0004780175	45
46	0.152858	14.1	1081.9	1024.9	57.0	0.0282	2.1402	2018.71	0.0004955181	46
47	0.158660	15.1	1081.2	1024.1	57.1	0.0302	2.1346	1947.69	0.0005136188	47
48	0.164662	16.1	1080.5	1023.3	57.2	0.0322	2.1291	1878.66	0.0005242195	48
49	0.170865	17.1	1079.8	1022.5	57.3	0.0342	2.1236	1812.63	0.0005319199	49
50	0.177366	18.1	1079.1	1021.7	57.4	0.0361	2.1180	1749.60	0.0005718205	50
51	0.183969	19.1	1078.4	1021.0	57.4	0.0381	2.1124	1689.59	0.0005923212	51
52	0.190871	20.1	1077.7	1020.2	57.5	0.0401	2.1069	1630.56	0.0006135218	52
53	0.197973	21.1	1077.0	1019.4	57.6	0.0420	2.1014	1574.54	0.0006353226	53
54	0.205276	22.1	1076.3	1018.6	57.7	0.0440	2.0960	1520.52	0.0006579233	54
55	0.212878	23.1	1075.6	1017.8	57.8	0.0459	2.0906	1468.50	0.0006812240	55
56	0.220681	24.1	1074.9	1017.0	57.9	0.0479	2.0851	1418.48	0.0007052247	56
57	0.228783	25.1	1074.2	1016.2	58.0	0.0498	2.0797	1370.46	0.0007209254	57
58	0.237086	26.1	1073.5	1015.5	58.0	0.0517	2.0744	1324.45	0.0007553263	58
59	0.245689	27.1	1072.8	1014.7	58.1	0.0537	2.0691	1279.42	0.0007816288	59
60	0.254592	28.1	1072.1	1013.9	58.2	0.0556	2.0638	1237.41	0.0008084275	60
61	0.263794	29.1	1071.4	1013.1	58.3	0.0575	2.0585	1196.40	0.0008362289	61
62	0.273190	30.1	1070.8	1012.4	58.4	0.0594	2.0533	1156.38	0.0008651304	62
63	0.282998	31.1	1070.1	1011.6	58.5	0.0614	2.0481	1118.37	0.0008945304	63

SATURATED STEAM—TABLE I.

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	Heat of Vaporization.						Entropy of the Liquid.	Entropy of Vaporiza- tion.	Specific Volume.	DENSITY.		Temperature, Degrees Fahr.
		t	p	q	r	s	t				Weight, in Pounds of One Cubic Foot.	γ	
64	0.2929	32.1	1069.4	1010.8	58.6	0.0633	2.0431	1081.37	0.0009249313	64			
65	0.3033	33.1	1068.7	1010.0	58.7	0.0652	2.0378	1044.33	0.0009562326	65			
66	0.3140	34.1	1068.0	1009.3	58.7	0.0671	2.0324	1011.33	0.0009888332	66			
67	0.3250	35.1	1067.3	1008.5	58.8	0.0690	2.0272	978.5316	0.00102235	67			
68	0.3364	36.1	1066.6	1007.7	58.9	0.0709	2.0221	946.9305	0.00105735	68			
69	0.3481	37.1	1065.9	1006.9	59.0	0.0728	2.0160	916.4294	0.00109236	69			
70	0.3602	38.1	1065.2	1006.1	59.1	0.0747	2.0118	887.0283	0.00112837	70			
71	0.3726	39.1	1064.5	1005.3	59.2	0.0766	2.0066	858.7273	0.00116538	71			
72	0.3854	40.1	1063.8	1004.5	59.3	0.0784	2.0015	831.4264	0.00120339	72			
73	0.3986	41.1	1063.1	1003.7	59.4	0.0803	1.9964	805.0254	0.00124241	73			
74	0.4122	42.1	1062.4	1002.9	59.5	0.0822	1.9914	779.6244	0.00128342	74			
75	0.4262	43.1	1061.7	1002.2	59.5	0.0841	1.9863	755.2237	0.00132542	75			
76	0.4406	44.1	1061.0	1001.4	59.6	0.0859	1.9813	731.5228	0.00136744	76			
77	0.4555	45.1	1060.3	1000.6	59.7	0.0878	1.9763	708.7219	0.00141145	77			
78	0.4708	46.1	1059.6	999.8	59.8	0.0896	1.9713	686.8212	0.00145646	78			
79	0.4865	47.1	1058.9	999.0	59.9	0.0915	1.9663	665.6204	0.00150248	79			
80	0.5027	48.1	1058.2	998.2	60.0	0.0934	1.9614	645.2197	0.00155049	80			
81	0.5194	49.1	1057.5	997.4	60.1	0.0952	1.9565	625.5191	0.00159950	81			
82	0.5365	50.1	1056.9	996.7	60.2	0.0971	1.9516	606.4185	0.00164952	82			
83	1.5542	51.1	1056.2	995.9	60.3	0.0989	1.9468	587.9178	0.00170153	83			
84	0.5723	52.1	1055.5	995.1	60.4	0.1007	1.9420	570.1171	0.00175454	84			
85	0.5910	53.1	1054.8	994.3	60.5	0.1026	1.9372	553.0166	0.00180855	85			
86	0.6102	54.1	1054.1	993.6	60.5	0.1044	1.9324	536.4160	0.00186458	86			
87	0.6299	55.1	1053.4	992.8	60.6	0.1062	1.9276	520.4156	0.00192259	87			
88	0.6502	56.1	1052.7	992.0	60.7	0.1081	1.9228	504.8148	0.00198160	88			
89	0.6711	57.1	1052.0	991.2	60.8	0.1099	1.9180	490.0144	0.00204162	89			
90	0.6925	58.1	1051.3	990.4	60.9	0.1117	1.9132	475.6139	0.00210364	90			
91	0.7146	59.1	1050.6	989.6	61.0	0.1135	1.9085	461.7136	0.00216765	91			
92	0.7372	60.1	1049.9	988.8	61.1	0.1153	1.9037	448.1131	0.00223267	92			
93	0.7605	61.1	1049.2	988.0	61.2	0.1171	1.8990	435.0126	0.00229968	93			
94	0.7844	62.1	1048.5	987.2	61.3	0.1189	1.8943	422.4122	0.00236771	94			
95	0.8090	63.1	1047.8	986.4	61.4	0.1207	1.8896	410.2118	0.00243873	95			
96	0.8342	64.1	1047.1	985.6	61.5	0.1225	1.8850	398.4115	0.00251174	96			
97	0.8601	65.0	1046.5	984.9	61.6	0.1243	1.8805	386.9110	0.00258575	97			
98	0.8867	66.0	1045.8	984.1	61.7	0.1261	1.8759	375.9107	0.00266078	98			
99	0.9140	67.0	1045.1	983.3	61.8	0.1279	1.8713	365.2105	0.00273880	99			
100	0.9421	68.0	1044.4	982.6	61.8	0.1297	1.8667	354.799	0.00281882	100			
101	0.9709	69.0	1043.7	981.8	61.9	0.1314	1.8621	344.896	0.00290084	101			
102	1.0000	70.0	1043.1	981.1	62.0	0.1332	1.8575	335.293	0.00298485	102			
103	1.031	71.0	1042.4	980.3	62.1	0.1350	1.8530	325.991	0.00306988	103			
104	1.062	72.0	1041.7	979.5	62.2	0.1368	1.8485	316.888	0.00315790	104			

SATURATED STEAM—TABLE I.

35

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch	Densities										Temperature, Degrees Cels.
		t	p	q	r	s	Heat Equivalent of Internal Work	Heat Equivalent of External Work	Entropy of the Liquid	Entropy of Vapourization	Specific Volume	Weight in Cubic Feet
105	1.094 ₃₃	73.0	1041.0	978.7	62.3	0.1385	1.8440	308.0 ₈₆	0.003247 ₈₃	0.003247 ₈₃	105	
106	1.127 ₃₃	74.0	1040.3	977.9	62.4	0.1403	1.8396	296.4 ₇₄	0.003340 ₈₄	0.003340 ₈₄	106	
107	1.160 ₃₃	75.0	1039.6	977.1	62.5	0.1421	1.8351	291.2 ₇₉	0.003434 ₈₅	0.003434 ₈₅	107	
108	1.195 ₃₅	76.0	1038.9	976.3	62.6	0.1438	1.8306	283.3 ₇₇	0.003530 ₈₆	0.003530 ₈₆	108	
109	1.210 ₃₆	77.0	1038.2	975.5	62.7	0.1456	1.8261	275.6 ₇₅	0.003628 ₈₇	0.003628 ₈₇	109	
110	1.266 ₃₈	78.0	1037.5	974.7	62.8	0.1473	1.8217	268.1 ₇₂	0.003730 ₈₄	0.003730 ₈₄	110	
111	1.304 ₃₈	79.0	1036.8	973.9	62.9	0.1491	1.8173	260.9 ₇₁	0.003834 ₈₆	0.003834 ₈₆	111	
112	1.342 ₃₉	80.0	1036.1	973.1	63.0	0.1508	1.8129	253.8 ₆₈	0.003940 ₈₉	0.003940 ₈₉	112	
113	1.381 ₄₀	81.0	1035.4	972.3	63.1	0.1526	1.8085	247.0 ₆₆	0.004049 ₉₁	0.004049 ₉₁	113	
114	1.421 ₄₁	82.0	1034.7	971.5	63.2	0.1543	1.8042	240.4 ₆₄	0.004160 ₉₄	0.004160 ₉₄	114	
115	1.462 ₄₂	83.0	1034.0	970.7	63.3	0.1560	1.7998	234.0 ₆₂	0.004274 ₉₅	0.004274 ₉₅	115	
116	1.504 ₄₃	84.0	1033.3	969.9	63.4	0.1578	1.7955	227.8 ₆₀	0.004390 ₉₉	0.004390 ₉₉	116	
117	1.547 ₄₄	85.0	1032.6	969.1	63.5	0.1595	1.7912	221.8 ₅₈	0.004509 ₁₀₁	0.004509 ₁₀₁	117	
118	1.591 ₄₄	86.0	1031.9	968.3	63.6	0.1612	1.7868	215.0 ₅₇	0.004630 ₁₀₂	0.004630 ₁₀₂	118	
119	1.636 ₄₅	87.0	1031.2	967.5	63.7	0.1630	1.7825	210.3 ₅₅	0.004755 ₁₀₃	0.004755 ₁₀₃	119	
120	1.683 ₄₇	88.0	1030.5	966.7	63.8	0.1647	1.7782	204.8 ₅₃	0.004883 ₁₀₅	0.004883 ₁₀₅	120	
121	1.730 ₄₇	89.0	1029.8	966.0	63.8	0.1664	1.7740	199.5 ₅₂	0.005018 ₁₀₆	0.005018 ₁₀₆	121	
122	1.779 ₄₉	90.0	1029.2	965.3	63.9	0.1682	1.7699	194.3 ₅₀	0.005147 ₁₀₈	0.005147 ₁₀₈	122	
123	1.829 ₅₁	91.0	1028.5	964.5	64.0	0.1699	1.7657	189.3 ₄₈	0.005283 ₁₀₉	0.005283 ₁₀₉	123	
124	1.880 ₅₁	92.0	1027.8	963.7	64.1	0.1716	1.7615	184.5 ₄₈	0.005421 ₁₁₀	0.005421 ₁₁₀	124	
125	1.932 ₅₂	93.0	1027.1	962.9	64.2	0.1733	1.7573	179.8 ₄₇	0.005562 ₁₁₁	0.005562 ₁₁₁	125	
126	1.985 ₅₅	94.0	1026.4	962.1	64.3	0.1750	1.7531	175.2 ₄₅	0.005708 ₁₁₂	0.005708 ₁₁₂	126	
127	2.040 ₅₅	95.0	1025.7	961.3	64.4	0.1767	1.7489	170.7 ₄₃	0.005857 ₁₁₄	0.005857 ₁₁₄	127	
128	2.096 ₅₆	96.0	1025.0	960.5	64.5	0.1784	1.7447	166.4 ₄₁	0.006010 ₁₁₅	0.006010 ₁₁₅	128	
129	2.153 ₅₉	97.0	1024.3	959.7	64.6	0.1801	1.7405	162.3 ₄₀	0.006165 ₁₁₆	0.006165 ₁₁₆	129	
130	2.212 ₆₀	98.0	1023.6	958.9	64.7	0.1818	1.7364	158.1 ₃₉	0.006324 ₁₁₇	0.006324 ₁₁₇	130	
131	2.272 ₆₁	99.0	1022.9	958.1	64.8	0.1835	1.7323	154.2 ₃₈	0.006485 ₁₁₈	0.006485 ₁₁₈	131	
132	2.333 ₆₃	100.0	1022.2	957.3	64.9	0.1852	1.7281	150.4 ₃₇	0.006649 ₁₁₈	0.006649 ₁₁₈	132	
133	2.396 ₆₃	101.0	1021.5	956.5	65.0	0.1869	1.7240	146.7 ₃₆	0.006817 ₁₁₉	0.006817 ₁₁₉	133	
134	2.460 ₆₄	102.0	1020.8	955.7	65.1	0.1886	1.7200	143.1 ₃₆	0.006990 ₁₂₁	0.006990 ₁₂₁	134	
135	2.526 ₆₇	103.0	1020.1	954.9	65.2	0.1902	1.7159	139.5 ₃₄	0.007166 ₁₂₂	0.007166 ₁₂₂	135	
136	2.593 ₆₇	104.0	1019.4	954.1	65.3	0.1919	1.7118	136.1 ₃₄	0.007345 ₁₂₃	0.007345 ₁₂₃	136	
137	2.662 ₆₉	105.0	1018.7	953.3	65.4	0.1936	1.7078	132.8 ₃₃	0.007528 ₁₂₃	0.007528 ₁₂₃	137	
138	2.732 ₇₂	106.0	1018.0	952.5	65.5	0.1952	1.7037	129.6 ₃₁	0.007713 ₁₂₄	0.007713 ₁₂₄	138	
139	2.804 ₇₂	107.0	1017.3	951.7	65.6	0.1969	1.6997	126.5 ₃₁	0.007894 ₁₂₅	0.007894 ₁₂₅	139	
140	2.877 ₇₃	108.0	1016.6	950.9	65.7	0.1986	1.6957	123.4 ₃₁	0.008100 ₁₂₆	0.008100 ₁₂₆	140	
141	2.953 ₇₆	109.0	1015.9	950.1	65.8	0.2002	1.6918	120.4 ₂₉	0.008298 ₁₂₇	0.008298 ₁₂₇	141	
142	3.029 ₇₆	110.0	1015.3	949.4	65.9	0.2019	1.6879	117.5 ₂₈	0.008502 ₁₂₈	0.008502 ₁₂₈	142	
143	3.108 ₇₉	111.0	1014.6	948.6	66.0	0.2036	1.6840	114.7 ₂₇	0.008710 ₁₂₉	0.008710 ₁₂₉	143	
144	3.188 ₈₂	112.0	1013.9	947.8	66.1	0.2052	1.6800	112.0 ₂₆	0.008929 ₁₂₉	0.008929 ₁₂₉	144	
145	3.270 ₈₃	113.0	1013.2	947.0	66.2	0.2069	1.6761	109.4 ₂₆	0.009143 ₁₂₉	0.009143 ₁₂₉	145	

SATURATED STEAM—TABLE I.

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	Heat of the Liquid.	Heat of Vap- oration.					Entropy of the Liquid.	Entropy of Vaporiza- tion.	Specific Volume.	Weight, in Pounds, of One Cubic Foot.	DENSITY.	Temperature, Degrees Fahr.
				t	p	q	r						
146	3.353 ₈₆	114.0	1012.5	946.2	66.3	0.2085	1.6722	106.8 ₂₅	0.009363 ₂₂₅	146			
147	3.439 ₈₇	115.0	1011.8	945.4	66.4	0.2102	1.6683	104.3 ₂₄	0.009585 ₂₂₈	147			
148	3.526 ₈₉	116.0	1011.1	944.6	66.5	0.2118	1.6644	101.9 ₂₄	0.009816 ₂₃₄	148			
149	3.615 ₉₁	117.0	1010.4	943.8	66.6	0.2135	1.6605	99.5 ₂₃₀	0.01005 ₂₃	149			
150	3.706 ₉₃	118.0	1009.7	943.0	66.7	0.2151	1.6566	97.2 ₂₂₅	0.01028 ₂₄	150			
151	3.799 ₉₅	119.0	1009.0	942.2	66.8	0.2168	1.6527	94.9 ₂₁₈	0.01052 ₂₅	151			
152	3.894 ₉₇	120.0	1008.3	941.5	66.8	0.2184	1.6488	92.8 ₂₁₃	0.01077 ₂₅	152			
153	3.991 ₉₉	121.0	1007.6	940.7	66.9	0.2200	1.6450	90.6 ₂₀₆	0.01102 ₂₆	153			
154	4.090 ₁₀₁	122.0	1006.9	939.9	67.0	0.2217	1.6412	88.6 ₂₀₁	0.01128 ₂₇	154			
155	4.191 ₁₀₄	123.0	1006.2	939.1	67.1	0.2233	1.6374	86.6 ₁₉₅	0.01155 ₂₇	155			
156	4.295 ₁₀₅	124.0	1005.5	938.3	67.2	0.2249	1.6336	84.6 ₁₉₂	0.01182 ₂₇	156			
157	4.400 ₁₀₈	125.0	1004.8	937.5	67.3	0.2265	1.6298	82.7 ₁₈₆	0.01209 ₂₇	157			
158	4.508 ₁₀₉	126.0	1004.1	936.7	67.4	0.2282	1.6261	80.8 ₁₈₁	0.01236 ₂₈	158			
159	4.617 ₁₁₀	127.0	1003.4	935.9	67.5	0.2298	1.6224	79.0 ₁₇₆	0.01264 ₂₉	159			
160	4.729 ₁₁₂	128.0	1002.7	935.1	67.6	0.2314	1.6186	77.3 ₁₇₁	0.01293 ₃₀	160			
161	4.844 ₁₁₆	129.0	1002.0	934.3	67.7	0.2330	1.6148	75.6 ₁₆₇	0.01323 ₃₀	161			
162	4.960 ₁₃₀	130.0	1001.4	933.6	67.8	0.2347	1.6111	73.9 ₁₆₃	0.01353 ₃₀	162			
163	5.079 ₁₁₉	131.0	1000.7	932.8	67.9	0.2363	1.6075	72.3 ₁₅₈	0.01383 ₃₁	163			
164	5.200 ₁₂₄	132.0	1000.0	932.0	68.0	0.2379	1.6038	70.7 ₁₅₅	0.01414 ₃₂	164			
165	5.324 ₁₂₆	133.0	999.3	931.2	68.1	0.2395	1.6002	69.1 ₁₅₀	0.01446 ₃₂	165			
166	5.450 ₁₂₉	134.0	998.6	930.4	68.2	0.2411	1.5965	67.6 ₁₄₆	0.01478 ₃₂	166			
167	5.579 ₁₃₁	135.0	997.9	929.6	68.3	0.2427	1.5928	66.2 ₁₄₄	0.01510 ₃₄	167			
168	5.710 ₁₃₂	136.0	997.2	928.8	68.4	0.2443	1.5891	64.7 ₁₄₀	0.01544 ₃₄	168			
169	5.844 ₁₃₄	137.0	996.5	928.0	68.5	0.2459	1.5855	63.3 ₁₃₇	0.01578 ₃₅	169			
170	5.981 ₁₃₉	138.0	995.8	927.2	68.6	0.2475	1.5819	62.0 ₁₃₃	0.01613 ₃₅	170			
171	6.120 ₁₄₀	139.0	995.1	926.4	68.7	0.2491	1.5783	60.6 ₁₂₈	0.01648 ₃₆	171			
172	6.262 ₁₄₂	140.0	994.4	925.6	68.8	0.2506	1.5747	59.3 ₁₂₆	0.01684 ₃₆	172			
173	6.407 ₁₄₁	141.0	993.7	924.8	68.9	0.2522	1.5711	58.1 ₁₂₃	0.01720 ₃₇	173			
174	6.554 ₁₄₇	142.0	993.0	924.1	68.9	0.2538	1.5675	56.9 ₁₂₀	0.01757 ₃₈	174			
175	6.704 ₁₅₀	143.0	992.3	923.3	69.0	0.2554	1.5639	55.7 ₁₁₆	0.01795 ₃₉	175			
176	6.858 ₁₅₆	144.0	991.6	922.5	69.1	0.2570	1.5604	54.5 ₁₁₅	0.01834 ₃₉	176			
177	7.014 ₁₅₉	145.0	990.9	921.7	69.2	0.2585	1.5569	53.3 ₁₁₂	0.01873 ₄₀	177			
178	7.173 ₁₆₂	146.0	990.2	920.9	69.3	0.2601	1.5533	52.2 ₁₀₈	0.01913 ₄₁	178			
179	7.335 ₁₆₅	147.0	989.5	920.1	69.4	0.2617	1.5498	51.1 ₁₀₅	0.01954 ₄₁	179			
180	7.500 ₁₆₈	148.0	988.8	919.3	69.5	0.2633	1.5463	50.1 ₁₀₄	0.01995 ₄₁	180			
181	7.668 ₁₇₂	149.0	988.1	918.5	69.6	0.2648	1.5428	49.1 ₁₀₁	0.02037 ₄₂	181			
182	7.840 ₁₇₄	150.1	987.4	917.7	69.7	0.2664	1.5393	48.0 ₉₈	0.02080 ₄₃	182			
183	8.014 ₁₇₈	151.1	986.7	916.9	69.8	0.2680	1.5358	47.1 ₉₆	0.02123 ₄₃	183			
184	8.192 ₁₈₁	152.1	986.0	916.1	69.9	0.2696	1.5323	46.1 ₉₅	0.02167 ₄₄	184			
185	8.373 ₁₈₅	153.1	985.3	915.3	70.0	0.2711	1.5288	45.2 ₉₂	0.02212 ₄₆	185			
186	8.558 ₁₈₈	154.1	984.6	914.5	70.1	0.2727	1.5254	44.2 ₉₀	0.02258 ₄₇	186			

SATURATED STEAM—TABLE I

37

Temperature Degrees Fahr.	Pressure Pounds per Square Inch	Heat of the Liquid	Heat of Vap- orization.	Heat Equiva- lent of Inter- nal Work.	Heat Equiva- lent of Ex- ternal Work	Fraction of the Liquid	Entropy of Vaporiza- tion	Specific Volume.	Density. Weight of Unit Volume Per Foot	Tempera- ture Fahr.
t	P	q	r	s	t	u	v	w	x	t
187	8.746 ₁₉₁	155.1	983.9	913.8	70.1	0.2742	1.5219	43.38	0.02305 _{.47}	187
188	8.937 ₁₉₅	156.1	983.2	913.0	70.2	0.2758	1.5185	42.51	0.02315 _{.48}	188
189	9.132 ₁₉₈	157.1	982.5	912.2	70.3	0.2773	1.5150	41.66	0.02340 _{.49}	189
190	9.330 ₂₀₂	158.1	981.8	911.4	70.4	0.2789	1.5116	40.83	0.02449 _{.50}	190
191	9.522 ₂₀₆	159.1	981.1	910.6	70.5	0.2805	1.5082	40.01	0.02599 _{.51}	191
192	9.735 ₂₀₉	160.1	980.4	909.8	70.6	0.2820	1.5048	39.22	0.02550 _{.51}	192
193	9.947 ₂₁₃	161.1	979.7	909.0	70.7	0.2835	1.5015	38.44	0.02601 _{.52}	193
194	10.16 ₂₁₆	162.1	979.0	908.2	70.8	0.2851	1.4981	37.68	0.02654 _{.54}	194
195	10.38 ₂₂	163.1	978.3	907.4	70.9	0.2866	1.4947	36.94	0.02708 _{.54}	195
196	10.60 ₂₂	164.1	977.6	906.7	70.9	0.2882	1.4913	36.21	0.02762 _{.53}	196
197	10.82 ₂₃	165.1	976.9	905.9	71.0	0.2897	1.4880	35.50	0.02817 _{.55}	197
198	11.05 ₂₃	166.2	976.1	905.0	71.1	0.2912	1.4846	34.81	0.02873 _{.56}	198
199	11.28 ₂₄	167.2	975.4	904.2	71.2	0.2928	1.4813	34.14	0.02929 _{.58}	199
200	11.53 ₂₄	168.2	974.7	903.4	71.3	0.2943	1.4779	33.48	0.03087 _{.59}	200
201	11.76 ₂₄	169.2	974.0	902.6	71.4	0.2958	1.4746	32.84	0.03146 _{.60}	201
202	12.00 ₂₅	170.2	973.4	901.9	71.5	0.2973	1.4714	32.20	0.03185 _{.60}	202
203	12.25 ₂₆	171.2	972.7	901.2	71.5	0.2989	1.4682	31.56	0.03164 _{.61}	203
204	12.51 ₂₆	172.2	972.0	900.4	71.6	0.3004	1.4650	30.99	0.03227 _{.62}	204
205	12.77 ₂₆	173.2	971.3	899.6	71.7	0.3019	1.4617	30.40	0.03289 _{.63}	205
206	13.03 ₂₆	174.2	970.6	898.8	71.8	0.3034	1.4585	29.87	0.03352 _{.65}	206
207	13.29 ₂₇	175.2	969.9	898.0	71.9	0.3049	1.4552	29.26	0.03418 _{.66}	207
208	13.56 ₂₈	176.2	969.2	897.2	72.0	0.3064	1.4520	28.70	0.03484 _{.67}	208
209	13.84 ₂₈	177.2	968.5	896.5	72.0	0.3079	1.4488	28.16	0.03551 _{.68}	209
210	14.12 ₂₉	178.3	967.7	895.6	72.1	0.3095	1.4455	27.63	0.03619 _{.70}	210
211	14.41 ₂₉	179.3	967.0	894.8	72.2	0.3110	1.4422	27.11	0.03689 _{.62}	211
212	14.70 ₂₉	180.3	966.3	893.9	72.4	0.3125	1.4389	26.66	0.03751 _{.65}	212
213	14.99 ₃₀	181.3	965.6	893.0	72.6	0.3140	1.4358	26.21	0.03817 _{.70}	213
214	15.29 ₃₀	182.3	964.9	892.2	72.7	0.3155	1.4326	25.73	0.03887 _{.72}	214
215	15.59 ₃₁	183.3	964.2	891.4	72.8	0.3170	1.4295	25.25	0.03956 _{.74}	215
216	15.86 ₃₁	184.3	963.5	890.6	72.9	0.3185	1.4263	24.79	0.04034 _{.74}	216
217	16.21 ₃₂	185.3	962.8	889.9	72.9	0.3200	1.4232	24.34	0.04108 _{.76}	217
218	16.53 ₃₃	186.3	962.1	889.1	73.0	0.3215	1.4200	23.90	0.04184 _{.79}	218
219	16.86 ₃₃	187.4	961.3	888.2	73.1	0.3230	1.4168	23.46	0.04263 _{.79}	219
220	17.19 ₃₃	188.4	960.6	887.3	73.1	0.3244	1.4137	23.03	0.04342 _{.81}	220
221	17.52 ₃₄	189.4	959.9	886.7	73.2	0.3259	1.4106	22.61	0.04422 _{.82}	221
222	17.86 ₃₅	190.4	959.3	886.0	73.3	0.3274	1.4075	22.20	0.04506 _{.82}	222
223	18.21 ₃₅	191.4	958.6	885.2	73.4	0.3289	1.4045	21.81	0.04587 _{.83}	223
224	18.50 ₃₅	192.4	957.9	884.4	73.5	0.3304	1.4014	21.42	0.04670 _{.84}	224
225	18.91 ₃₇	193.4	957.2	883.7	73.5	0.3319	1.3984	21.04	0.04754 _{.86}	225
226	19.28 ₃₇	194.4	956.5	882.9	73.6	0.3333	1.3954	20.67	0.04840 _{.89}	226
227	19.65 ₃₇	195.4	955.8	882.1	73.7	0.3348	1.3923	20.39	0.04929 _{.89}	227

SATURATED STEAM—TABLE I.

Temperature, Degrees Fahr. <i>t</i>	Pressure, Pounds per Square Inch. <i>p</i>	Heat of the Liquid. <i>q</i>						Entropy of the Liquid. <i>s</i>	Entropy of Vaporiza- tion. <i>r</i>	Specific Volume. <i>v</i>	Weight, in Pounds, of One Cubic Foot. <i>y</i>	DENSITY. <i>t</i>
		<i>r</i>	<i>s</i>	<i>A_{pu}</i>	<i>θ</i>	$\frac{r}{T}$						
228	20.02 ₃₈	196.5	955.0	881.2	73.8	0.3363	1.3892	19.93 ₃₅	0.05018 ₈₉			228
229	20.40 ₃₈	197.5	954.3	880.5	73.8	0.3378	1.3861	19.58 ₃₄	0.05107 ₉₀			229
230	20.78 ₃₉	198.5	953.6	879.7	73.9	0.3392	1.3831	19.24 ₃₃	0.05197 ₉₂			230
231	21.17 ₄₀	199.5	952.9	878.9	74.0	0.3407	1.3800	18.91 ₃₃	0.05289 ₉₄			231
232	21.57 ₄₁	200.5	952.2	878.2	74.0	0.3422	1.3770	18.58 ₃₂	0.05383 ₉₅			232
233	21.98 ₄₁	201.5	951.5	877.4	74.1	0.3436	1.3740	18.26 ₃₂	0.05478 ₉₇			233
234	22.39 ₄₁	202.5	950.8	876.6	74.2	0.3451	1.3710	17.94 ₃₁	0.05575 ₉₉			234
235	22.80 ₄₃	203.6	950.0	875.7	74.3	0.3466	1.3679	17.63 ₃₀	0.05674 ₉₉			235
236	23.23 ₄₃	204.6	949.3	874.9	74.4	0.3480	1.3649	17.33 ₃₀	0.05773 ₁₀₁			236
237	23.66 ₄₃	205.6	948.6	874.2	74.4	0.3495	1.3619	17.03 ₂₉	0.05874 ₁₀₂			237
238	24.09 ₄₄	206.6	947.9	873.4	74.5	0.3509	1.3590	16.74 ₂₉	0.05976 ₁₀₃			238
239	24.53 ₄₅	207.6	947.2	872.6	74.6	0.3524	1.3560	16.45 ₂₈	0.06079 ₁₀₅			239
240	24.98 ₄₆	208.6	946.5	871.9	74.6	0.3538	1.3531	16.17 ₂₇	0.06184 ₁₀₆			240
241	25.44 ₄₆	209.6	945.8	871.1	74.7	0.3553	1.3502	15.90 ₂₇	0.06290 ₁₀₇			241
242	25.90 ₄₇	210.7	945.1	870.3	74.8	0.3567	1.3473	15.63 ₂₆	0.06397 ₁₀₉			242
243	26.37 ₄₈	211.7	944.4	869.5	74.9	0.3582	1.3444	15.37 ₂₆	0.06506 ₁₁₁			243
244	26.85 ₄₈	212.7	943.7	868.7	75.0	0.3596	1.3415	15.11 ₂₅	0.06617 ₁₁₂			244
245	27.33 ₄₉	213.7	943.0	868.0	75.0	0.3611	1.3386	14.86 ₂₅	0.06729 ₁₁₄			245
246	27.82 ₅₀	214.7	942.3	867.2	75.1	0.3625	1.3357	14.61 ₂₄	0.06843 ₁₁₅			246
247	28.32 ₅₀	215.7	941.6	866.4	75.2	0.3639	1.3328	14.37 ₂₃	0.06958 ₁₁₆			247
248	28.82 ₅₂	216.7	940.9	865.6	75.3	0.3654	1.3299	14.14 ₂₃	0.07074 ₁₁₈			248
249	29.34 ₅₂	217.7	940.2	864.8	75.4	0.3668	1.3270	13.91 ₂₃	0.07192 ₁₂₀			249
250	29.86 ₅₂	218.8	939.4	864.0	75.4	0.3683	1.3241	13.68 ₂₂	0.07312 ₁₂₁			250
251	30.38 ₅₄	219.8	938.7	863.2	75.5	0.3697	1.3212	13.46 ₂₂	0.07433 ₁₂₂			251
252	30.92 ₅₄	220.8	938.0	862.4	75.6	0.3711	1.3183	13.24 ₂₂	0.07555 ₁₂₆			252
253	31.46 ₅₅	221.8	937.3	861.6	75.7	0.3726	1.3154	13.09 ₂₁	0.07680 ₁₂₈			253
254	32.01 ₅₆	222.8	936.6	860.9	75.7	0.3740	1.3126	12.81 ₂₁	0.07808 ₁₂₈			254
255	32.57 ₅₇	223.8	935.9	860.1	75.8	0.3754	1.3098	12.60 ₂₁	0.07936 ₁₂₈			255
256	33.14 ₅₇	224.9	935.1	859.2	75.9	0.3768	1.3070	12.39 ₂₀	0.08064 ₁₃₂			256
257	33.71 ₅₈	225.9	934.4	858.4	76.0	0.3782	1.3042	12.19 ₁₉	0.08196 ₁₃₃			257
258	34.29 ₅₉	226.9	933.7	857.7	76.0	0.3797	1.3014	12.00 ₁₉	0.08329 ₁₃₅			258
259	34.88 ₆₀	227.9	933.0	856.9	76.1	0.3811	1.2986	11.81 ₁₉	0.08464 ₁₃₇			259
260	35.48 ₆₁	229.0	932.2	856.0	76.2	0.3825	1.2957	11.62 ₁₈	0.08601 ₁₃₈			260
261	36.09 ₆₂	230.0	931.5	855.2	76.3	0.3839	1.2929	11.44 ₁₈	0.08739 ₁₄₀			261
262	36.71 ₆₂	231.0	930.9	854.5	76.4	0.3853	1.2902	11.26 ₁₈	0.08879 ₁₄₂			262
263	37.33 ₆₃	232.0	930.2	853.8	76.4	0.3867	1.2875	11.08 ₁₇	0.09021 ₁₄₃			263
264	37.96 ₆₄	233.0	929.5	853.0	76.5	0.3881	1.2848	10.91 ₁₇	0.09164 ₁₄₅			264
265	38.60 ₆₅	234.0	928.8	852.2	76.6	0.3895	1.2820	10.74 ₁₇	0.09309 ₁₄₆			265
266	39.25 ₆₆	235.0	928.1	851.4	76.7	0.3909	1.2792	10.57 ₁₆	0.09455 ₁₅₀			266
267	39.91 ₆₇	236.1	927.3	850.6	76.7	0.3923	1.2764	10.41 ₁₆	0.09604 ₁₅₁			267
268	40.58 ₆₈	237.1	926.6	849.8	76.8	0.3937	1.2737	10.25 ₁₆	0.09755 ₁₅₂			268

SATURATED STEAM—TABLE I.

39

Temperature Degrees Fahr.	Pressure, Pounds per Square Inch.	Heat of the Liquid,	Heat Equivalent of Internal Work						Entropy of the Liquid	Entropy of Vaporization	Specific Volume	Density	Temperature Degrees Fahr.
			t	P	q	r	s	Aps					
269	41.26 ⁶⁹	238.1	925.9	819.0	76.9	0.3951	1	2710	10.09	0.00007	153	269	
270	41.95 ⁶⁹	239.1	925.2	818.2	77.0	0.3965	1	2883	9.337	15	0.1000	270	
271	42.64 ⁶⁹	240.2	924.4	817.4	77.0	0.3979	1	2655	9.785	152	0.1022	271	
272	43.35 ⁷¹	241.2	923.7	816.6	77.1	0.3993	1	2628	9.636	147	0.1038	272	
273	44.06 ⁷¹	242.2	923.0	815.8	77.2	0.4007	1	2601	9.483	147	0.1054	273	
274	44.78 ⁷²	243.2	922.3	815.0	77.3	0.4021	1	2574	9.345	144	0.1070	274	
275	45.52 ⁷⁴	244.2	921.6	814.2	77.4	0.4035	1	2547	9.204	143	0.1086	275	
276	46.26 ⁷⁴	245.3	920.8	813.4	77.4	0.4049	1	2520	9.068	138	0.1103	276	
277	47.01 ⁷⁵	246.3	920.1	812.6	77.5	0.4063	1	2493	8.930	136	0.1120	277	
278	47.77 ⁷⁵	247.3	919.4	811.8	77.6	0.4077	1	2466	8.796	132	0.1137	278	
279	48.55 ⁷⁸	248.3	918.7	811.0	77.7	0.4091	1	2440	8.664	128	0.1154	279	
280	49.33 ⁷⁸	249.4	917.9	810.2	77.7	0.4104	1	2413	8.536	128	0.1171	280	
281	50.12 ⁸⁰	250.4	917.2	809.4	77.8	0.4118	1	2387	8.410	126	0.1189	281	
282	50.92 ⁸⁰	251.4	916.6	808.7	77.9	0.4132	1	2361	8.285	125	0.1207	282	
283	51.74 ⁸²	252.4	915.9	807.9	78.0	0.4146	1	2335	8.162	123	0.1225	283	
284	52.56 ⁸³	253.4	915.2	807.1	78.1	0.4160	1	2309	8.043	121	0.1243	284	
285	53.39 ⁸³	254.5	914.4	806.3	78.1	0.4173	1	2283	7.920	117	0.1261	285	
286	54.24 ⁸⁵	255.5	913.7	805.5	78.2	0.4187	1	2257	7.810	116	0.1280	286	
287	55.09 ⁸⁵	256.5	913.0	804.7	78.3	0.4201	1	2231	7.697	111	0.1299	287	
288	55.96 ⁸⁷	257.5	912.3	803.9	78.4	0.4215	1	2205	7.582	111	0.1318	288	
289	56.83 ⁸⁷	258.6	911.5	803.1	78.4	0.4228	1	2179	7.475	111	0.1337	289	
290	57.72 ⁹⁰	259.6	910.8	802.3	78.5	0.4242	1	2153	7.367	105	0.1357	290	
291	58.62 ⁹⁰	260.6	910.1	801.5	78.6	0.4255	1	2127	7.262	105	0.1377	291	
292	59.53 ⁹¹	261.6	909.4	800.7	78.7	0.4269	1	2101	7.150	103	0.1397	292	
293	60.45 ⁹³	262.7	908.6	809.9	78.7	0.4283	1	2075	7.056	100	0.1417	293	
294	61.38 ⁹³	263.7	907.9	809.1	78.8	0.4297	1	2049	6.956	100	0.1437	294	
295	62.33 ⁹⁵	264.7	907.2	808.3	78.9	0.4310	1	2023	6.857	99	0.1458	295	
296	63.28 ⁹⁷	265.7	906.5	807.5	79.0	0.4324	1	1998	6.760	98	0.1479	296	
297	64.25 ⁹⁷	266.7	905.8	806.7	79.1	0.4337	1	1972	6.665	95	0.1500	297	
298	65.23 ⁹⁸	267.8	905.0	805.9	79.1	0.4351	1	1947	6.571	94	0.1521	298	
299	66.22 ⁹⁹	268.8	904.3	805.1	79.2	0.4364	1	1922	6.479	92	0.1543	299	
300	67.22 ¹⁰⁰	269.8	903.6	804.3	79.3	0.4378	1	1897	6.388	91	0.1565	300	
301	68.24 ¹⁰²	270.8	902.9	803.5	79.4	0.4391	1	1872	6.300	88	0.1587	301	
302	69.27 ¹⁰³	271.9	902.2	802.8	79.4	0.4405	1	1847	6.213	87	0.1609	302	
303	70.30 ¹⁰³	272.9	901.5	802.0	79.5	0.4418	1	1822	6.120	87	0.1632	303	
304	71.36 ¹⁰⁶	273.9	900.8	801.2	79.6	0.4432	1	1799	6.042	84	0.1655	304	
305	72.42 ¹⁰⁸	274.9	900.1	800.4	79.7	0.4445	1	1774	5.959	83	0.1678	305	
306	73.50 ¹⁰⁸	276.0	899.3	801.5	79.8	0.4458	1	1749	5.878	81	0.1701	306	
307	74.59 ¹⁰⁹	277.0	898.6	801.8	79.8	0.4472	1	1724	5.798	80	0.1725	307	
308	75.69 ¹¹¹	278.0	897.9	818.0	79.9	0.4485	1	1699	5.718	78	0.1749	308	
309	76.80 ¹¹¹	279.1	897.1	817.1	80.0	0.4499	1	1674	5.640	76	0.1773	309	

SATURATED STEAM—TABLE I.

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	Heat of the Liquid.		Heat of Vap- orization.	Heat Equiva- lent of Inter- nal Work.	Heat Equiva- lent of Ex- ternal Work.	Entropy of the Liquid.	Entropy of Vapori- ation.	Specific Volume.	Weight, in Pounds, of One Cubic Foot.	DENSITY.	Temperature, Degrees Fahr.
		t	p	q	r	s	T	γ				
310	77.93 ₁₁₄	280.1	896.4	816.4	80.0	0.4512	1.1649	5.564 ₇₄	0.1797 ₂₄	0.1797 ₂₄	310	
311	79.07 ₁₁₆	281.1	895.7	815.6	80.1	0.4525	1.1625	5.490 ₇₄	0.1821 ₂₅	0.1821 ₂₅	311	
312	80.23 ₁₁₆	282.1	895.0	814.8	80.2	0.4538	1.1600	5.416 ₇₃	0.1846 ₂₅	0.1846 ₂₅	312	
313	81.39 ₁₁₈	283.2	894.2	813.9	80.3	0.4552	1.1576	5.343 ₇₁	0.1871 ₂₆	0.1871 ₂₆	313	
314	82.57 ₁₂₀	284.2	893.5	813.2	80.3	0.4565	1.1551	5.272 ₇₁	0.1897 ₂₆	0.1897 ₂₆	314	
315	83.77 ₁₂₁	285.2	892.8	812.4	80.4	0.4578	1.1527	5.201 ₆₉	0.1923 ₂₆	0.1923 ₂₆	315	
316	84.98 ₁₂₂	286.2	892.1	811.6	80.5	0.4592	1.1503	5.132 ₆₈	0.1949 ₂₆	0.1949 ₂₆	316	
317	86.20 ₁₂₃	287.3	891.3	810.8	80.5	0.4605	1.1479	5.064 ₆₇	0.1975 ₂₆	0.1975 ₂₆	317	
318	87.43 ₁₂₅	288.3	890.6	810.0	80.6	0.4618	1.1455	4.997 ₆₆	0.2001 ₂₇	0.2001 ₂₇	318	
319	88.68 ₁₂₇	289.3	889.9	809.2	80.7	0.4631	1.1431	4.931 ₆₄	0.2028 ₂₇	0.2028 ₂₇	319	
320	89.95 ₁₂₈	290.4	889.1	808.3	80.8	0.4644	1.1407	4.867 ₆₄	0.2055 ₂₇	0.2055 ₂₇	320	
321	91.23 ₁₂₉	291.4	888.4	807.6	80.8	0.4658	1.1383	4.803 ₆₂	0.2082 ₂₇	0.2082 ₂₇	321	
322	92.52 ₁₃₀	292.4	887.8	806.9	80.9	0.4671	1.1360	4.741 ₆₂	0.2109 ₂₈	0.2109 ₂₈	322	
323	93.82 ₁₃₂	293.4	887.1	806.1	81.0	0.4684	1.1336	4.679 ₆₁	0.2137 ₂₈	0.2137 ₂₈	323	
324	95.14 ₁₃₄	294.5	886.3	805.3	81.0	0.4697	1.1312	4.618 ₆₀	0.2165 ₂₈	0.2165 ₂₈	324	
325	96.48 ₁₃₅	295.5	885.6	804.5	81.1	0.4710	1.1289	4.558 ₅₉	0.2194 ₂₉	0.2194 ₂₉	325	
326	97.83 ₁₃₇	296.5	884.9	803.7	81.2	0.4723	1.1265	4.499 ₅₇	0.2223 ₂₉	0.2223 ₂₉	326	
327	99.20 ₁₄	297.5	884.1	802.9	81.2	0.4736	1.1241	4.442 ₅₇	0.2252 ₂₉	0.2252 ₂₉	327	
328	100.6 ₁₄	298.6	883.4	802.1	81.3	0.4749	1.1218	4.385 ₅₆	0.2281 ₂₉	0.2281 ₂₉	328	
329	102.0 ₁₄	299.6	882.7	801.3	81.4	0.4762	1.1194	4.329 ₅₆	0.2310 ₃₀	0.2310 ₃₀	329	
330	103.4 ₁₄	300.6	882.0	800.6	81.4	0.4775	1.1171	4.273 ₅₄	0.2340 ₃₀	0.2340 ₃₀	330	
331	104.8 ₁₄	301.7	881.2	799.7	81.5	0.4789	1.1147	4.219 ₅₄	0.2370 ₃₁	0.2370 ₃₁	331	
332	106.2 ₁₅	302.7	880.5	798.9	81.6	0.4802	1.1124	4.165 ₅₂	0.2400 ₃₁	0.2400 ₃₁	332	
333	107.7 ₁₅	303.7	879.8	798.2	81.6	0.4815	1.1101	4.113 ₅₂	0.2431 ₃₁	0.2431 ₃₁	333	
334	109.2 ₁₅	304.8	879.0	797.3	81.7	0.4828	1.1078	4.061 ₅₁	0.2462 ₃₁	0.2462 ₃₁	334	
335	110.7 ₁₅	305.8	878.3	796.5	81.8	0.4841	1.1055	4.010 ₅₁	0.2493 ₃₁	0.2493 ₃₁	335	
336	112.2 ₁₅	306.8	877.6	795.8	81.8	0.4854	1.1032	3.960 ₅₀	0.2525 ₃₂	0.2525 ₃₂	336	
337	113.7 ₁₅	307.9	876.8	794.9	81.9	0.4867	1.1009	3.910 ₄₉	0.2557 ₃₃	0.2557 ₃₃	337	
338	115.2 ₁₆	308.9	876.1	794.1	82.0	0.4880	1.0986	3.861 ₄₉	0.2590 ₃₃	0.2590 ₃₃	338	
339	116.8 ₁₅	309.9	875.4	793.4	82.0	0.4892	1.0963	3.813 ₄₈	0.2623 ₃₃	0.2623 ₃₃	339	
340	118.3 ₁₆	310.9	874.7	792.6	82.1	0.4905	1.0940	3.766 ₄₇	0.2656 ₃₃	0.2656 ₃₃	340	
341	119.9 ₁₆	312.0	873.9	791.7	82.2	0.4918	1.0918	3.719 ₄₅	0.2689 ₃₄	0.2689 ₃₄	341	
342	121.5 ₁₆	313.0	873.3	791.1	82.2	0.4931	1.0896	3.674 ₄₅	0.2722 ₃₄	0.2722 ₃₄	342	
343	123.1 ₁₇	314.0	872.6	790.3	82.3	0.4944	1.0873	3.629 ₄₅	0.2756 ₃₄	0.2756 ₃₄	343	
344	124.8 ₁₆	315.1	871.8	789.4	82.4	0.4957	1.0850	3.584 ₄₄	0.2790 ₃₅	0.2790 ₃₅	344	
345	126.4 ₁₇	316.1	871.1	788.7	82.4	0.4970	1.0828	3.540 ₄₄	0.2825 ₃₅	0.2825 ₃₅	345	
346	128.1 ₁₇	317.1	870.4	787.9	82.5	0.4982	1.0806	3.497 ₄₃	0.2860 ₃₆	0.2860 ₃₆	346	
347	129.8 ₁₇	318.2	869.6	787.0	82.6	0.4995	1.0783	3.455 ₄₂	0.2895 ₃₅	0.2895 ₃₅	347	
348	131.5 ₁₇	319.2	868.9	786.3	82.6	0.5008	1.0761	3.413 ₄₂	0.2930 ₃₆	0.2930 ₃₆	348	
349	133.2 ₁₇	320.2	868.2	785.5	82.7	0.5021	1.0738	3.371 ₄₁	0.2966 ₃₆	0.2966 ₃₆	349	
350	134.9 ₁₈	321.3	867.4	784.7	82.7	0.5034	1.0716	3.330 ₄₀	0.3002 ₃₇	0.3002 ₃₇	350	

SATURATED STEAM—TABLE I.

41

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch	Heat of the Liquid.	γ	γ'	Heat Equivalent of Intern- al Work	Heat Equiva- lent of Ex- ternal Work	θ	Entropy of the Liquid	Entropy of Vaporiza- tion	$\frac{\gamma}{T}$	μ	Specific Volume	Weight in Pounds per Cubic Foot	Dissociation Coefficients	δ	Temperature, Degrees Fahr.
351	136.7 ₁₈	322.3	866.7	783.9	82.8	0.5047	1.0693	3.290 ₃₉	0.3010 ₃₉	0.3010 ₃₉	3.290 ₃₉	3.290 ₃₉	0.3010 ₃₉	0.3010 ₃₉	0.3010 ₃₉	351
352	138.5 ₁₈	323.3	866.0	783.1	82.9	0.5059	1.0671	3.251 ₃₉	0.3074 ₃₇	0.3074 ₃₇	3.251 ₃₉	3.251 ₃₉	0.3074 ₃₇	0.3074 ₃₇	0.3074 ₃₇	352
353	140.3 ₁₈	324.4	865.2	782.3	82.9	0.5072	1.0649	3.212 ₃₈	0.3113 ₃₈	0.3113 ₃₈	3.212 ₃₈	3.212 ₃₈	0.3113 ₃₈	0.3113 ₃₈	0.3113 ₃₈	353
354	142.1 ₁₈	325.4	864.5	781.5	83.0	0.5085	1.0627	3.174 ₃₆	0.3151 ₃₄	0.3151 ₃₄	3.174 ₃₆	3.174 ₃₆	0.3151 ₃₄	0.3151 ₃₄	0.3151 ₃₄	354
355	143.9 ₁₈	326.4	863.8	780.8	83.0	0.5097	1.0605	3.136 ₃₈	0.3189 ₃₉	0.3189 ₃₉	3.136 ₃₈	3.136 ₃₈	0.3189 ₃₉	0.3189 ₃₉	0.3189 ₃₉	355
356	145.7 ₁₉	327.5	863.0	779.9	83.1	0.5110	1.0583	3.098 ₃₇	0.3228 ₃₉	0.3228 ₃₉	3.098 ₃₇	3.098 ₃₇	0.3228 ₃₉	0.3228 ₃₉	0.3228 ₃₉	356
357	147.6 ₁₉	328.5	862.3	779.1	83.2	0.5123	1.0561	3.061 ₃₆	0.3267 ₃₉	0.3267 ₃₉	3.061 ₃₆	3.061 ₃₆	0.3267 ₃₉	0.3267 ₃₉	0.3267 ₃₉	357
358	149.5 ₁₉	329.5	861.6	778.4	83.2	0.5135	1.0540	3.025 ₃₆	0.3306 ₃₉	0.3306 ₃₉	3.025 ₃₆	3.025 ₃₆	0.3306 ₃₉	0.3306 ₃₉	0.3306 ₃₉	358
359	151.4 ₁₉	330.6	860.8	777.5	83.3	0.5148	1.0518	2.989 ₃₅	0.3345 ₄₀	0.3345 ₄₀	2.989 ₃₅	2.989 ₃₅	0.3345 ₄₀	0.3345 ₄₀	0.3345 ₄₀	359
360	153.3 ₂₀	331.6	860.1	776.8	83.3	0.5161	1.0496	2.954 ₃₅	0.3385 ₄₁	0.3385 ₄₁	2.954 ₃₅	2.954 ₃₅	0.3385 ₄₁	0.3385 ₄₁	0.3385 ₄₁	360
361	155.3 ₂₀	332.6	859.4	776.0	83.4	0.5173	1.0475	2.919 ₃₅	0.3426 ₄₁	0.3426 ₄₁	2.919 ₃₅	2.919 ₃₅	0.3426 ₄₁	0.3426 ₄₁	0.3426 ₄₁	361
362	157.2 ₂₀	333.7	858.7	775.3	83.4	0.5186	1.0453	2.885 ₃₄	0.3467 ₄₁	0.3467 ₄₁	2.885 ₃₄	2.885 ₃₄	0.3467 ₄₁	0.3467 ₄₁	0.3467 ₄₁	362
363	159.2 ₂₀	334.7	858.0	774.5	83.5	0.5199	1.0432	2.851 ₃₃	0.3508 ₄₁	0.3508 ₄₁	2.851 ₃₃	2.851 ₃₃	0.3508 ₄₁	0.3508 ₄₁	0.3508 ₄₁	363
364	161.2 ₂₀	335.7	857.3	773.7	83.6	0.5211	1.0410	2.818 ₃₃	0.3545 ₄₁	0.3545 ₄₁	2.818 ₃₃	2.818 ₃₃	0.3545 ₄₁	0.3545 ₄₁	0.3545 ₄₁	364
365	163.2 ₂₀	336.8	856.5	772.9	83.6	0.5224	1.0389	2.785 ₃₃	0.3591 ₄₂	0.3591 ₄₂	2.785 ₃₃	2.785 ₃₃	0.3591 ₄₂	0.3591 ₄₂	0.3591 ₄₂	365
366	165.2 ₂₁	337.8	855.8	772.1	83.7	0.5236	1.0367	2.753 ₃₂	0.3633 ₄₂	0.3633 ₄₂	2.753 ₃₂	2.753 ₃₂	0.3633 ₄₂	0.3633 ₄₂	0.3633 ₄₂	366
367	167.3 ₂₁	338.8	855.1	771.4	83.7	0.5249	1.0346	2.721 ₃₁	0.3675 ₄₂	0.3675 ₄₂	2.721 ₃₁	2.721 ₃₁	0.3675 ₄₂	0.3675 ₄₂	0.3675 ₄₂	367
368	169.4 ₂₁	339.9	854.3	770.6	83.7	0.5261	1.0324	2.689 ₃₁	0.3718 ₄₃	0.3718 ₄₃	2.689 ₃₁	2.689 ₃₁	0.3718 ₄₃	0.3718 ₄₃	0.3718 ₄₃	368
369	171.5 ₂₁	340.0	853.6	769.8	83.8	0.5274	1.0303	2.659 ₃₁	0.3761 ₄₄	0.3761 ₄₄	2.659 ₃₁	2.659 ₃₁	0.3761 ₄₄	0.3761 ₄₄	0.3761 ₄₄	369
370	173.6 ₂₁	341.9	852.9	769.0	83.9	0.5286	1.0281	2.628 ₃₀	0.3805 ₄₄	0.3805 ₄₄	2.628 ₃₀	2.628 ₃₀	0.3805 ₄₄	0.3805 ₄₄	0.3805 ₄₄	370
371	175.7 ₂₁	343.0	852.1	768.2	83.9	0.5299	1.0260	2.598 ₃₀	0.3849 ₄₅	0.3849 ₄₅	2.598 ₃₀	2.598 ₃₀	0.3849 ₄₅	0.3849 ₄₅	0.3849 ₄₅	371
372	177.9 ₂₂	344.0	851.4	767.4	84.0	0.5311	1.0239	2.568 ₂₉	0.3894 ₄₅	0.3894 ₄₅	2.568 ₂₉	2.568 ₂₉	0.3894 ₄₅	0.3894 ₄₅	0.3894 ₄₅	372
373	180.1 ₂₂	345.0	850.7	766.7	84.0	0.5324	1.0217	2.539 ₂₉	0.3939 ₄₅	0.3939 ₄₅	2.539 ₂₉	2.539 ₂₉	0.3939 ₄₅	0.3939 ₄₅	0.3939 ₄₅	373
374	182.3 ₂₂	346.1	849.9	765.8	84.1	0.5336	1.0196	2.510 ₂₉	0.3984 ₄₅	0.3984 ₄₅	2.510 ₂₉	2.510 ₂₉	0.3984 ₄₅	0.3984 ₄₅	0.3984 ₄₅	374
375	184.5 ₂₂	347.1	849.2	765.1	84.1	0.5349	1.0175	2.481 ₂₈	0.4030 ₄₇	0.4030 ₄₇	2.481 ₂₈	2.481 ₂₈	0.4030 ₄₇	0.4030 ₄₇	0.4030 ₄₇	375
376	186.7 ₂₂	348.2	848.4	764.2	84.2	0.5361	1.0154	2.453 ₂₈	0.4077 ₄₇	0.4077 ₄₇	2.453 ₂₈	2.453 ₂₈	0.4077 ₄₇	0.4077 ₄₇	0.4077 ₄₇	376
377	189.0 ₂₃	349.2	847.7	763.5	84.2	0.5374	1.0133	2.425 ₂₇	0.4124 ₄₇	0.4124 ₄₇	2.425 ₂₇	2.425 ₂₇	0.4124 ₄₇	0.4124 ₄₇	0.4124 ₄₇	377
378	191.3 ₂₃	350.2	847.0	762.7	84.3	0.5386	1.0113	2.398 ₂₇	0.4171 ₄₇	0.4171 ₄₇	2.398 ₂₇	2.398 ₂₇	0.4171 ₄₇	0.4171 ₄₇	0.4171 ₄₇	378
379	193.6 ₂₃	351.3	846.2	761.9	84.3	0.5398	1.0092	2.371 ₂₇	0.4218 ₄₇	0.4218 ₄₇	2.371 ₂₇	2.371 ₂₇	0.4218 ₄₇	0.4218 ₄₇	0.4218 ₄₇	379
380	195.9 ₂₃	352.3	845.5	761.2	84.3	0.5411	1.0072	2.344 ₂₆	0.4266 ₄₈	0.4266 ₄₈	2.344 ₂₆	2.344 ₂₆	0.4266 ₄₈	0.4266 ₄₈	0.4266 ₄₈	380
381	198.2 ₂₄	353.3	844.8	760.4	84.4	0.5423	1.0050	2.318 ₂₆	0.4314 ₄₈	0.4314 ₄₈	2.318 ₂₆	2.318 ₂₆	0.4314 ₄₈	0.4314 ₄₈	0.4314 ₄₈	381
382	200.6 ₂₄	354.4	844.1	759.7	84.4	0.5435	1.0030	2.292 ₂₅	0.4362 ₄₈	0.4362 ₄₈	2.292 ₂₅	2.292 ₂₅	0.4362 ₄₈	0.4362 ₄₈	0.4362 ₄₈	382
383	203.0 ₂₄	355.4	843.4	758.9	84.5	0.5448	1.0010	2.267 ₂₅	0.4411 ₄₉	0.4411 ₄₉	2.267 ₂₅	2.267 ₂₅	0.4411 ₄₉	0.4411 ₄₉	0.4411 ₄₉	383
384	205.4 ₂₅	356.5	842.6	758.1	84.5	0.5460	0.9990	2.242 ₂₅	0.4460 ₅₁	0.4460 ₅₁	2.242 ₂₅	2.242 ₂₅	0.4460 ₅₁	0.4460 ₅₁	0.4460 ₅₁	384
385	207.9 ₂₅	357.5	841.9	757.3	84.6	0.5473	0.9969	2.217 ₂₅	0.4511 ₅₁	0.4511 ₅₁	2.217 ₂₅	2.217 ₂₅	0.4511 ₅₁	0.4511 ₅₁	0.4511 ₅₁	385
386	210.3 ₂₅	358.5	841.2	756.6	84.6	0.5485	0.9948	2.192 ₂₄	0.4567 ₅₁	0.4567 ₅₁	2.192 ₂₄	2.192 ₂₄	0.4567 ₅₁	0.4567 ₅₁	0.4567 ₅₁	386
387	212.8 ₂₅	359.6	840.4	755.7	84.7	0.5497	0.9928	2.168 ₂₄	0.4614 ₅₂	0.4614 ₅₂	2.168 ₂₄	2.168 ₂₄	0.4614 ₅₂	0.4614 ₅₂	0.4614 ₅₂	387
388	215.3 ₂₅	360.6	839.7	755.0	84.7	0.5509	0.9907	2.144 ₂₄	0.4666 ₅₂	0.4666 ₅₂	2.144 ₂₄	2.144 ₂₄	0.4666 ₅₂	0.4666 ₅₂	0.4666 ₅₂	388
389	217.8 ₂₆	361.7	838.9	754.2	84.7	0.5522	0.9887	2.120 ₂₃	0.4718 ₅₂	0.4718 ₅₂	2.120 ₂₃	2.120 ₂₃	0.4718 ₅₂	0.4718 ₅₂	0.4718 ₅₂	389
390	220.4 ₂₆	362.7	838.2	753.4	84.8	0.5534	0.9867	2.097 ₂₃	0.4770 ₅₃	0.4770 ₅₃	2.097 ₂₃	2.097 ₂₃	0.4770 ₅₃	0.4770 ₅₃	0.4770 ₅₃	390
391	223.0 ₂₆	363.7	837.5	752.7	84.8	0.5546	0.9847	2.074 ₂₃	0.4823 ₅₄	0.4823 ₅₄	2.074 ₂₃	2.074 ₂₃	0.4823 ₅₄	0.4823 ₅₄	0.4823 ₅₄	391

SATURATED STEAM—TABLE I.

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	Heat of the Liquid.	Heat of Vap- orization.	Heat Equiva- lent of Inter- nal Work.	Heat Equiva- lent of Ex- ternal Work.	Entropy of the Liquid.	Entropy of Vaporiza- tion.	Specific Volume.	DENSITY. Weight, in Pounds of One Cubic Foot.	Temperature, Degrees Fahr.
t	p	q	r	s	Ap	θ	r/T	s	γ	t
392	225.6 ₂₆	364.8	836.7	751.8	84.9	0.5558	0.9826	2.051 ₂₃	0.4877	392
393	228.2 ₂₆	365.8	836.0	751.1	84.9	0.5571	0.9806	2.028 ₂₂	0.4931 ₅₄	393
394	230.8 ₂₇	366.9	835.2	750.3	84.9	0.5583	0.9786	2.006 ₂₂	0.4986 ₅₅	394
									0.4986 ₅₆	
395	233.5 ₂₇	367.9	834.5	749.5	85.0	0.5595	0.9766	1.984 ₂₂	0.5040 ₅₆	395
396	236.2 ₂₇	368.9	833.8	748.8	85.0	0.5607	0.9746	1.962 ₂₁	0.5096 ₅₆	396
397	238.9 ₂₇	370.0	833.0	748.0	85.0	0.5619	0.9726	1.941 ₂₁	0.5152 ₅₇	397
									0.5152 ₅₇	
398	241.6 ₂₈	371.0	832.3	747.2	85.1	0.5632	0.9706	1.920 ₂₁	0.5209 ₅₇	398
399	244.4 ₂₈	372.0	831.6	746.5	85.1	0.5644	0.9686	1.899 ₂₁	0.5266 ₅₈	399
400	247.2 ₂₈	373.1	830.8	745.7	85.1	0.5656	0.9666	1.878 ₂₀	0.5324 ₅₈	400
									0.5324 ₅₈	
401	250.0 ₂₉	374.1	830.1	745.0	85.1	0.5668	0.9647	1.858 ₂₀	0.5382 ₅₉	401
402	252.9 ₂₉	375.2	829.4	744.2	85.2	0.5680	0.9627	1.838 ₂₀	0.5441 ₅₉	402
403	255.7 ₂₉	376.2	828.7	743.5	85.2	0.5692	0.9608	1.818 ₂₀	0.5500 ₆₀	403
									0.5500 ₆₀	
404	258.6 ₂₉	377.3	827.9	742.7	85.2	0.5704	0.9588	1.798 ₁₉	0.5560	404
405	261.5 ₃₀	378.3	827.2	741.9	85.3	0.5716	0.9569	1.779 ₁₉	0.5621 ₆₁	405
406	264.5 ₃₀	379.4	826.4	741.1	85.3	0.5728	0.9549	1.760 ₁₉	0.5682 ₆₁	406
									0.5682 ₆₁	
407	267.5 ₃₀	380.4	825.7	740.4	85.3	0.5741	0.9529	1.741 ₁₉	0.5744 ₆₂	407
408	270.5 ₃₀	381.4	825.0	739.7	85.3	0.5753	0.9509	1.722 ₁₈	0.5806 ₆₃	408
409	273.5 ₃₀	382.5	824.2	738.8	85.4	0.5765	0.9490	1.704 ₁₈	0.5869 ₆₃	409
									0.5869 ₆₃	
410	276.5 ₃₁	383.5	823.5	738.1	85.4	0.5777	0.9470	1.686 ₁₈	0.5931 ₆₄	410
411	279.6 ₃₁	384.6	822.7	737.3	85.4	0.5789	0.9451	1.668 ₁₈	0.5995 ₆₄	411
412	282.7 ₃₂	385.6	822.0	736.6	85.4	0.5801	0.9431	1.650 ₁₇	0.6059 ₆₅	412
									0.6059 ₆₅	
413	285.9 ₃₁	386.7	821.2	735.8	85.4	0.5813	0.9412	1.633 ₁₇	0.6124 ₆₅	413
414	289.0 ₃₂	387.7	820.5	735.0	85.5	0.5825	0.9393	1.616 ₁₇	0.6189 ₆₆	414
415	292.2 ₃₂	388.7	819.8	734.3	85.5	0.5837	0.9374	1.599 ₁₇	0.6255 ₆₆	415
									0.6255 ₆₆	
416	295.4 ₃₃	389.8	819.0	733.5	85.5	0.5849	0.9355	1.582 ₁₇	0.6321 ₆₇	416
417	298.7 ₃₃	390.8	818.3	732.8	85.5	0.5861	0.9336	1.565 ₁₇	0.6388 ₆₈	417
418	301.9 ₃₃	391.9	817.5	732.0	85.5	0.5873	0.9317	1.548 ₁₆	0.6450 ₆₉	418
									0.6450 ₆₉	
419	305.2 ₃₄	392.9	816.8	731.3	85.5	0.5885	0.9298	1.532 ₁₆	0.6525	419
420	308.6 ₃₄	394.0	816.0	730.5	85.5	0.5896	0.9279	1.516 ₁₆	0.6596 ₇₁	420
421	311.9 ₃₄	395.0	815.3	729.8	85.5	0.5908	0.9260	1.500 ₁₆	0.6667 ₇₁	421
									0.6667 ₇₁	
422	315.3 ₃₄	396.1	814.6	729.0	85.6	0.5920	0.9241	1.484 ₁₆	0.6739 ₇₃	422
423	318.7 ₃₅	397.1	813.9	728.3	85.6	0.5932	0.9222	1.468 ₁₆	0.6812 ₇₄	423
424	322.2 ₃₅	398.2	813.1	727.5	85.6	0.5944	0.9203	1.452 ₁₆	0.6886 ₇₅	424
									0.6886 ₇₅	
425	325.7 ₃₅	399.2	812.4	726.8	85.6	0.5955	0.9184	1.436 ₁₅	0.6961 ₇₅	425
426	329.2 ₃₅	400.3	811.6	726.0	85.6	0.5967	0.9165	1.421 ₁₅	0.7036 ₇₆	426
427	332.7 ₃₆	401.3	810.9	725.3	85.6	0.5979	0.9147	1.406 ₁₄	0.7112 ₇₆	427
									0.7112 ₇₆	
428	336.3	402.3	810.2	724.6	85.6	0.5991	0.9129	1.392	0.7188	428

TABLE II.
SATURATED STEAM.

ENGLISH UNITS.

Pressure Pounds per Square Inch.	Temperature, Degrees Fahr.	Heat of the Liquid.						Entropy of the Liquid.	Specific Volume	Weight in Pounds of One Cubic Foot.	Pressure Pounds per Square Inch.
		P	t	q	r	s	Aps				
1	102.0 ²⁴³	70.0	1043.1	981.1	62.0	0.1332	1.8574	335.3 ^{161.3}	0.00294 ²⁷⁷	1	
2	126.3 ¹⁵³	94.3	1026.2	961.9	64.3	0.1756	1.7519	174.0 ^{45.4}	0.00375 ²⁶⁸	2	
3	141.6 ¹¹⁵	109.6	1015.5	949.6	65.9	0.2012	1.6895	118.6 ^{28.0}	0.00843 ²⁶¹	3	
4	153.1 ⁹²	121.1	1007.5	940.6	66.9	0.2201	1.6447	90.60 ^{17.22}	0.01104 ²⁵⁰	4	
5	162.3 ⁷⁸	130.3	1001.2	933.4	67.8	0.2351	1.6100	73.38 ^{11.56}	0.01363 ²⁴⁵	5	
6	170.1 ⁶⁸	138.1	995.7	927.1	68.6	0.2478	1.5815	61.82 ^{8.32}	0.01618 ²⁵¹	6	
7	176.9 ⁶⁰	144.9	991.0	921.8	69.2	0.2584	1.5571	53.50 ^{6.31}	0.01860 ²⁵⁰	7	
8	182.9 ⁵⁴	151.0	986.7	916.9	69.8	0.2679	1.5350	47.19 ^{4.96}	0.02119 ²⁴⁹	8	
9	188.3 ⁴⁹	156.4	983.0	912.8	70.2	0.2763	1.5174	42.23 ^{3.98}	0.02368 ²⁴⁶	9	
10	193.2 ⁴⁶	161.4	979.5	908.8	70.7	0.2839	1.5006	38.25 ^{2.20}	0.02614 ²⁴⁶	10	
11	197.8 ⁴²	166.0	976.3	905.2	71.1	0.2929	1.4853	34.96 ^{2.75}	0.02860 ²⁴⁵	11	
12	202.0 ³⁹	170.2	973.4	901.9	71.5	0.2973	1.4714	32.21 ^{2.32}	0.03105 ²⁴³	12	
13	205.9 ³⁷	174.1	970.6	898.8	71.8	0.3032	1.4586	29.89 ^{2.03}	0.03348 ²⁴²	13	
14	209.6 ³⁴	177.8	968.0	895.9	72.1	0.3088	1.4467	27.86 ^{1.66}	0.03590 ²⁴²	14	
15	213.0 ³³	181.3	965.6	893.0	72.6	0.3141	1.4358	26.20 ^{1.55}	0.03817 ²⁴⁰	15	
16	216.3 ³¹	184.6	963.3	890.4	72.9	0.3190	1.4254	24.65 ^{1.38}	0.04057 ²⁴⁰	16	
17	219.4 ³⁰	187.8	961.1	888.0	73.1	0.3236	1.4155	23.27 ^{1.22}	0.04297 ²³⁸	17	
18	222.4 ²⁸	190.8	959.0	885.7	73.3	0.3280	1.4062	22.05 ^{1.10}	0.04535 ²³⁸	18	
19	225.2 ²⁷	193.7	957.0	883.5	73.5	0.3322	1.3975	20.95 ^{1.00}	0.04773 ²³⁸	19	
20	227.9 ²⁷	196.5	955.0	881.3	73.7	0.3362	1.3892	19.95 ^{0.90}	0.05011 ²³⁷	20	
21	230.6 ²⁵	199.1	953.2	879.3	73.9	0.3400	1.3813	19.05 ^{0.81}	0.05248 ²³⁶	21	
22	233.1 ²⁴	201.6	951.4	877.3	74.1	0.3437	1.3737	18.24 ^{0.75}	0.05484 ²³⁵	22	
23	235.5 ²³	204.1	949.6	875.3	74.3	0.3472	1.3665	17.49 ^{0.70}	0.05713 ²³⁵	23	
24	237.8 ²²	206.4	948.0	873.5	74.5	0.3506	1.3596	16.79 ^{0.63}	0.05954 ²³⁴	24	
25	240.0 ²²	208.7	946.4	871.8	74.6	0.3539	1.3529	16.16 ^{0.58}	0.06188 ²³²	25	
26	242.2 ²¹	210.9	944.9	870.1	74.8	0.3571	1.3465	15.58 ^{0.55}	0.06420 ²³²	26	
27	244.3 ²¹	213.1	943.4	868.4	75.0	0.3601	1.3405	15.03 ^{0.51}	0.06653 ²³⁴	27	
28	246.4 ¹⁹	215.1	942.0	866.9	75.1	0.3630	1.3343	14.52 ^{0.46}	0.06887 ²³⁰	28	
29	248.3 ¹⁹	217.1	940.6	865.3	75.3	0.3659	1.3286	14.06 ^{0.44}	0.07117 ²³⁰	29	
30	250.3 ¹⁹	219.1	939.2	863.8	75.4	0.3687	1.3232	13.62 ^{0.41}	0.07347 ²²⁹	30	
31	252.2 ¹⁸	221.0	937.9	862.3	75.6	0.3714	1.3179	13.21 ^{0.40}	0.07576 ²³⁰	31	
32	254.0 ¹⁸	222.8	936.6	860.9	75.7	0.3739	1.3127	12.81 ^{0.37}	0.07806 ²³¹	32	

SATURATED STEAM—TABLE II.

Pressure, Pounds per Square Inch.	Temperature, Degrees Fahr.								DENSITY. Weight, in Pounds, of One Cubic Foot.	Pressure, Pounds per Square Inch.
	p	r	q	r	s	t	u	v		
33	255.8 ₁₇	224.6	935.3	859.4	75.9	0.3764	1.3075	12.44 ₃₄	0.08037 ₂₃₁	33
34	257.5 ₁₇	226.4	934.0	858.0	76.0	0.3790	1.3026	12.09 ₃₂	0.08265 ₂₂₈	34
35	259.2 ₁₇	228.1	932.9	856.7	76.1	0.3814	1.2979	11.77 ₃₀	0.08496 ₂₂₆	35
36	260.9 ₁₆	229.8	931.7	855.4	76.3	0.3837	1.2932	11.47 ₂₉	0.08722 ₂₂₆	36
37	262.5 ₁₆	231.5	930.5	854.1	76.4	0.3859	1.2887	11.18 ₂₈	0.08948 ₂₂₆	37
38	264.1 ₁₅	233.1	929.4	852.9	76.5	0.3881	1.2844	10.90 ₂₆	0.09174 ₂₂₄	38
39	265.6 ₁₅	234.6	928.3	851.7	76.6	0.3903	1.2801	10.64 ₂₅	0.09398 ₂₃₇	39
40	267.1 ₁₅	236.2	927.2	850.5	76.8	0.3925	1.2759	10.39 ₂₄	0.09625 ₂₂₇	40
41	268.6 ₁₅	237.7	926.2	849.3	76.9	0.3946	1.2718	10.15 ₂₂	0.09852 ₂₂	41
42	270.1 ₁₄	239.2	925.1	848.1	77.0	0.3967	1.2679	9.925 ₂₁₆	0.1007 ₂₃	42
43	271.5 ₁₄	240.7	924.1	847.0	77.1	0.3987	1.2641	9.709 ₂₀₇	0.1030 ₂₂	43
44	272.9 ₁₄	242.1	923.1	845.9	77.2	0.4006	1.2604	9.502 ₁₉₈	0.1052 ₂₃	44
45	274.3 ₁₄	243.5	922.1	844.8	77.3	0.4025	1.2566	9.304 ₁₉₀	0.1075 ₂₂	45
46	275.7 ₁₃	244.9	921.1	843.7	77.4	0.4044	1.2529	9.114 ₁₈₃	0.1097 ₂₂	46
47	277.0 ₁₃	246.3	920.1	842.6	77.5	0.4062	1.2493	8.931 ₁₇₅	0.1120 ₂₂	47
48	278.3 ₁₃	247.6	919.2	841.6	77.6	0.4080	1.2458	8.756 ₁₆₈	0.1142 ₂₂	48
49	279.6 ₁₃	248.9	918.3	840.6	77.7	0.4098	1.2424	8.588 ₁₅₉	0.1164 ₂₂	49
50	280.8 ₁₂	250.2	917.4	839.6	77.8	0.4115	1.2391	8.429 ₁₅₆	0.1186 ₂₂	50
51	282.1	251.5	916.5	838.6	77.9	0.4133	1.2359	8.273 ₁₅₀	0.1209 ₂₂	51
52	283.3 ₁₂	252.7	915.7	837.7	78.0	0.4150	1.2327	8.123 ₁₄₂	0.1231 ₂₂	52
53	284.5 ₁₂	253.9	914.8	836.7	78.1	0.4167	1.2295	7.981 ₁₃₉	0.1253 ₂₂	53
54	285.7	255.2	913.9	835.7	78.2	0.4183	1.2263	7.842 ₁₃₃	0.1275 ₂₂	54
55	286.9 ₁₂	256.4	913.0	834.7	78.3	0.4199	1.2232	7.709 ₁₂₉	0.1297 ₂₂	55
56	288.1 ₁₂	257.6	912.2	833.8	78.4	0.4215	1.2201	7.580 ₁₂₆	0.1319 ₂₂	56
57	289.2	258.8	911.3	832.9	78.5	0.4231	1.2172	7.454 ₁₂₀	0.1342 ₂₂	57
58	290.3 ₁₁	259.9	910.6	832.1	78.5	0.4246	1.2144	7.334 ₁₁₅	0.1364 ₂₁	58
59	291.4 ₁₁	261.0	909.8	831.2	78.6	0.4261	1.2116	7.219 ₁₁₂	0.1385 ₂₁	59
60	292.5	262.1	909.1	830.3	78.7	0.4276	1.2088	7.107 ₁₁₀	0.1407 ₂₂	60
61	293.6 ₁₁	263.2	908.3	829.4	78.8	0.4291	1.2060	6.997 ₁₀₅	0.1429 ₂₂	61
62	294.7 ₁₁	264.3	907.5	828.6	78.9	0.4305	1.2033	6.892 ₁₀₂	0.1451 ₂₂	62
63	295.7	265.4	906.7	827.8	79.0	0.4319	1.2006	6.790 ₉₈	0.1473 ₂₂	63
64	296.7 ₁₀	266.5	905.9	827.0	79.0	0.4333	1.1980	6.690 ₉₃	0.1495 ₂₂	64
65	297.8 ₁₁	267.5	905.2	826.2	79.1	0.4347	1.1953	6.592 ₉₃	0.1517 ₂₂	65
66	298.8 ₁₀	268.6	904.4	825.3	79.2	0.4361	1.1927	6.499 ₉₀	0.1539 ₂₁	66
67	299.8 ₁₀	269.6	903.7	824.5	79.3	0.4375	1.1902	6.409 ₈₇	0.1560 ₂₁	67
68	300.8 ₉	270.6	903.0	823.7	79.3	0.4388	1.1877	6.322 ₈₆	0.1582 ₂₂	68
69	301.7	271.6	902.3	823.0	79.4	0.4401	1.1853	6.236 ₈₅	0.1604 ₂₂	69
70	302.7 ₁₀	272.6	901.7	822.3	79.5	0.4414	1.1829	6.151 ₈₁	0.1626 ₂₁	70
71	303.7 ₉	273.6	901.0	821.5	79.6	0.4427	1.1806	6.070 ₇₉	0.1647 ₂₁	71
72	304.6 ₉	274.5	900.4	820.8	79.6	0.4440	1.1783	5.991 ₇₆	0.1669 ₂₂	72
73	305.5 ₁₀	275.5	899.7	820.0	79.7	0.4452	1.1761	5.915 ₇₄	0.1691 ₂₁	73

SATURATED STEAM - TABLE II

45

Pressure Pounds per square inch.	Temperature, Degrees Fahr.	Heat of the Liquid	Heat of Vap- orization	Heat Equiva- lent of Inter- nal Work	Heat Equiva- lent of Vol- ternal Work	Entropy of the Liquid	Entropy of Vaporiza- tion	Specific Volume	Density		Pressure Pounds per square inch.
									P	γ	
74	306.5 ₉	276.5	828.9	819.1	79.8	0.4464	1.1736	5.841 ₇₂	0.1712 ₂₂	74	
75	307.4 ₉	277.4	828.3	818.6	79.8	0.4477	1.1714	5.789 ₇₂	0.1734 ₂₁	75	
76	308.3 ₉	278.3	827.7	817.9	79.9	0.4489	1.1691	5.697 ₇₀	0.1755 ₂₂	76	
77	309.2 ₉	279.2	827.0	817.0	80.0	0.4501	1.1669	5.627 ₆₇	0.1777 ₂₂	77	
78	310.1 ₈	280.1	826.4	816.4	80.0	0.4513	1.1646	5.560 ₆₆	0.1799 ₂₁	78	
79	310.9 ₉	281.0	825.8	815.7	80.1	0.4525	1.1626	5.494 ₆₃	0.1820 ₂₁	79	
80	311.8 ₉	281.9	825.1	815.0	80.2	0.4536	1.1605	5.431 ₆₃	0.1841 ₂₂	80	
81	312.7 ₈	282.8	824.5	814.3	80.2	0.4548	1.1583	5.368 ₆₁	0.1863 ₂₁	81	
82	313.5 ₉	283.7	823.9	813.6	80.3	0.4559	1.1563	5.307 ₆₁	0.1884 ₂₂	82	
83	314.4 ₈	284.6	823.2	812.9	80.4	0.4570	1.1541	5.246 ₅₈	0.1906 ₂₂	83	
84	315.3 ₈	285.4	822.7	812.3	80.4	0.4581	1.1522	5.188 ₅₇	0.1928 ₂₁	84	
85	316.0 ₈	286.2	822.1	811.6	80.5	0.4592	1.1503	5.131 ₅₆	0.1949 ₂₂	85	
86	316.8 ₈	287.1	821.5	811.0	80.5	0.4603	1.1484	5.075 ₅₅	0.1971 ₂₁	86	
87	317.6 ₈	287.9	820.9	810.3	80.6	0.4614	1.1465	5.020 ₅₃	0.1992 ₂₁	87	
88	318.4 ₈	288.8	820.3	809.7	80.6	0.4624	1.1445	4.967 ₅₂	0.2013 ₂₁	88	
89	319.2 ₈	289.5	819.8	809.0	80.7	0.4634	1.1426	4.915 ₅₁	0.2034 ₂₁	89	
90	320.0 ₈	290.3	819.3	808.4	80.8	0.4644	1.1407	4.864 ₅₀	0.2055 ₂₂	90	
91	320.8 ₈	291.1	818.7	807.8	80.8	0.4655	1.1388	4.814 ₄₈	0.2077 ₂₁	91	
92	321.6 ₈	291.9	818.1	807.2	80.9	0.4665	1.1369	4.766 ₄₈	0.2098 ₂₁	92	
93	322.4 ₇	292.7	817.6	806.6	80.9	0.4675	1.1350	4.718 ₄₇	0.2119 ₂₂	93	
94	323.1 ₈	293.5	817.0	806.0	81.0	0.4685	1.1333	4.671 ₄₆	0.2141 ₂₁	94	
95	323.9 ₇	294.3	816.4	805.4	81.0	0.4695	1.1314	4.625 ₄₅	0.2162 ₂₁	95	
96	324.6 ₈	295.1	815.9	804.8	81.1	0.4704	1.1298	4.580 ₄₄	0.2183 ₂₂	96	
97	325.4 ₇	295.9	815.3	804.2	81.1	0.4714	1.1279	4.536 ₄₄	0.2205 ₂₁	97	
98	326.1 ₈	296.6	814.8	803.6	81.2	0.4723	1.1262	4.492 ₄₂	0.2226 ₂₁	98	
99	326.9 ₇	297.3	814.3	803.0	81.2	0.4733	1.1243	4.450 ₄₁	0.2247 ₂₁	99	
100	327.6 ₇	298.1	813.8	802.4	81.3	0.4743	1.1227	4.409 ₄₁	0.2268 ₂₂	100	
101	328.3 ₇	298.8	813.3	801.9	81.3	0.4753	1.1211	4.368 ₄₀	0.2290 ₂₁	101	
102	329.0 ₇	299.6	812.7	801.3	81.4	0.4763	1.1194	4.328 ₄₀	0.2311 ₂₁	102	
103	329.7 ₇	300.3	812.2	800.8	81.4	0.4773	1.1178	4.288 ₃₈	0.2332 ₂₁	103	
104	330.4 ₇	301.1	811.6	800.2	81.5	0.4782	1.1161	4.250 ₃₈	0.2353 ₂₁	104	
105	331.1 ₇	301.8	811.1	799.6	81.5	0.4791	1.1145	4.212 ₃₇	0.2374 ₂₁	105	
106	331.8 ₇	302.5	810.6	799.1	81.6	0.4800	1.1129	4.175 ₃₇	0.2395 ₂₁	106	
107	332.5 ₇	303.2	810.2	798.6	81.6	0.4809	1.1112	4.138 ₃₆	0.2416 ₂₁	107	
108	333.2 ₇	303.9	810.7	798.0	81.7	0.4818	1.1096	4.102 ₃₅	0.2437 ₂₁	108	
109	333.9 ₇	304.6	810.2	797.5	81.7	0.4827	1.1080	4.067 ₃₅	0.2458 ₂₂	109	
110	334.6 ₆	305.3	817.7	796.9	81.8	0.4836	1.1064	4.032 ₃₄	0.2480 ₂₁	110	
111	335.2 ₇	306.0	817.2	796.4	81.8	0.4844	1.1050	3.998 ₃₃	0.2501 ₂₁	111	
112	335.9 ₇	306.7	817.7	795.9	81.8	0.4852	1.1034	3.965 ₃₃	0.2522 ₂₁	112	
113	336.6 ₆	307.4	817.2	795.3	81.9	0.4861	1.1018	3.932 ₃₂	0.2543 ₂₁	113	
114	337.2 ₇	308.1	817.6	794.8	81.9	0.4869	1.1004	3.900 ₃₂	0.2564 ₂₁	114	

SATURATED STEAM—TABLE II.

Pressure Pounds per Square Inch.	Temperature, Degrees Fahr.	DENSITY.								Pressure, Pounds per Square Inch.
		P	t	q	r	s	A _p n	e	$\frac{r}{T}$	
115	337.9 ₆	308.8	876.2	794.3	82.0	0.4878	1.0988	3.868 ₃₁	0.2585 ₂₁	115
116	338.5 ₆	309.5	875.7	793.8	82.0	0.4886	1.0974	3.837 ₃₀	0.2606 ₂₁	116
117	339.1 ₇	310.1	875.3	793.3	82.0	0.4894	1.0961	3.807 ₃₁	0.2627 ₂₂	117
118	339.8 ₆	310.8	874.8	792.8	82.1	0.4902	1.0946	3.776 ₃₀	0.2649 ₂₁	118
119	340.4 ₆	311.4	874.4	792.3	82.1	0.4911	1.0931	3.746 ₂₉	0.2670 ₂₁	119
120	341.0 ₇	312.0	874.0	791.8	82.2	0.4919	1.0918	3.717 ₂₈	0.2691 ₂₀	120
121	341.7 ₆	312.7	873.5	791.3	82.2	0.4927	1.0903	3.689 ₂₈	0.2711 ₂₁	121
122	342.3 ₆	313.3	873.0	790.7	82.3	0.4935	1.0889	3.661 ₂₈	0.2732 ₂₁	122
123	342.9 ₆	313.9	872.6	790.2	82.3	0.4943	1.0875	3.633 ₂₈	0.2753 ₂₁	123
124	343.5 ₆	314.5	872.2	789.8	82.3	0.4951	1.0861	3.605 ₂₇	0.2774 ₂₁	124
125	344.1 ₆	315.1	871.8	789.3	82.4	0.4959	1.0848	3.578 ₂₆	0.2795 ₂₀	125
126	344.7 ₆	315.8	871.3	788.8	82.4	0.4967	1.0835	3.552 ₂₆	0.2815 ₂₁	126
127	345.3 ₆	316.4	870.9	788.3	82.5	0.4975	1.0821	3.526 ₂₆	0.2836 ₂₁	127
128	345.9 ₆	317.0	870.4	787.9	82.5	0.4981	1.0808	3.500 ₂₅	0.2857 ₂₁	128
129	346.5 ₆	317.6	870.0	787.5	82.5	0.4989	1.0794	3.475 ₂₅	0.2878 ₂₁	129
130	347.1 ₆	318.3	869.5	787.0	82.6	0.4997	1.0781	3.450 ₂₅	0.2899 ₂₁	130
131	347.7 ₆	318.9	869.1	786.5	82.6	0.5004	1.0768	3.425 ₂₄	0.2920 ₂₁	131
132	348.3 ₆	319.5	868.7	786.1	82.6	0.5012	1.0754	3.401 ₂₄	0.2941 ₂₁	132
133	348.9 ₆	320.1	868.3	785.6	82.7	0.5019	1.0740	3.377 ₂₄	0.2962 ₂₀	133
134	349.5 ₅	320.7	867.8	785.1	82.7	0.5027	1.0727	3.353 ₂₄	0.2982 ₂₁	134
135	350.0 ₆	321.3	867.4	784.7	82.7	0.5034	1.0715	3.329 ₂₃	0.3003 ₂₁	135
136	350.6 ₆	321.9	867.0	784.2	82.8	0.5042	1.0702	3.306 ₂₃	0.3024 ₂₁	136
137	351.2 ₅	322.4	866.6	783.8	82.8	0.5049	1.0689	3.283 ₂₂	0.3045 ₂₁	137
138	351.7 ₆	323.0	866.2	783.4	82.8	0.5055	1.0677	3.261 ₂₁	0.3066 ₂₀	138
139	352.3 ₆	323.6	865.8	782.9	82.9	0.5062	1.0664	3.240 ₂₂	0.3086 ₂₁	139
140	352.9 ₅	324.2	865.3	782.4	82.9	0.5070	1.0651	3.218 ₂₁	0.3107 ₂₁	140
141	353.4 ₆	324.8	864.9	781.9	82.9	0.5077	1.0640	3.197 ₂₁	0.3128 ₂₁	141
142	354.0 ₅	325.4	864.5	781.5	83.0	0.5085	1.0627	3.176 ₂₁	0.3149 ₂₁	142
143	354.5 ₆	326.0	864.1	781.1	83.0	0.5092	1.0616	3.155 ₂₁	0.3170 ₂₁	143
144	355.1 ₅	326.5	863.7	780.7	83.0	0.5098	1.0603	3.134 ₂₁	0.3191 ₂₁	144
145	355.6 ₅	327.0	863.4	780.3	83.1	0.5105	1.0592	3.113 ₂₀	0.3212 ₂₁	145
146	356.1 ₆	327.6	863.0	779.9	83.1	0.5112	1.0581	3.093 ₁₉	0.3233 ₂₀	146
147	356.7 ₅	328.1	862.6	779.5	83.1	0.5119	1.0568	3.074 ₂₀	0.3253 ₂₁	147
148	357.2 ₅	328.7	862.2	779.0	83.2	0.5125	1.0557	3.054 ₁₉	0.3274 ₂₀	148
149	357.7 ₆	329.2	861.8	778.6	83.2	0.5131	1.0546	3.035 ₁₉	0.3294 ₂₁	149
150	358.3 ₅	329.8	861.4	778.2	83.2	0.5138	1.0534	3.016 ₁₉	0.3315 ₂₁	150
151	358.8 ₅	330.4	861.0	777.8	83.3	0.5145	1.0522	2.997 ₁₉	0.3336 ₂₁	151
152	359.3 ₅	330.9	860.6	777.4	83.3	0.5152	1.0511	2.978 ₁₈	0.3357 ₂₁	152
153	359.8 ₅	331.4	860.3	777.0	83.3	0.5159	1.0500	2.960 ₁₈	0.3378 ₂₁	153
154	360.3 ₆	331.9	859.9	776.6	83.4	0.5166	1.0489	2.942 ₁₈	0.3399 ₂₁	154
155	360.9 ₅	332.4	859.6	776.2	83.4	0.5172	1.0477	2.924 ₁₈	0.3420 ₂₁	155

SATURATED STEAM—TABLE II.

47

Pressure Pounds per Square Inch. <i>P</i>	Temperature, Degrees Fahr. <i>t</i>	Heat of the Liquid. <i>q</i>	Heat of Vaporiza- tion. <i>r</i>	Heat Evolu- tion of Inter- nal Work. <i>s</i>	Heat Evolu- tion of Inter- nal Work Apu	Entropy of the Liquid. <i>s</i>	Entropy of Vaporiza- tion. <i>r</i>	Specific Volume. <i>v</i>	Density Weight in Pounds of One Cubic Foot. <i>w</i>	Pressure Pounds per Square Inch. <i>P</i>
156	361.4 ₅	333.0	859.2	775.8	83.4	0.5178	1.0466	2.906 ₁₇	0.3441 ₂₀	156
157	361.5 ₅	333.5	858.8	775.3	83.4	0.5184	1.0458	2.889 ₁₇	0.3451 ₂₁	157
158	362.4 ₅	334.1	858.4	774.9	83.5	0.5191	1.0445	2.872 ₁₇	0.3462 ₂₁	158
159	362.9 ₅	334.6	858.1	774.6	83.5	0.5198	1.0434	2.855 ₁₇	0.3503 ₂₁	159
160	363.4 ₅	335.1	857.7	774.2	83.5	0.5204	1.0423	2.838 ₁₇	0.3524 ₂₁	160
161	363.9 ₅	335.6	857.4	773.9	83.5	0.5210	1.0412	2.821 ₁₇	0.3545 ₂₁	161
162	364.4 ₅	336.1	857.0	773.4	83.6	0.5216	1.0402	2.804 ₁₆	0.3566 ₂₁	162
163	364.9 ₅	336.7	856.6	773.0	83.6	0.5222	1.0391	2.788 ₁₆	0.3587 ₂₁	163
164	365.4 ₅	337.2	856.2	772.6	83.6	0.5229	1.0381	2.772 ₁₆	0.3608 ₂₁	164
165	365.9 ₅	337.7	855.9	772.2	83.7	0.5235	1.0370	2.756 ₁₅	0.3629 ₂₀	165
166	366.4 ₅	338.2	855.5	771.8	83.7	0.5241	1.0359	2.741 ₁₅	0.3649 ₂₀	166
167	366.9 ₅	338.7	855.2	771.5	83.7	0.5247	1.0348	2.726 ₁₅	0.3669 ₂₀	167
168	367.3 ₅	339.2	854.9	771.1	83.7	0.5253	1.0338	2.711 ₁₅	0.3689 ₂₀	168
169	367.8 ₅	339.7	854.5	770.7	83.8	0.5259	1.0328	2.696 ₁₅	0.3709 ₂₀	169
170	368.3 ₅	340.2	854.1	770.3	83.8	0.5265	1.0318	2.681 ₁₅	0.3730 ₂₁	170
171	368.8 ₅	340.7	853.7	770.0	83.8	0.5271	1.0308	2.666 ₁₄	0.3751 ₂₀	171
172	369.2 ₄	341.2	853.4	769.6	83.8	0.5277	1.0298	2.652 ₁₄	0.3771 ₂₀	172
173	369.7 ₅	341.6	853.1	769.2	83.9	0.5283	1.0288	2.637 ₁₅	0.3792 ₂₁	173
174	370.2 ₅	342.1	852.7	768.8	83.9	0.5289	1.0277	2.623 ₁₄	0.3813 ₂₁	174
175	370.7 ₅	342.6	852.4	768.4	83.9	0.5295	1.0266	2.608 ₁₅	0.3834 ₂₁	175
176	371.1 ₄	343.1	852.0	768.0	83.9	0.5301	1.0257	2.594 ₁₄	0.3855 ₂₁	176
177	371.6 ₅	343.6	851.7	767.7	83.9	0.5306	1.0247	2.580 ₁₄	0.3876 ₂₁	177
178	372.1 ₅	344.0	851.4	767.4	84.0	0.5312	1.0237	2.566 ₁₃	0.3897 ₂₁	178
179	372.5 ₄	344.5	851.1	767.1	84.0	0.5317	1.0227	2.553 ₁₃	0.3918 ₂₁	179
180	373.0 ₄	344.9	850.8	766.8	84.0	0.5323	1.0217	2.540 ₁₃	0.3938 ₂₀	180
181	373.4 ₄	345.4	850.5	766.4	84.0	0.5329	1.0207	2.527 ₁₄	0.3958 ₂₀	181
182	373.9 ₅	345.9	850.1	766.0	84.1	0.5335	1.0197	2.513 ₁₃	0.3979 ₂₁	182
183	374.3 ₅	346.4	849.7	765.6	84.1	0.5340	1.0188	2.500 ₁₃	0.4000 ₂₁	183
184	374.8 ₅	346.9	849.3	765.2	84.1	0.5346	1.0179	2.487 ₁₂	0.4021 ₂₀	184
185	375.2 ₅	347.4	849.0	764.9	84.1	0.5351	1.0170	2.475 ₁₂	0.4041 ₂₁	185
186	375.7 ₅	347.8	848.7	764.6	84.1	0.5357	1.0161	2.462 ₁₂	0.4062 ₂₀	186
187	376.1 ₄	348.3	848.3	764.2	84.2	0.5363	1.0152	2.450 ₁₂	0.4082 ₂₁	187
188	376.6 ₅	348.8	848.0	763.8	84.2	0.5368	1.0142	2.437 ₁₂	0.4103 ₂₁	188
189	377.0 ₅	349.2	847.7	763.5	84.2	0.5374	1.0133	2.425 ₁₂	0.4124 ₂₁	189
190	377.4 ₄	349.7	847.4	763.2	84.2	0.5379	1.0124	2.413 ₁₂	0.4145 ₂₁	190
191	377.9 ₄	350.1	847.1	762.8	84.3	0.5385	1.0115	2.401 ₁₂	0.4166 ₂₁	191
192	378.3 ₅	350.6	846.7	762.4	84.3	0.5390	1.0106	2.390 ₁₂	0.4186 ₂₀	192
193	378.8 ₅	351.0	846.4	762.1	84.3	0.5395	1.0097	2.378 ₁₂	0.4206 ₂₀	193
194	379.2 ₄	351.5	846.1	761.8	84.3	0.5400	1.0088	2.366 ₁₂	0.4227 ₂₁	194
195	379.6 ₄	351.9	845.8	761.5	84.3	0.5406	1.0080	2.355 ₁₂	0.4248 ₂₁	195
196	380.0 ₅	352.3	845.5	761.2	84.3	0.5412	1.0071	2.343 ₁₂	0.4269 ₂₀	196

SATURATED STEAM—TABLE II.

Pressure, Pounds per Square Inch.	Temperature, Degrees Fahr.	Heat of the Liquid.	Heat of Vap- oration.	Heat Equiva- lent of Inter- nal Work.	Heat Equiva- lent of Ex- ternal Work.	Entropy of the Liquid.	Entropy of Vaporiza- tion.	Specific Volume.	DENSITY.	Pressure, Pounds per Square Inch.
<i>p</i>	<i>t</i>	<i>q</i>	<i>r</i>	<i>s</i>	<i>A_p</i>	<i>θ</i>	T^{-r}	<i>s</i>	γ	<i>p</i>
197	380.5	352.8	845.2	760.8	84.4	0.5417	1.0062	2.331 ₁₂	0.4289 ₂₀	197
198	380.9	353.2	844.9	760.5	84.4	0.5422	1.0053	2.319 ₁₀	0.4309 ₂₀	198
199	381.3	353.6	844.6	760.2	84.4	0.5427	1.0044	2.309 ₁₀	0.4329 ₂₀	199
200	381.7	354.1	844.3	759.9	84.4	0.5432	1.0035	2.299 ₁₀	0.4349 ₂₀	200
201	382.2	354.5	844.0	759.5	84.5	0.5437	1.0026	2.289 ₁₀	0.4369 ₂₀	201
202	382.6	354.9	843.7	759.2	84.5	0.5443	1.0018	2.279 ₁₀	0.4389 ₂₁	202
203	383.0	355.4	843.4	758.9	84.5	0.5448	1.0010	2.268 ₁₁	0.4410 ₂₁	203
204	383.4	355.8	843.1	758.6	84.5	0.5453	1.0002	2.257 ₁₁	0.4431 ₂₀	204
205	383.8	356.3	842.7	758.2	84.5	0.5458	.9994	2.246 ₁₀	0.4451 ₂₁	205
206	384.2	356.8	842.4	757.8	84.6	0.5463	.9986	2.236 ₁₀	0.4472 ₂₁	206
207	384.6	357.2	842.1	757.5	84.6	0.5469	.9977	2.226 ₁₀	0.4493 ₂₁	207
208	385.1	357.6	841.8	757.2	84.6	0.5474	.9968	2.216 ₁₀	0.4514 ₂₀	208
209	385.5	358.0	841.5	756.9	84.6	0.5479	.9959	2.205 ₁₀	0.4534 ₂₁	209
210	385.9	358.4	841.2	756.6	84.6	0.5484	.9950	2.195 ₁₀	0.4555 ₂₁	210
211	386.3	358.8	841.0	756.3	84.6	0.5489	.9942	2.185 ₉	0.4576 ₂₁	211
212	386.7	359.2	840.7	756.0	84.7	0.5493	.9934	2.176 ₉	0.4597 ₂₀	212
213	387.1	359.6	840.4	755.7	84.7	0.5497	.9926	2.167 ₉	0.4617 ₂₁	213
214	387.5	360.1	840.0	755.3	84.7	0.5502	.9918	2.157 ₁₀	0.4638 ₂₁	214
215	387.9	360.5	839.7	755.0	84.7	0.5507	.9909	2.147 ₉	0.4659 ₂₁	215
216	388.3	360.9	839.5	754.8	84.7	0.5512	.9901	2.137 ₁₀	0.4680 ₂₁	216
217	388.7	361.3	839.2	754.5	84.7	0.5518	.9893	2.128 ₉	0.4701 ₂₁	217
218	389.1	361.7	838.9	754.2	84.7	0.5523	.9885	2.119 ₉	0.4721 ₂₀	218
219	389.5	362.1	838.6	753.8	84.8	0.5528	.9878	2.110 ₉	0.4741 ₂₀	219
220	389.8	362.5	838.3	753.5	84.8	0.5532	.9871	2.101 ₉	0.4762 ₂₁	220
221	390.2	362.9	838.0	753.2	84.8	0.5536	.9863	2.092 ₉	0.4782 ₂₁	221
222	390.6	363.3	837.8	753.0	84.8	0.5541	.9855	2.083 ₉	0.4803 ₂₁	222
223	391.0	363.7	837.5	752.7	84.8	0.5546	.9847	2.074 ₉	0.4824 ₂₁	223
224	391.4	364.1	837.2	752.4	84.8	0.5551	.9839	2.065 ₉	0.4845 ₂₁	224
225	391.8	364.5	836.9	752.0	84.8	0.5556	.9830	2.056 ₉	0.4866 ₂₀	225
226	392.2	364.9	836.7	751.7	84.9	0.5560	.9822	2.047 ₉	0.4886 ₂₁	226
227	392.6	365.3	836.4	751.5	84.9	0.5565	.9814	2.038 ₈	0.4907 ₂₁	227
228	392.9	365.7	836.1	751.2	84.9	0.5570	.9807	2.030 ₈	0.4928 ₂₁	228
229	393.3	366.1	835.8	750.9	84.9	0.5574	.9800	2.021 ₈	0.4949 ₂₀	229
230	393.7	366.6	835.4	750.5	84.9	0.5579	.9792	2.013 ₈	0.4969 ₂₁	230
231	394.1	367.0	835.1	750.2	84.9	0.5584	.9784	2.005 ₈	0.4990 ₂₁	231
232	394.5	367.4	834.8	749.9	84.9	0.5588	.9776	1.996 ₈	0.5011 ₂₁	232
233	394.8	367.8	834.6	749.6	85.0	0.5593	.9769	1.988 ₈	0.5031 ₂₀	233
234	395.2	368.1	834.4	749.4	85.0	0.5597	.9762	1.980 ₈	0.5051 ₂₀	234
235	395.6	368.4	834.2	749.2	85.0	0.5602	.9755	1.972 ₈	0.5071 ₂₀	235
236	395.9	368.8	833.9	748.9	85.0	0.5606	.9748	1.964 ₈	0.5092 ₂₀	236
237	396.3	369.2	833.6	748.6	85.0	0.5611	.9740	1.956 ₈	0.5112 ₂₁	237

SATURATED STEAM—TABLE II.

49

Pressure Pounds per Square Inch.	Temperature, Degrees Fahr.	Heat Properties of Saturated Steam						Density Weight Pounds per Cubic Foot.	Pressure Pounds per Square Inch.
		<i>p</i>	<i>t</i>	<i>q</i>	<i>r</i>	<i>s</i>	<i>Aps</i>		
238	396.7	369.7	833.3	748.3	85.0	0.5615	.9732	1.948 ₅	0.5133 ₂₁
239	397.0	370.1	833.0	748.0	85.0	0.5620	.9725	1.940 ₅	0.5144 ₂₁
240	397.4	370.4	832.7	747.7	85.0	0.5624	.9718	1.932 ₇	0.5175 ₂₀
241	397.8	370.7	832.6	747.5	85.1	0.5629	.9711	1.925 ₈	0.5195 ₂₀
242	398.1	371.1	831.3	747.2	85.1	0.5633	.9694	1.917 ₇	0.5215 ₂₁
243	398.5	371.5	832.0	746.9	85.1	0.5638	.9696	1.910 ₈	0.5236 ₂₁
244	398.9	371.9	831.7	746.6	85.1	0.5642	.9688	1.902 ₇	0.5257 ₂₁
245	399.2	372.2	831.5	746.4	85.1	0.5646	.9681	1.895 ₇	0.5278 ₂₁
246	399.6	372.6	831.2	746.1	85.1	0.5651	.9674	1.887 ₈	0.5299 ₂₁
247	399.9	373.0	830.9	745.8	85.1	0.5655	.9668	1.879 ₇	0.5320 ₂₁
248	400.3	373.4	830.6	745.5	85.1	0.5659	.9661	1.872 ₇	0.5341 ₂₀
249	400.6	373.7	830.4	745.3	85.1	0.5664	.9654	1.865 ₇	0.5361 ₂₀
250	401.0	374.1	830.1	745.0	85.1	0.5668	.9647	1.858 ₇	0.5381 ₂₀
251	401.3	374.5	829.9	744.7	85.2	0.5672	.9641	1.851 ₇	0.5401 ₂₀
252	401.7	374.8	829.7	744.5	85.2	0.5676	.9634	1.844 ₇	0.5421 ₂₁
253	402.0	375.2	829.4	744.2	85.2	0.5681	.9627	1.837 ₇	0.5442 ₂₁
254	402.4	375.6	829.1	743.9	85.2	0.5685	.9620	1.830 ₇	0.5463 ₂₁
255	402.7	375.9	828.9	743.7	85.2	0.5689	.9613	1.823 ₇	0.5484 ₂₁
256	403.1	376.3	828.6	743.4	85.2	0.5693	.9606	1.816 ₇	0.5505 ₂₁
257	403.4	376.7	828.3	743.1	85.2	0.5698	.9599	1.809 ₇	0.5526 ₂₁
258	403.8	377.0	828.1	742.9	85.2	0.5702	.9592	1.802 ₆	0.5547 ₂₁
259	404.1	377.4	827.8	742.6	85.2	0.5706	.9585	1.796 ₇	0.5568 ₂₀
260	404.5	377.8	827.5	742.3	85.2	0.5710	.9578	1.789 ₆	0.5588 ₂₁
261	404.8	378.1	827.3	742.0	85.3	0.5714	.9572	1.783 ₇	0.5609 ₂₁
262	405.2	378.5	827.0	741.7	85.3	0.5718	.9565	1.777 ₇	0.5630 ₂₁
263	405.3	378.8	826.8	741.5	85.3	0.5722	.9559	1.770 ₆	0.5651 ₂₁
264	405.8	379.2	826.5	741.2	85.3	0.5726	.9552	1.763 ₆	0.5672 ₂₁
265	406.2	379.6	826.2	740.9	85.3	0.5730	.9545	1.757 ₇	0.5693 ₂₁
266	406.5	379.9	826.0	740.7	85.3	0.5734	.9539	1.750 ₆	0.5714 ₂₀
267	406.8	380.2	825.8	740.5	85.3	0.5738	.9532	1.744 ₆	0.5734 ₂₁
268	407.2	380.6	825.5	740.2	85.3	0.5742	.9525	1.738 ₆	0.5755 ₂₁
269	407.5	380.9	825.3	740.0	85.3	0.5746	.9519	1.732 ₆	0.5776 ₂₁
270	407.9	381.3	825.0	739.7	85.3	0.5750	.9512	1.726 ₆	0.5797 ₂₀
271	408.2	381.6	824.8	739.5	85.3	0.5754	.9505	1.720 ₇	0.5817 ₂₁
272	408.5	382.0	824.5	739.2	85.3	0.5759	.9499	1.713 ₆	0.5838 ₂₁
273	408.8	382.3	824.3	738.9	85.4	0.5763	.9493	1.707 ₆	0.5859 ₂₁
274	409.2	382.7	824.0	738.6	85.4	0.5767	.9486	1.701 ₆	0.5880 ₂₁
275	409.5	383.0	823.8	738.4	85.4	0.5771	.9480	1.695 ₆	0.5901 ₂₁
276	409.8	383.4	823.5	738.1	85.4	0.5775	.9474	1.689 ₆	0.5922 ₂₁
277	410.2	383.7	823.3	737.9	85.4	0.5779	.9467	1.683 ₆	0.5943 ₂₁
278	410.5	384.0	823.1	737.7	85.4	0.5782	.9460	1.677 ₅	0.5964 ₂₁

SATURATED STEAM—TABLE II.

Pressure, Pounds per Square Inch.	Temperature, Degrees Fahr.	Heat of Vaporization.						Entropy of the Liquid	Entropy of Vaporiza- tion.	DENSITY.		Pressure, Pounds per Square Inch.
		<i>p</i>	<i>t</i>	<i>a</i>	<i>r</i>	<i>p</i>	<i>A_pu</i>	<i>e</i>	$\frac{r}{T}$	<i>s</i>	γ	
279	410.8	384.4	822.8	737.4	85.4	0.5786	.9454	1.672 ₆	0.5985 ₂	0.5985 ₂	279	
280	411.1	384.7	822.6	737.2	85.4	0.5790	.9448	1.666 ₆	0.600 ₂	0.600 ₂	280	
281	411.4	385.0	822.4	737.0	85.4	0.5794	.9442	1.660 ₆	0.602 ₂	0.602 ₂	281	
282	411.8	385.4	822.1	736.7	85.4	0.5798	.9435	1.654 ₅	0.604 ₂	0.604 ₂	282	
283	412.1	385.7	821.9	736.5	85.4	0.5802	.9429	1.649 ₆	0.606 ₂	0.606 ₂	283	
284	412.4	386.0	821.7	736.3	85.4	0.5806	.9423	1.643 ₅	0.608 ₂	0.608 ₂	284	
285	412.7	386.4	821.4	776.0	85.4	0.5809	.9416	1.638 ₆	0.610 ₂	0.610 ₂	285	
286	413.0	386.7	821.2	735.8	85.4	0.5813	.9410	1.632 ₅	0.612 ₂	0.612 ₂	286	
287	413.4	387.1	820.9	735.5	85.4	0.5817	.9404	1.627 ₆	0.614 ₂	0.614 ₂	287	
288	413.7	387.4	820.7	735.2	85.5	0.5821	.9399	1.621 ₅	0.616 ₂	0.616 ₂	288	
289	414.0	387.7	820.5	735.0	85.5	0.5825	.9393	1.616 ₅	0.618 ₂	0.618 ₂	289	
290	414.3	388.0	820.3	734.8	85.5	0.5829	.9387	1.611 ₅	0.620 ₂	0.620 ₂	290	
291	414.6	388.3	820.1	734.6	85.5	0.5832	.9382	1.605 ₅	0.623 ₂	0.623 ₂	291	
292	414.9	388.6	819.9	734.4	85.5	0.5836	.9377	1.600 ₅	0.625 ₂	0.625 ₂	292	
293	415.3	388.9	819.7	734.2	85.5	0.5840	.9370	1.595 ₆	0.627 ₂	0.627 ₂	293	
294	415.6	389.3	819.4	733.9	85.5	0.5843	.9363	1.589 ₅	0.629 ₂	0.629 ₂	294	
295	415.9	389.7	819.1	733.6	85.5	0.5847	.9357	1.584 ₅	0.631 ₂	0.631 ₂	295	
296	416.2	390.0	818.9	733.4	85.5	0.5851	.9351	1.579 ₅	0.633 ₂	0.633 ₂	296	
297	416.5	390.3	818.7	733.2	85.5	0.5854	.9345	1.574 ₆	0.635 ₂	0.635 ₂	297	
298	416.8	390.6	818.5	733.0	85.5	0.5858	.9340	1.568 ₅	0.637 ₂	0.637 ₂	298	
299	417.1	390.9	818.3	732.8	85.5	0.5862	.9334	1.563 ₅	0.639 ₃	0.639 ₃	299	
300	417.4	391.3	818.0	732.5	85.5	0.5866	.9328	1.558 ₅	0.642 ₂	0.642 ₂	300	
301	417.7	391.6	817.7	732.2	85.5	0.5869	.9322	1.553 ₅	0.644 ₂	0.644 ₂	301	
302	418.0	391.9	817.5	732.0	85.5	0.5873	.9317	1.548 ₅	0.646 ₂	0.646 ₂	302	
303	418.3	392.2	817.3	731.8	85.5	0.5876	.9311	1.543 ₅	0.648 ₂	0.648 ₂	303	
304	418.6	392.5	817.1	731.6	85.5	0.5880	.9306	1.538 ₅	0.650 ₂	0.650 ₂	304	
305	418.9	392.8	816.9	731.4	85.5	0.5884	.9300	1.533 ₅	0.652 ₂	0.652 ₂	305	
306	419.2	393.1	816.7	731.2	85.5	0.5888	.9294	1.528 ₄	0.654 ₂	0.654 ₂	306	
307	419.5	393.5	816.4	730.9	85.5	0.5891	.9288	1.524 ₄	0.656 ₂	0.656 ₂	307	
308	419.8	393.8	816.2	730.7	85.5	0.5894	.9282	1.519 ₅	0.658 ₂	0.658 ₂	308	
309	420.1	394.1	816.0	730.5	85.5	0.5898	.9277	1.514 ₅	0.660 ₂	0.660 ₂	309	
310	420.4	394.4	815.8	730.3	85.5	0.5901	.9271	1.509 ₅	0.662 ₂	0.662 ₂	310	
311	420.7	394.8	815.5	730.0	85.5	0.5905	.9255	1.504 ₄	0.664 ₂	0.664 ₂	311	
312	421.0	395.1	815.3	729.8	85.5	0.5908	.9260	1.500 ₅	0.666 ₃	0.666 ₃	312	
313	421.3	395.4	815.0	729.5	85.5	0.5912	.9254	1.495 ₅	0.669 ₂	0.669 ₂	313	
314	421.6	395.7	814.8	729.2	85.5	0.5916	.9249	1.490 ₅	0.671 ₂	0.671 ₂	314	
315	421.9	396.0	814.6	729.0	85.5	0.5919	.9243	1.485 ₅	0.673 ₂	0.673 ₂	315	
316	422.2	396.3	814.4	728.8	85.5	0.5922	.9237	1.480 ₅	0.675 ₂	0.675 ₂	316	
317	422.5	396.6	814.2	728.6	85.5	0.5926	.9231	1.475 ₄	0.677 ₂	0.677 ₂	317	
318	422.8	396.9	814.0	728.4	85.5	0.5929	.9226	1.471 ₄	0.679 ₂	0.679 ₂	318	
319	423.1	397.2	813.8	728.2	85.5	0.5933	.9220	1.467 ₅	0.681 ₂	0.681 ₂	319	

SATURATED STEAM—TABLE II.

51

Pressure, Pounds per Square Inch	Temperature, Degrees Fahr.	Heat of the Liquid,	Heat of Vap- orization	Heat Enthal- py of Inter- nal Work	Heat Enthal- py of Inter- nal Work	Entropy of the Liquid	Entropy of Vaporiza- tion	Specific Volume	DENSITY.		Pressure Pounds per Square Inch
									P	q	
320	423.4	397.5	813.6	728.0	85.6	0.5936	.9214	1.462 ₅	0.683 ₃		320
321	423.7	397.8	813.4	727.8	85.6	0.5940	.9209	1.457 ₄	0.686 ₂		321
322	424.0	398.1	813.1	727.5	85.6	0.5943	.9204	1.453 ₅	0.688 ₃		322
323	424.2	398.4	812.9	727.3	85.6	0.5946	.9199	1.448 ₅	0.691 ₂		323
324	424.5	398.7	812.7	727.1	85.6	0.5949	.9193	1.443 ₄	0.693 ₂		324
325	424.8	399.0	812.5	726.9	85.6	0.5952	.9188	1.439 ₅	0.695 ₂		325
326	425.1	399.3	812.3	726.7	85.6	0.5956	.9182	1.434 ₄	0.697 ₂		326
327	425.4	399.6	812.1	726.5	85.6	0.5959	.9176	1.430 ₄	0.699 ₂		327
328	425.7	399.9	811.9	726.3	85.6	0.5963	.9171	1.426 ₄	0.701 ₂		328
329	426.0	400.2	811.7	726.1	85.6	0.5967	.9166	1.422 ₅	0.703 ₃		329
330	426.2	400.5	811.4	725.8	85.6	0.5970	.9161	1.417 ₄	0.705 ₂		330
331	426.5	400.8	811.2	725.6	85.6	0.5973	.9156	1.413 ₄	0.708 ₂		331
332	426.8	401.1	811.0	725.4	85.6	0.5977	.9151	1.409 ₄	0.710 ₂		332
333	427.1	401.4	810.8	725.2	85.6	0.5980	.9145	1.405 ₄	0.712 ₂		333
334	427.4	401.7	810.6	725.0	85.6	0.5983	.9140	1.401 ₄	0.714 ₂		334
335	427.6	402.0	810.4	724.8	85.6	0.5987	.9136	1.397 ₄	0.716 ₂		335
336	427.9	402.3	810.2	724.6	85.6	0.5990	.9131	1.393 ₄	0.718 ₂		336

TABLE III.
S A T U R A T E D S T E A M .
FRENCH AND ENGLISH CONVERSION TABLES.*

Temperature, Degrees Centi- grade.	PRESSURE.				HEAT OF THE LIQUID.		HEAT OF VAPORIZATION.		HEAT EQUIVA- LENT OF IN- TERNA L WORK.		Temperature, Degrees Fahr.		
	t	p Milli- meters of Mer- cury.	p Kilo- grams per Square Cen- ti- meter.	p Pounds per Square Inch.	q	B.T.U.	r	B.T.U.	s	B.T.U.			
0	4.602	.339	.006257	461	0.0890	65	0.00	0.0	606.5	1091.7	575.4	1035.8	32
1	4.941	.362	.006718	492	0.0955	71	1.01	1.8	605.8	1090.4	574.6	1034.4	33.8
2	5.303	.386	.007210	525	0.1026	74	2.02	3.6	605.1	1089.1	573.8	1033.0	35.6
3	5.689	.411	.007735	558	0.1100	79	3.03	5.5	604.4	1087.9	573.1	1031.5	37.4
4	6.100	.436	.008293	593	0.1179	85	4.03	7.3	603.7	1086.6	572.3	1030.1	39.2
5	6.536	.465	.008886	633	0.1264	90	5.04	9.1	603.0	1085.3	571.5	1028.7	41.0
6	7.001	.493	.009519	679	0.1354	95	6.04	10.9	602.3	1084.1	570.7	1027.3	42.8
7	7.494	.525	.010198	71	0.1449	102	7.05	12.7	601.5	1082.8	569.9	1025.9	44.6
8	8.019	.557	.01090	76	0.1551	107	8.05	14.5	600.8	1081.6	569.1	1024.5	46.4
9	8.576	.591	.01166	80	0.1658	115	9.05	16.3	600.1	1080.3	568.3	1023.1	48.2
10	9.167	.628	.01246	86	0.1773	121	10.06	18.1	599.5	1079.1	567.6	1021.7	50.0
11	9.795	.665	.01332	90	0.1894	129	11.06	19.9	598.8	1077.8	566.8	1020.3	51.8
12	10.46		.01422	95	0.2023	136	12.06	21.7	598.1	1076.6	566.0	1018.9	53.6
13	11.16	.70	.01517	102	0.2159	144	13.06	23.5	597.4	1075.3	565.2	1017.5	55.4
14	11.91	.75	.01619	108	0.2303	153	14.06	25.3	596.7	1074.1	564.4	1016.1	57.2
15	12.70	.84	.01727		0.2456		15.06	27.1	596.0	1072.8	563.7	1014.7	59.0
16	13.54	.88	.01841	114	0.2619	163	16.06	28.9	595.3	1071.6	562.9	1013.3	60.8
17	14.42	.94	.01961	120	0.2789	170	17.06	30.7	594.6	1070.3	562.1	1011.9	62.6
18	15.36	.99	.02088		0.2970		18.06	32.5	593.9	1069.1	561.3	1010.5	64.4
19	16.35	.99	.02223	135	0.3162	192	19.06	34.3	593.2	1067.8	560.5	1009.1	66.2
20	17.40	.105	.02366	143	0.3364	202	20.06	36.1	592.5	1066.6	559.7	1007.7	68.0
21	18.50	.116	.02515		0.3578		21.06	37.9	591.8	1065.3	558.9	1006.3	69.8
22	19.66	.123	.02673	158	0.3803	225	22.06	39.7	591.1	1064.1	558.1	1004.9	71.6
23	20.89	.130	.02840	167	0.4041	238	23.06	41.5	590.4	1062.8	557.4	1003.4	73.4
24	22.19	.136	.03017		0.4291		24.06	43.3	589.7	1061.6	556.6	1002.0	75.2
25	23.55	.144	.03202	185	0.4555	264	25.05	45.1	589.0	1060.3	555.8	1000.6	77.0
26	24.99	.152	.03398	196	0.4834	279	26.05	46.9	588.3	1059.1	555.0	999.2	78.8
27	26.51	.160	.03604		0.5127		27.05	48.7	587.6	1057.8	554.3	997.8	80.6
28	28.11	.168	.03822	218	0.5436	309	28.05	50.5	586.9	1056.6	553.5	996.4	82.4
29	29.79	.176	.04050		0.5761		29.04	52.3	586.3	1055.3	552.7	995.0	84.2
30	31.55	.186	.04290		0.6102		30.04	54.1	585.7	1054.1	552.0	993.6	86.0

* Note. This table gives the Metric values for one kilogram and the English values for one pound at corresponding temperatures. If refinement is desired Table I should be used.

TABLE III.
SATURATED STEAM.
FRENCH AND ENGLISH CONVERSION TABLES.*

Temperature, Degrees Centi- grade	HEAT EQUIVALENT OF EXTER- NAL WORK			Entropy of Vapourization	SPECIFIC VOLUME			DENSITY			Temperature, Degrees Fahr.
	t	A pu	B T U	Calories	Cubic Metres per Kilogram	Cubic Feet per Pound	Weight in Kilograms per Cubic Metre	Weight in Pounds per Cubic Foot	Weight in Grams per Cubic Metre	Weight in Ounces per Cubic Foot	
0	31.1	55.9	0	2.2211	212.0	3395.220	0.004717	0.0002946	328	204	32
1	31.2	56.0	0.0037	2.2105	198.2	3175.212	0.005045	0.0003150	360	225	33.8
2	31.3	56.2	0.0074	2.2000	185.0	2963.195	0.005405	0.0003375	382	238	35.6
3	31.4	56.3	0.0110	2.1890	172.8	2768.179	0.005787	0.0003613	401	249	37.4
4	31.4	56.5	0.0146	2.1789	161.6	2580.168	0.006188	0.0003862	426	269	39.2
5	31.5	56.6	0.0183	2.1684	151.2	2421.153	0.006614	0.0004131	448	278	41
6	31.6	56.8	0.0219	2.1583	141.6	2268.146	0.007062	0.0004409	485	304	42.8
7	31.7	56.9	0.0256	2.1482	132.5	2122.133	0.007547	0.0004713	505	315	44.6
8	31.7	57.1	0.0290	2.1379	124.2	1989.124	0.008052	0.0005028	539	334	46.4
9	31.8	57.2	0.0326	2.1279	116.4	1865.116	0.008591	0.0005362	558	356	48.2
10	31.9	57.4	0.0361	2.1180	109.3	1749.107	0.009149	0.0005718	587	382	50
11	32.0	57.5	0.0397	2.1081	102.5	1642.99	0.009756	0.0006090	624	391	51.8
12	32.1	57.7	0.0433	2.0983	96.3	1543.95	0.010386	0.0006481	67	425	53.6
13	32.2	57.8	0.0467	2.0885	90.42	1448.87	0.011057	0.0006906	72	442	55.4
14	32.3	58.0	0.0502	2.0786	84.95	1361.82	0.011777	0.0007348	5	471	57.2
15	32.3	58.1	0.0537	2.0691	79.87	1279.75	0.012527	0.0007819	8	487	59
16	32.4	58.3	0.0571	2.0595	75.16	1204.71	0.013308	0.0008306	3	520	60.8
17	32.5	58.4	0.0607	2.0502	70.73	1133.66	0.014138	0.0008826	8	546	62.6
18	32.6	58.6	0.0641	2.0410	66.60	1067.62	0.015019	0.0009372	3	578	64.4
19	32.7	58.7	0.0675	2.0313	62.73	1003.58	0.015943	0.0009950	7	61	66.2
20	32.8	58.9	0.0709	2.0221	59.12	946.95	0.016911	0.001036	03	64	68
21	32.9	59.1	0.0743	2.0129	55.74	892.9	0.017941	0.001120	08	67	69.8
22	33.0	59.2	0.0776	2.0035	52.58	842.2	0.019021	0.001187	13	71	71.6
23	33.0	59.4	0.0811	1.9945	49.62	794.8	0.020151	0.001258	20	75	73.4
24	33.1	59.5	0.0845	1.9854	46.84	750.3	0.02135	0.001333	416	78	75.2
25	33.2	59.7	0.0878	1.9763	44.25	708.7	0.02280	0.001411	125	78	77
26	33.3	59.9	0.0911	1.9673	41.82	669.9	0.02391	0.001493	131	82	78.8
27	33.4	60.0	0.0945	1.9584	39.54	633.4	0.02529	0.001579	145	90	80.6
28	33.5	60.2	0.0978	1.9496	37.40	599.1	0.02674	0.001669	152	95	82.4
29	33.6	60.3	0.1011	1.9409	35.39	566.9	0.02826	0.001764	159	100	84.2
30	33.7	60.5	0.1044	1.9324	33.50	536.4	0.02985	0.001864	168	104	86

* NOTE. This table gives the Metric values for one kilogram and the English values for one pound at corresponding temperatures. If refinement is desired Table I should be used.

SATURATED STEAM—TABLE III.

Temperature, Degrees Centi- grade.	PRESSURE.				HEAT OF THE LIQUID.		HEAT OF VAPORIZATION.		HEAT EQUIVA- LENT OF IN- INTERNAL WORK.		Temperature, Degrees Fahr.		
	t	p	Kilo- grams per Square Cen- ti- meter.	Pounds per Square Inch.	Calories.	r	B.T.U.	Calories.	r	B.T.U.	Calories.	B.T.U.	
31	33.41	195	0.04543	265	0.6462	377	31.04	55.9	585.0	1052.9	551.2	992.2	87.8
32	35.36	206	0.04808	279	0.6839	397	32.04	57.7	584.3	1051.6	550.4	990.7	89.6
33	37.42	215	0.05087	294	0.7236	417	33.04	59.5	583.6	1050.3	549.6	989.2	91.4
34	39.57	226	0.05381	307	0.7653	437	34.03	61.3	582.9	1049.0	548.8	987.8	93.2
35	41.83	238	0.05688	323	0.8090	460	35.03	63.1	582.2	1047.8	548.1	986.4	95.0
36	44.21	249	0.06011	339	0.8550	481	36.03	64.9	581.5	1046.6	547.3	985.0	96.8
37	46.70	261	0.06350	355	0.9031	505	37.02	66.6	580.8	1045.4	546.5	983.6	98.6
38	49.31	274	0.06705	372	0.9536	530	38.02	68.4	580.1	1044.2	545.7	982.2	100.4
39	52.05	286	0.07077	389	1.0066	553	39.02	70.2	579.4	1042.9	544.9	980.9	102.2
40	54.91	301	0.07466	410	1.0619	583	40.02	72.0	578.7	1041.7	544.1	979.5	104.0
41	57.92	314	0.07876	427	1.1202	607	41.01	73.8	578.0	1040.4	543.3	978.1	105.8
42	61.06	329	0.08303	447	1.1809	636	42.01	75.6	577.3	1039.2	542.5	976.6	107.6
43	64.35	345	0.08750	469	1.2445	668	43.01	77.4	576.6	1037.9	541.7	975.2	109.4
44	67.80	360	0.09219	488	1.3113	694	44.01	79.2	575.9	1036.7	540.9	973.7	111.2
45	71.40	376	0.09707	513	1.3807	729	45.00	81.0	575.2	1035.4	540.1	972.3	113.0
46	75.16	394	0.10220	536	1.4536	762	46.00	82.8	574.5	1034.1	539.3	970.9	114.8
47	79.10	411	0.10756	558	1.5298	795	47.00	84.6	573.8	1032.9	538.5	969.5	116.6
48	83.21	430	0.11314	585	1.6093	831	48.00	86.4	573.1	1031.6	537.7	968.0	118.4
49	87.51	447	0.11899	608	1.6924	865	48.99	88.2	572.4	1030.5	537.0	966.7	120.2
50	91.98	467	0.12507	634	1.7789	901	49.99	90.0	571.8	1029.2	536.3	965.3	122.0
51	96.65	489	0.13141	663	1.8690	944	50.99	91.8	571.1	1027.9	535.5	963.9	123.8
52	101.54	510	0.13804	693	1.9634	986	51.99	93.6	570.4	1026.7	534.6	962.4	125.6
53	106.64	531	0.14497	723	2.0620	1027	52.99	95.4	569.7	1025.4	533.8	961.0	127.4
54	111.95	554	0.15220	754	2.1647	1072	53.98	97.2	569.0	1024.2	533.0	959.5	129.2
55	117.49	576	0.15974	783	2.2719	1114	54.98	99.0	568.3	1022.9	532.2	958.1	131.0
56	123.25	601	0.16757	817	2.3833	1162	55.98	100.8	567.6	1021.7	531.5	956.7	132.8
57	129.26	625	0.17574	850	2.4995	1209	56.98	102.6	566.9	1020.4	530.8	955.3	134.6
58	135.51	651	0.18424	884	2.6204	1259	57.98	104.4	566.2	1019.2	530.0	953.8	136.4
59	142.02	678	0.19308	922	2.7463	1311	58.97	106.2	565.5	1017.9	529.2	952.4	138.2
60	148.80	705	0.20230	959	2.8774	1363	59.97	108.0	564.8	1016.6	528.4	950.9	140.0
61	155.85	733	0.21189	996	3.0137	1418	60.97	109.8	564.1	1015.3	527.6	949.5	141.8
62	163.18	762	0.22185	1037	3.1555	1474	61.97	111.6	563.4	1014.1	526.8	948.0	143.6
63	170.80	792	0.23222	1075	3.3029	1531	62.97	113.4	562.7	1012.9	526.0	946.7	145.4
64	178.72	823	0.24297	1120	3.4560	1592	63.98	115.2	562.0	1011.7	525.1	945.2	147.2
65	186.95	855	0.25417	1163	3.6152	1654	64.98	117.0	561.3	1010.4	524.3	943.8	149.0
66	195.50	888	0.26580	1207	3.7806	1717	65.98	118.8	560.6	1009.2	523.5	942.4	150.8
67	204.38	922	0.27787	1254	3.9523	1783	66.98	120.6	559.9	1007.8	522.7	940.9	152.6
68	213.60	957	0.29041	1301	4.1306	1851	67.98	122.4	559.2	1006.6	521.9	939.5	154.4
69	223.17	992	0.30342	1348	4.3157	1918	68.98	124.2	558.5	1005.3	521.1	938.0	156.2
70	233.09	1030	0.31690	1401	4.5075	1992	69.98	126.0	557.9	1004.1	520.5	936.7	158.0

SATURATED STEAM—TABLE III.

55

Temperature, Degrees Centi- grade	Heat EQUIVALENT OF EXTER- NAL WORK.			Entropy of the Liquid	Entropy of Evaporation	SPECIFIC VOLUME.			DENSITY.			Temperature, Degrees Fahr.
	Calories	B.T.U.	Apsu						Weight in Kilograms per Cubic Meter	Weight in Pounds per Cubic Foot		
t	Apsu	Apsu	a	T	T	x	x	y	y	y		
31	33.8	60.7	0.1077	1.9238	31.72 ₁₆₇	508.1 ₂₆₇	0.03153	0.0019658	87.8			
32	33.9	60.9	0.1110	1.9152	30.05 ₁₅₇	481.4 ₂₅₂	0.03128	0.0019771	89.6			
33	34.0	61.0	0.1142	1.9066	28.48 ₁₄₈	456.2 ₂₃₇	0.03111	0.0020192	91.4			
34	34.1	61.2	0.1175	1.8981	27.00 ₁₃₈	432.5 ₂₂₃	0.03074	0.00212	93.2			
35	34.1	61.4	0.1207	1.8896	25.62 ₁₃₁	410.2 ₂₀₈	0.03033	0.002438	95.0			
36	34.2	61.6	0.1239	1.8814	24.31 ₁₂₄	389.4 ₁₉₉	0.03114	0.002568	96.8			
37	34.3	61.7	0.1272	1.8732	23.07 ₁₁₆	369.5 ₁₈₅	0.03335	0.002706	98.6			
38	34.4	61.9	0.1304	1.8649	21.91 ₁₁₀	351.0 ₁₇₇	0.03564	0.002849	100.4			
39	34.5	62.0	0.1336	1.8566	20.81 ₁₀₃	333.3 ₁₆₅	0.03805	0.003000	102.2			
40	34.6	62.2	0.1368	1.8485	19.78 ₈₂	316.8 ₁₅₇	0.05056	0.003157	104.0			
41	34.7	62.4	0.1399	1.8405	18.80 ₉₂	301.1 ₁₄₇	0.05119	0.003321	105.8			
42	34.8	62.6	0.1431	1.8324	17.88 ₈₆	286.4 ₁₃₈	0.05591	0.003492	107.6			
43	34.9	62.7	0.1463	1.8243	17.02 ₈₂	272.6 ₁₃₁	0.05875	0.003668	109.4			
44	35.0	62.9	0.1494	1.8164	16.20 ₇₈	259.5 ₁₂₅	0.06173	0.003854	111.2			
45	35.1	63.1	0.1526	1.8085	15.42 ₇₃	247.0 ₁₁₇	0.06485	0.004049	113.0			
46	35.2	63.3	0.1557	1.8007	14.69 ₆₉	235.3 ₁₁₀	0.06807	0.004250	114.8			
47	35.3	63.4	0.1588	1.7929	14.00 ₆₆	224.3 ₁₀₆	0.07142	0.004458	116.6			
48	35.4	63.6	0.1619	1.7851	13.34 ₆₃	213.7 ₁₀₁	0.07496	0.004679	118.4			
49	35.5	63.7	0.1650	1.7774	12.71 ₅₈	203.6 ₉₃	0.07868	0.004912	120.2			
50	35.6	63.9	0.1682	1.7699	12.13 ₅₅	194.3 ₈₈	0.08244	0.005147	122.0			
51	35.7	64.1	0.1713	1.7623	11.58 ₅₃	185.5 ₈₅	0.08636	0.005391	123.8			
52	35.8	64.3	0.1743	1.7548	11.05 ₅₀	177.0 ₈₀	0.09050	0.005650	125.6			
53	35.9	64.4	0.1774	1.7472	10.55 ₄₇	169.0 ₇₅	0.09479	0.005917	127.4			
54	36.0	64.6	0.1804	1.7397	10.08 ₄₅	161.5 ₇₃	0.09921	0.006192	129.2			
55	36.1	64.8	0.1835	1.7323	9.62 ₄₂₅	154.2 ₆₈	0.1039	0.006485	131.0			
56	36.2	65.0	0.1865	1.7249	9.20 ₃₉₃	147.4 ₆₄	0.108748	0.006784	132.8			
57	36.2	65.2	0.1895	1.7175	8.80 ₃₆₃	141.0 ₆₂	0.113649	0.007092	134.6			
58	36.3	65.3	0.1925	1.7102	8.41 ₃₃₃	134.8 ₅₈	0.1188	0.007418	136.4			
59	36.4	65.5	0.1955	1.7029	8.05 ₃₁₁	129.0 ₅₆	0.124254	0.007752	138.2			
60	36.5	65.7	0.1986	1.6957	7.70 ₂₉₃	123.4 ₅₂	0.129858	0.008100	140.0			
61	36.6	65.9	0.2016	1.6886	7.377 ₃₁₂	118.2 ₅₀	0.1356	0.008460	141.8			
62	36.7	66.1	0.2046	1.6815	7.065 ₂₉₇	113.2 ₄₈	0.141559	0.008834	143.6			
63	36.8	66.2	0.2075	1.6745	6.768 ₂₈₅	108.4 ₄₆	0.147565	0.009225	145.4			
64	36.9	66.4	0.2105	1.6675	6.483 ₂₇₀	103.8 ₄₂₅	0.154367	0.009634	147.2			
65	37.0	66.6	0.2135	1.6605	6.213 ₂₅₄	99.5 ₄₀₉	0.161068	0.01005	149.0			
66	37.1	66.8	0.2164	1.6536	5.959 ₂₄₂	95.4 ₃₈₇	0.167871	0.010484	150.8			
67	37.2	66.9	0.2194	1.6467	5.717 ₂₃₃	91.5 ₃₇₄	0.174974	0.0109246	152.6			
68	37.3	67.1	0.2223	1.6398	5.484 ₂₂₂	87.8 ₃₅₅	0.182374	0.0113846	154.4			
69	37.4	67.2	0.2253	1.6329	5.262 ₂₁₁	84.2 ₃₄₁	0.190080	0.0118650	156.2			
70	37.5	67.4	0.2282	1.6261	5.051 ₂₀₁	80.8 ₃₁₉	0.198082	0.0123651	158.0			

SATURATED STEAM—TABLE III.

Temperature, Degrees Centi- grade.	PRESSURE.				HEAT OF THE LIQUID.		HEAT OF VAPORIZATION.		HEAT EQUIVA- LENT OF IN- INTERNAL WORK.		Temperature, Degrees Fahr. t
	t	Milli- meters of Mer- cury.	Kilo- grams per Square Centi- meter.	Pounds per Square Inch.	p	q	B.T.U.	r	s	B.T.U.	p
71	243.39	1068	0.33091	4.7067	70.98	127.8	557.2	1002.9	519.7	935.3	159.8
72	254.07	1107	0.34544	4.9132	71.99	129.6	556.5	1001.6	518.9	933.9	161.6
73	265.14	1148	0.36050	5.1273	72.99	131.4	555.8	1000.4	518.1	932.4	163.4
74	276.62	1189	0.37600	5.3493	73.99	133.2	555.1	999.1	517.3	931.0	165.2
75	288.51	1232	0.39226	5.5792	74.90	135.0	554.4	997.9	516.5	929.6	167.0
76	300.83	1276	0.40900	5.8175	76.00	136.8	553.7	996.6	515.7	928.2	168.8
77	313.59	1321	0.42636	6.0642	77.00	138.6	553.0	995.4	514.8	926.8	170.6
78	326.80	1368	0.44433	6.3197	78.00	140.4	552.3	994.2	514.0	925.4	172.4
79	340.48	1415	0.46293	6.5842	79.01	142.2	551.6	992.9	513.2	923.9	174.2
80	354.63	1464	0.48217	6.8578	80.01	144.0	550.9	991.6	512.5	922.5	176.0
81	369.27	1514	0.50205	7.1400	81.02	145.8	550.2	990.3	511.7	921.1	177.8
82	384.41	1567	0.52264	7.4337	82.02	147.6	549.5	989.1	510.9	919.6	179.6
83	400.08	1619	0.54395	7.7367	83.03	149.4	548.8	987.8	510.1	918.2	181.4
84	416.27	1674	0.56509	8.0499	84.03	151.2	548.1	986.6	509.3	916.7	183.2
85	433.01	1730	0.58870	8.3730	85.04	153.1	547.4	985.3	508.5	915.3	185.0
86	450.31	1787	0.61238	8.7081	86.04	154.9	546.7	984.0	507.7	913.9	186.8
87	468.18	1846	0.63656	9.0537	87.05	156.7	545.9	982.8	506.9	912.5	188.6
88	486.64	1907	0.66162	9.4106	88.06	158.5	545.2	981.5	506.1	911.0	190.4
89	505.71	1969	0.68755	9.7770	89.06	160.3	544.5	980.3	505.2	909.6	192.2
90	525.40	2032	0.71435	10.160	90.07	162.1	543.9	979.0	504.5	908.2	194.0
91	545.72	2098	0.74195	10.553	91.08	163.9	543.2	977.8	503.9	906.9	195.8
92	566.70	2164	0.77050	10.959	92.08	165.7	542.5	976.6	503.1	905.5	197.6
93	588.34	2233	0.79988	11.377	93.09	167.5	541.8	975.2	502.2	904.0	199.4
94	610.67	2303	0.83025	11.809	94.10	169.3	541.1	974.0	501.4	902.6	201.2
95	633.70	2375	0.86155	12.254	95.11	171.2	540.4	972.7	500.6	901.2	203.0
96	657.45	2448	0.89358	12.714	96.12	173.0	539.7	971.4	499.8	899.7	204.8
97	681.93	2524	0.92715	13.187	97.12	174.8	539.0	970.1	499.0	898.3	206.6
98	707.17	2602	0.96145	13.675	98.13	176.6	538.3	969.0	498.4	896.9	208.4
99	733.19	2681	0.99680	14.178	99.14	178.5	537.6	967.6	497.5	895.4	210.2
100	760.00	275	1.0333	14.697	100.2	180.3	536.8	966.3	496.6	893.9	212.0
101	787.5	283	1.0707	15.220	101.2	182.1	536.1	965.0	495.8	892.5	213.8
102	815.8	292	1.1093	15.776	102.2	183.9	535.4	963.7	494.9	891.0	215.6
103	845.0	301	1.1490	16.341	103.2	185.7	534.7	962.5	494.1	889.6	217.4
104	875.1	309	1.1898	16.923	104.2	187.6	534.0	961.1	493.4	888.0	219.2
105	906.0	319	1.2319	17.521	105.2	189.4	533.3	959.9	492.6	886.7	221.0
106	937.9	328	1.2752	18.137	106.2	191.2	532.6	958.7	491.8	885.3	222.8
107	970.7	337	1.3198	18.771	107.2	193.0	531.9	957.4	491.0	883.9	224.6
108	1004.4	347	1.3656	19.423	108.2	194.8	531.2	956.2	490.3	882.6	226.4
109	1039.1	356	1.4129	20.094	109.3	196.7	530.4	954.8	489.5	881.1	228.2
110	1074.7	367	1.4612	20.783	110.3	198.5	529.8	953.6	488.8	879.7	230.0

SATURATED STEAM—TABLE III.

57

Temperature, Degrees Centi- grade.	Heat EQUIVALENT OF EXTER- NAL WORK.			Entropy of the Liquid.	Entropy of Vaporization	SPECIFIC VOLUME.			DENSITY.			Temperature, Degrees Fahr.
	Cel.	Fahr.	B.T.U.			Cel.	Meters per Kil.	Cel.	Foot per Pound	Weight in Kilograms of One Cubic Meter	Weight in Pounds of One Cubic Foot	
t	Aps	Aps	T	s	T	s	s	s	s	s	s	s
71	37.6	67.8	0.2311	1.6194	4.850	77.60	306	0.2062	.84	0.01287	.53	159.8
72	37.7	67.8	0.2340	1.6126	4.659	74.63	295	0.2146	.79	0.01340	.55	161.6
73	37.8	67.9	0.2369	1.6060	4.475	71.68	281	0.2237	.71	0.01395	.57	163.4
74	37.9	68.1	0.2398	1.5994	4.300	68.87	266	0.2326	.63	0.01452	.58	165.2
75	38.0	68.3	0.2427	1.5928	4.134	66.21	255	0.2419	.57	0.01510	.61	167.0
76	38.1	68.5	0.2456	1.5862	3.974	63.66	244	0.2516	.50	0.01571	.62	168.8
77	38.2	68.6	0.2484	1.5797	3.822	61.22	232	0.2616	.44	0.01633	.65	170.6
78	38.3	68.8	0.2513	1.5733	3.677	58.90	210	0.2720	.34	0.01698	.68	172.4
79	38.4	68.9	0.2541	1.5668	3.538	56.67	193	0.2826	.26	0.01765	.67	174.2
80	38.4	69.1	0.2570	1.5604	3.406	54.54	183	0.2936	.18	0.01834	.73	176.0
81	38.5	69.3	0.2598	1.5540	3.278	52.51	173	0.3051	.11	0.01904	.70	177.8
82	38.6	69.5	0.2626	1.5477	3.157	50.57	164	0.3168	.07	0.01977	.73	179.6
83	38.7	69.6	0.2654	1.5414	3.040	48.70	158	0.3289	.03	0.02053	.78	181.4
84	38.8	69.8	0.2682	1.5351	2.929	46.92	145	0.3414	.00	0.02181	.81	183.2
85	38.9	70.0	0.2711	1.5288	2.822	45.20	134	0.3544	.00	0.02212	.84	185.0
86	39.0	70.2	0.2739	1.5226	2.720	43.56	126	0.3676	.00	0.02296	.86	186.8
87	39.1	70.3	0.2767	1.5164	2.622	42.00	116	0.3814	.03	0.02381	.88	188.6
88	39.2	70.5	0.2795	1.5103	2.529	40.51	109	0.3954	.00	0.02469	.91	190.4
89	39.3	70.6	0.2823	1.5042	2.439	39.07	139	0.4100	.00	0.02560	.94	192.2
90	39.4	70.8	0.2851	1.4981	2.352	37.68	130	0.4250	.00	0.02654	.95	194.0
91	39.4	70.9	0.2879	1.4921	2.271	36.38	120	0.4403	.00	0.02749	.95	195.8
92	39.5	71.1	0.2906	1.4861	2.191	35.10	112	0.4564	.00	0.02849	.99	197.6
93	39.6	71.2	0.2934	1.4801	2.115	33.88	102	0.4728	.00	0.02952	.103	199.4
94	39.7	71.4	0.2961	1.4741	2.043	32.71	97	0.4895	.00	0.03057	.105	201.2
95	39.8	71.5	0.2989	1.4682	1.972	31.59	87	0.5071	.00	0.03166	.112	203.0
96	39.9	71.7	0.3016	1.4623	1.905	30.51	80	0.5249	.00	0.03278	.112	204.8
97	40.0	71.9	0.3043	1.4564	1.840	29.47	72	0.5435	.00	0.03393	.115	206.6
98	40.0	72.0	0.3070	1.4506	1.778	28.48	64	0.5624	.00	0.03511	.120	208.4
99	40.1	72.2	0.3097	1.4448	1.719	27.54	54	0.5817	.00	0.03631	.120	210.2
100	40.3	72.4	0.3125	1.4390	1.665	26.66	52	0.6008	.00	0.03751	.119	212.0
101	40.4	72.6	0.3152	1.4333	1.613	25.84	45	0.6200	.00	0.03870	.132	213.8
102	40.5	72.8	0.3179	1.4276	1.560	24.99	32	0.6410	.00	0.04002	.133	215.6
103	40.6	72.9	0.3205	1.4219	1.509	24.17	20	0.6627	.00	0.04137	.142	217.4
104	40.6	73.0	0.3232	1.4162	1.459	23.37	16	0.6854	.00	0.04279	.144	219.2
105	40.7	73.2	0.3259	1.4106	1.412	22.61	76	0.7082	.00	0.04423	.145	221.0
106	40.8	73.3	0.3286	1.4051	1.367	21.89	72	0.7315	.00	0.04568	.151	222.8
107	40.9	73.5	0.3312	1.3996	1.323	21.19	67	0.7550	.00	0.04719	.154	224.6
108	40.9	73.6	0.3339	1.3941	1.281	20.52	67	0.7806	.00	0.04873	.154	226.4
109	41.0	73.8	0.3365	1.3886	1.240	19.86	66	0.8063	.00	0.05035	.162	228.2
110	41.1	73.9	0.3392	1.3831	1.201	19.24	59	0.8326	.00	0.05197	.165	230.0

SATURATED STEAM—TABLE III.

Temperature, Degrees Centi- grade. <i>t</i>	PRESSURE.			HEAT OF THE LIQUID.		HEAT OF VAPORIZATION		EQUIVA- LENT OF IN- INTERNAL WORK.		Temperature, Degrees Fahr. <i>t</i>
	Milli- meters of Mer- cury.	Kilo- grams per Square Cen- timeter.	Pounds per Square Inch.	Calories. <i>p</i>	B.T.U. <i>q</i>	Calories. <i>p</i>	B.T.U. <i>q</i>	Calories. <i>p</i>	B.T.U. <i>q</i>	
111 1111.4 377	1.5110	21.492	111.3	200.3	529.1	952.3	488.0	878.3	231.8	
112 1149.1 388	1.5623	22.221	112.3	202.1	528.4	951.1	487.2	877.0	233.6	
113 1187.9 398	1.6151	22.972	113.3	203.9	527.7	949.8	486.5	875.4	235.4	
114 1227.7 410	1.6692	23.741	114.3	205.8	527.0	948.5	485.6	874.0	237.2	
115 1268.7 420	1.7248	24.533	115.3	207.6	526.3	947.2	484.8	872.6	239.0	
116 1310.7 432	1.7820	25.346	116.4	209.4	525.5	945.9	484.0	871.2	240.8	
117 1353.9 444	1.8408	26.182	117.4	211.2	524.8	944.5	483.2	869.7	242.6	
118 1398.3 455	1.9011	27.040	118.4	213.0	524.1	943.3	482.4	868.3	244.4	
119 1443.8 467	1.9630	27.920	119.4	214.9	523.4	942.2	481.7	867.0	246.2	
120 1490.5 480	2.0265	28.824	120.4	216.7	522.7	940.9	480.9	865.6	248.0	
121 1538.5 492	2.0918	29.752	121.4	218.5	522.0	939.6	480.2	864.2	249.8	
122 1587.5 506	2.1586	30.703	122.5	220.4	521.2	938.2	479.3	862.7	251.6	
123 1638.3 518	2.2274	31.681	123.5	222.2	520.5	937.0	478.5	861.2	253.4	
124 1690.1 532	2.2978	32.683	124.5	224.1	519.8	935.7	477.7	859.8	255.2	
125 1743.3 545	2.3701	33.711	125.5	225.9	519.1	934.4	476.9	858.4	257.0	
126 1797.8 559	2.4443	34.766	126.5	227.7	518.4	933.2	476.2	857.0	258.8	
127 1853.7 573	2.5203	35.847	127.5	229.5	517.6	931.8	475.3	855.5	260.6	
128 1911.0 587	2.5982	36.955	128.6	231.4	516.9	930.6	474.5	854.2	262.4	
129 1969.7 601	2.6780	38.090	129.6	233.3	516.2	929.3	473.7	852.8	264.2	
130 2029.8 617	2.7599	39.255	130.6	235.1	515.6	928.1	473.0	851.4	266.0	
131 2091.5 633	2.8436	40.445	131.6	236.9	514.9	926.8	472.3	850.0	267.8	
132 2154.8 647	2.9297	41.670	132.6	238.7	514.2	925.5	471.5	848.6	269.6	
133 2219.5 663	3.0176	42.921	133.7	240.6	513.5	924.2	470.6	847.0	271.4	
134 2285.8 679	3.1078	44.203	134.7	242.4	512.8	922.9	469.8	845.6	273.2	
135 2353.7 695	3.2000	45.515	135.7	244.2	512.1	921.6	469.1	844.2	275.0	
136 2423.2 712	3.2946	46.860	136.7	246.0	511.4	920.2	468.2	842.7	276.8	
137 2494.4 728	3.3914	48.237	137.7	247.9	510.7	919.0	467.4	841.3	278.6	
138 2567.2 745	3.4904	49.645	138.8	249.7	510.0	917.6	466.6	839.8	280.4	
139 2641.7 762	3.5916	51.085	140.1	251.6	509.2	916.5	465.8	838.5	282.2	
140 2717.9 780	3.6953	52.56	1.475	253.4	508.6	915.2	465.0	837.1	284.0	
141 2795.9 798	3.8015	54.07	141.8	255.3	507.9	913.8	464.2	835.6	285.8	
142 2875.7 816	3.9095	55.61	1.54	257.1	507.0	912.6	463.4	834.2	287.6	
143 2957.3 835	4.0208	57.19	1.58	259.0	506.2	911.2	462.6	832.8	289.4	
144 3040.8 853	4.1340	58.80	144.9	260.8	505.5	910.0	461.8	831.4	291.2	
145 3126.1 872	4.2500	60.45	1.65	262.7	504.8	908.6	461.0	829.9	293.0	
146 3213.3 892	4.3689	62.14	1.69	264.5	504.1	907.3	460.2	828.5	294.8	
147 3302.5 911	4.4898	63.86	1.77	266.4	503.3	906.2	459.4	827.2	296.6	
148 3393.6 931	4.6142	65.63	1.80	268.2	502.6	904.8	458.7	825.7	298.4	
149 3486.7 952	4.7408	67.43	1.84	270.1	501.9	903.6	457.9	824.3	300.2	
150 3581.9 972	4.8701	69.27	1.88	271.9	501.3	902.2	457.1	822.8	302.0	

SATURATED STEAM—TABLE III.

59

Temperature, Degrees Centi- grade.	HEAT EQUIVALENT OF EXTER- NAL WORK.			Entropy of the Liquid.	Entropy of Vaporization	SPECIFIC VOLUME.			DENSITY.			Temperature, Degrees Fahr.
	Calories	B.T.U.				Cubic Metres per kilo	Cubic Feet per Pound	Weight, in Grams of One Cubic Meter	Weight, in Pounds of One Cubic Foot			
t	Apu	Apu		s	T	s	s	s	s	s	s	s
111	41.2	74.0	0.3418	1.3776	1.164	18.65 ⁵⁸	0.8591 ²⁷⁴	0.05362 ¹⁷²	0.05362 ¹⁷²	231.8		
112	41.3	74.2	0.3445	1.3722	1.128	18.07 ⁵⁸	0.8865 ²⁸⁴	0.05334 ¹⁷⁷	0.05334 ¹⁷⁷	233.6		
113	41.3	74.3	0.3471	1.3668	1.093	17.51 ⁵⁸	0.9149 ²⁹⁴	0.05711 ¹⁸⁵	0.05711 ¹⁸⁵	235.4		
114	41.4	74.5	0.3498	1.3614	1.059	16.96 ⁵¹	0.9443 ²⁹⁴	0.05896 ¹⁸³	0.05896 ¹⁸³	237.2		
115	41.5	74.6	0.3524	1.3560	1.027	16.45 ⁴⁹	0.9737 ³⁰³	0.06079 ¹⁸⁷	0.06079 ¹⁸⁷	239.0		
116	41.6	74.7	0.3550	1.3507	0.9961	15.96 ⁴⁹	1.004 ³¹	0.06266 ¹⁹⁴	0.06266 ¹⁹⁴	240.8		
117	41.6	74.9	0.3576	1.3455	0.9661	15.48 ⁴⁷	1.035 ³²	0.06460 ²⁰²	0.06460 ²⁰²	242.6		
118	41.7	75.0	0.3602	1.3403	0.9371	15.01 ⁴⁷	1.067 ³³	0.06662 ²⁰¹	0.06662 ²⁰¹	244.4		
119	41.8	75.2	0.3628	1.3351	0.9094	14.57 ⁴³	1.100 ³⁴	0.06863 ²¹¹	0.06863 ²¹¹	246.2		
120	41.9	75.3	0.3654	1.3299	0.8822	14.14 ⁴²	1.134 ³³	0.07074 ²¹⁵	0.07074 ²¹⁵	248.0		
121	41.9	75.4	0.3680	1.3247	0.8566	13.72 ⁴⁰	1.157 ³⁶	0.07289 ²¹⁹	0.07289 ²¹⁹	249.8		
122	42.0	75.6	0.3705	1.3195	0.8315	13.32 ³⁹	1.203 ³⁶	0.07508 ²²⁶	0.07508 ²²⁶	251.6		
123	42.1	75.7	0.3731	1.3144	0.8073	12.93 ³⁷	1.239 ³⁷	0.07734 ²²⁸	0.07734 ²²⁸	253.4		
124	42.2	75.9	0.3756	1.3093	0.7840	12.56 ³⁷	1.276 ³⁷	0.07962 ²³⁴	0.07962 ²³⁴	255.2		
125	42.3	76.0	0.3782	1.3042	0.7615	12.19 ³⁴	1.313 ³⁸	0.08196 ²⁴³	0.08196 ²⁴³	257.0		
126	42.3	76.1	0.3807	1.2992	0.7399	11.85 ³⁴	1.351	0.08439 ²⁴⁹	0.08439 ²⁴⁹	258.8		
127	42.4	76.3	0.3833	1.2942	0.7188	11.51 ³⁴	1.391 ⁴⁰	0.08688 ²⁴⁹	0.08688 ²⁴⁹	260.6		
128	42.5	76.4	0.3858	1.2892	0.6986	11.19 ³²	1.431 ⁴²	0.08937 ²⁵⁴	0.08937 ²⁵⁴	262.4		
129	42.6	76.6	0.3884	1.2842	0.6791	10.88 ³¹	1.473	0.09191 ²⁷⁰	0.09191 ²⁷⁰	264.2		
130	42.6	76.7	0.3909	1.2792	0.6604	10.57 ³¹	1.514	0.09461 ²⁵⁷	0.09461 ²⁵⁷	266.0		
131	42.7	76.8	0.3934	1.2743	0.6421	10.29 ²⁸	1.557 ⁴³	0.09718 ²⁸²	0.09718 ²⁸²	267.8		
132	42.8	77.0	0.3959	1.2694	0.6244	10.00 ²⁷²	1.602 ⁴⁵	0.1000 ²⁸	0.1000 ²⁸	269.6		
133	42.9	77.1	0.3985	1.2645	0.6073	9.728 ²⁶⁶	1.647 ⁴⁶	0.1028 ²⁹	0.1028 ²⁹	271.4		
134	43.0	77.3	0.4010	1.2596	0.5907	9.462 ²⁵⁸	1.693 ⁴⁷	0.1057 ²⁹	0.1057 ²⁹	273.2		
135	43.0	77.4	0.4035	1.2547	0.5747	9.204 ²⁴⁴	1.740 ⁴⁸	0.1086 ³⁰	0.1086 ³⁰	275.0		
136	43.1	77.5	0.4060	1.2499	0.5592	8.957 ²⁴⁰	1.788 ⁵⁰	0.1116 ³¹	0.1116 ³¹	276.8		
137	43.2	77.7	0.4085	1.2451	0.5442	8.717 ²³⁰	1.835 ⁵⁰	0.1147 ³¹	0.1147 ³¹	278.6		
138	43.3	77.8	0.4110	1.2403	0.5298	8.487 ²²⁵	1.888 ⁵¹	0.1178 ³²	0.1178 ³²	280.4		
139	43.3	78.0	0.4135	1.2356	0.5158	8.262 ²¹⁹	1.939 ⁵³	0.1210 ³³	0.1210 ³³	282.2		
140	43.4	78.1	0.4160	1.2309	0.5021	8.043 ²⁰⁹	1.992 ⁵³	0.1243 ³³	0.1243 ³³	284.0		
141	43.5	78.2	0.4185	1.2262	0.4891	7.834 ¹²⁷	2.045	0.1276 ³⁴	0.1276 ³⁴	285.8		
142	43.6	78.3	0.4209	1.2215	0.4764	7.631 ²⁰³	2.089 ³⁴	0.1310 ³⁵	0.1310 ³⁵	287.6		
143	43.6	78.5	0.4234	1.2168	0.4640	7.433 ¹⁹⁸	2.155 ³⁶	0.1345 ³⁶	0.1345 ³⁶	289.4		
144	43.7	78.6	0.4259	1.2121	0.4521	7.242 ¹⁸⁶	2.212 ³⁸	0.1381 ³⁶	0.1381 ³⁶	291.2		
145	43.8	78.7	0.4283	1.2075	0.4405	7.056 ¹⁷⁹	2.270 ³⁸	0.1417 ³⁷	0.1417 ³⁷	293.0		
146	43.9	78.8	0.4307	1.2029	0.4293	6.877 ¹⁶⁸	2.329 ⁶⁰	0.1454 ³⁸	0.1454 ³⁸	294.8		
147	44.0	79.0	0.4332	1.1983	0.4155	6.704 ¹⁶⁸	2.389	0.1492 ³⁸	0.1492 ³⁸	296.6		
148	44.0	79.1	0.4356	1.1937	0.4080	6.536 ¹⁶⁴	2.431 ⁶²	0.1530 ³⁹	0.1530 ³⁹	298.4		
149	44.1	79.3	0.4380	1.1892	0.3978	6.372 ¹⁵⁹	2.514 ⁶³	0.1569 ⁴⁰	0.1569 ⁴⁰	300.2		
150	44.2	79.4	0.4405	1.1847	0.3880	6.213 ¹⁵³	2.577 ⁶⁶	0.1609 ⁴¹	0.1609 ⁴¹	302.0		

SATURATED STEAM—TABLE III.

Temperature, Degrees Centi- grade.	PRESSURE.				HEAT OF THE LIQUID.		HEAT OF VAPORIZATION.		HEAT EQUIVA- LENT OF IN- INTERNAL WORK.		Temperature, Degrees Fahr.	
	<i>t</i>	Milli- meters of Mer- cury.	Kilo- grams per Square Cen- ti- meter.	Pounds per Square Inch.	<i>a</i>	Calories.	<i>q</i>	B.T.U.	<i>r</i>	Calories.	<i>s</i>	B.T.U.
	<i>p</i>	<i>p</i>	<i>p</i>	<i>p</i>	<i>q</i>	<i>r</i>	<i>s</i>	<i>t</i>	<i>p</i>	<i>s</i>	<i>t</i>	
151	3679.1	993	5.0023	71.15	152.1	273.8	500.6	900.9	456.3	821.4	303.8	
152	3778.4	1014	5.1373	73.07	153.1	275.6	499.8	899.6	455.5	820.0	305.6	
153	3879.8	1035	5.2751	75.03	154.1	277.4	499.1	898.4	454.7	818.5	307.4	
154	3983.3	1057	5.4157	77.03	155.1	279.2	498.2	897.0	453.9	817.0	309.2	
155	4089.0	1079	5.5592	79.07	156.2	281.1	497.6	895.7	453.1	815.6	311.0	
156	4196.9	1102	5.7061	81.16	157.2	283.0	496.9	894.4	452.4	814.1	312.8	
157	4307.1	1124	5.8558	83.29	158.2	284.8	496.1	893.0	451.5	812.7	314.6	
158	4419.5	1148	6.0084	85.46	159.3	286.7	495.4	891.8	450.7	811.3	316.4	
159	4534.3	1171	6.1645	87.68	160.3	288.5	494.7	890.4	449.9	809.8	318.2	
160	4651.4	1195	6.3241	89.95	161.3	290.4	494.0	889.1	449.1	808.3	320.0	
161	4770.9	1218	6.4865	92.26	162.3	292.2	493.2	887.8	448.2	806.9	321.8	
162	4892.7	1243	6.6524	94.62	163.4	294.1	492.5	886.6	447.5	805.5	323.6	
163	5017.127		6.8212	97.02	164.4	295.9	491.8	885.2	446.8	804.1	325.4	
164	5144.129		6.9934	99.47	165.4	297.7	491.0	883.9	445.9	802.6	327.2	
165	5273.132		7.1692	101.97	166.5	299.6	490.3	882.7	445.1	801.3	329.0	
166	5405.134		7.3485	104.52	167.5	301.5	489.6	881.4	444.3	799.8	330.8	
167	5539.137		7.5306	107.11	168.5	303.3	488.9	880.1	443.6	798.5	332.6	
168	5676.140		7.7169	109.76	169.5	305.1	488.1	878.8	442.8	797.0	334.4	
169	5816.143		7.9074	112.47	170.6	307.0	487.4	877.4	442.0	795.6	336.2	
170	5959.145		8.1007	115.22	171.6	308.9	486.8	876.1	441.2	794.1	338.0	
171	6104.147		8.2990	118.04	172.6	310.7	486.1	874.9	440.4	792.8	339.8	
172	6251.151		8.4987	120.88	173.7	312.6	485.3	873.6	439.6	791.3	341.6	
173	6402.153		8.7040	123.80	174.7	314.5	484.6	872.3	438.9	790.0	343.4	
174	6555.157		8.9121	126.76	175.7	316.3	483.8	870.9	438.1	788.4	345.2	
175	6712.159		9.1251	129.79	176.8	318.2	483.1	869.6	437.2	787.0	347.0	
176	6871.162		9.3417	132.87	177.8	320.0	482.4	868.3	436.5	785.6	348.8	
177	7033.165		9.5617	136.00	178.8	321.8	481.6	867.0	435.7	784.2	350.6	
178	7198.168		9.7860	139.19	179.9	323.7	480.9	865.7	435.0	782.8	352.4	
179	7366.171		10.014	142.44	180.9	325.6	480.2	864.4	434.1	781.4	354.2	
180	7537.175		10.247	145.75	181.9	327.5	479.5	863.0	433.4	779.9	356.0	
181	7712.177		10.485	149.13	183.0	329.3	478.7	861.7	432.5	778.5	357.8	
182	7889.181		10.726	152.56	184.0	331.2	478.0	860.4	431.8	777.1	359.6	
183	8070.183		10.972	156.06	185.0	333.0	477.2	859.1	430.9	775.7	361.4	
184	8253.187		11.221	159.60	186.1	334.9	476.5	857.8	430.2	774.3	363.2	
185	8440.191		11.476	163.22	187.1	336.8	475.8	856.5	429.3	772.9	365.0	
186	8631.193		11.735	166.91	188.1	338.6	475.1	855.2	428.6	771.5	366.8	
187	8824.197		11.997	170.64	189.2	340.5	474.3	853.8	427.7	770.0	368.6	
188	9021.201		12.265	174.45	190.2	342.4	473.6	852.6	427.0	768.7	370.4	
189	9222.204		12.538	178.34	191.2	344.2	472.9	851.2	426.3	767.2	372.2	
190	9426.207		12.815	182.27	192.3	346.1	472.2	849.9	425.5	765.8	374.0	

SATURATED STEAM—TABLE III.

61

Temperature, Degrees Centi- grade	HEAT EQUIVALENT OF EXTER- NAL WORK			Entropy of the Liquid.	Entropy of Vaporization	SPECIFIC VOLUME		DENSITY			Temperature, Degrees Fahr.
	Calories	B.T.U.	°			Calor. Meters per Kil.	Calor. Foot per Pound	Weight in Kil. Grams of One Cubic Meter.	Weight in Pounds of One Cubic Foot		
t	° Aps	° Aps	θ		T	s	s	γ	γ	γ	γ
151	44.3	79.5	0.4429	1.1802	0.3783 ₉₃	6.060 ₁₄₉	2.643 ₆₇	0.1650 ₄₂	303.8		
152	44.3	79.7	0.4453	1.1757	0.3690 ₉₀	5.911 ₁₄₄	2.710 ₆₈	0.1674 ₄₂	305.6		
153	44.4	79.8	0.4477	1.1713	0.3600 ₈₈	5.767 ₁₄₁	2.778 ₆₉	0.1734 ₄₃	307.4		
154	44.5	80.0	0.4501	1.1769	0.3512 ₈₅	5.626 ₁₃₆	2.847 ₇₁	0.1777 ₄₄	309.2		
155	44.6	80.1	0.4525	1.1625	0.3427 ₈₂	5.499 ₁₃₂	2.918 ₇₂	0.1821 ₄₅	311.0		
156	44.6	80.2	0.4549	1.1681	0.3345 ₈₀	5.358 ₁₂₈	2.990 ₇₃	0.1866 ₄₆	312.8		
157	44.7	80.4	0.4573	1.1637	0.3265 ₇₈	5.230 ₁₂₅	3.063 ₇₅	0.1912 ₄₇	314.6		
158	44.8	80.5	0.4596	1.1593	0.3187 ₇₆	5.105 ₁₂₂	3.138 ₇₆	0.1959 ₄₇	316.4		
159	44.8	80.7	0.4620	1.1550	0.3111 ₇₃	4.983 ₁₁₆	3.214 ₇₈	0.2071 ₄₈	318.2		
160	44.9	80.8	0.4644	1.1407	0.3038 ₇₁	4.867 ₁₁₄	3.292 ₇₈	0.2055 ₄₉	320.0		
161	45.0	80.9	0.4668	1.1364	0.2967 ₆₉	4.753 ₁₁₁	3.370 ₈₅	0.2104 ₅₀	321.8		
162	45.1	81.0	0.4692	1.1321	0.2898 ₆₇	4.642 ₁₀₇	3.451 ₈₁	0.2154 ₅₁	323.6		
163	45.1	81.2	0.4715	1.1278	0.2831 ₆₆	4.535 ₁₀₆	3.532 ₈₅	0.2205 ₅₃	325.4		
164	45.2	81.3	0.4739	1.1236	0.2765 ₆₃	4.429 ₁₀₀	3.617 ₈₄	0.2255 ₅₂	327.2		
165	45.3	81.4	0.4763	1.1194	0.2702 ₆₂	4.329 ₉₉	3.701 ₈₇	0.2310 ₅₅	329.0		
166	45.3	81.5	0.4786	1.1152	0.2640 ₆₀	4.229 ₉₆	3.788 ₈₈	0.2365 ₅₅	330.8		
167	45.4	81.6	0.4810	1.1110	0.2580 ₅₈	4.133 ₉₃	3.876 ₈₉	0.2420 ₅₅	332.6		
168	45.4	81.8	0.4833	1.1068	0.2522 ₅₇	4.040 ₉₁	3.965 ₉₂	0.2473 ₅₇	334.4		
169	45.5	81.9	0.4857	1.1027	0.2465 ₅₅	3.949 ₈₈	4.057 ₉₂	0.2532 ₅₈	336.2		
170	45.6	82.0	0.4880	1.0986	0.2410 ₅₃	3.861 ₈₅	4.149 ₉₄	0.2590 ₅₈	338.0		
171	45.7	82.1	0.4903	1.0945	0.2357 ₅₂	3.776 ₈₄	4.243 ₉₅	0.2648 ₆₁	339.8		
172	45.7	82.2	0.4926	1.0904	0.2305 ₅₁	3.692 ₈₁	4.338 ₁₀₁	0.2709 ₆₀	341.6		
173	45.8	82.4	0.4949	1.0863	0.2254 ₅₀	3.611 ₈₀	4.437 ₁₀₀	0.2760 ₆₄	343.4		
174	45.8	82.5	0.4972	1.0823	0.2204 ₄₈	3.531 ₇₆	4.537 ₁₀₁	0.2833 ₆₂	345.2		
175	45.9	82.6	0.4995	1.0783	0.2156 ₄₇	3.455 ₇₆	4.638 ₁₀₄	0.2895 ₆₅	347.0		
176	46.0	82.7	0.5018	1.0743	0.2109 ₄₅	3.379 ₇₃	4.742 ₁₀₃	0.2960 ₆₅	348.8		
177	46.0	82.8	0.5041	1.0703	0.2064 ₄₄	3.306 ₇₀	4.845 ₁₀₅	0.3025 ₆₇	350.6		
178	46.1	82.9	0.5064	1.0663	0.2020 ₄₄	3.236 ₇₁	4.950 ₁₁₁	0.3092 ₆₈	352.4		
179	46.2	83.0	0.5087	1.0623	0.1976 ₄₂	3.165 ₆₇	5.066 ₁₁₀	0.3162 ₆₈	354.2		
180	46.2	83.1	0.5110	1.0583	0.1934 ₄₁	3.098 ₆₆	5.171 ₁₁₂	0.3228 ₇₀	356.0		
181	46.3	83.2	0.5123	1.0544	0.1893 ₄₀	3.032 ₆₄	5.283 ₁₁₄	0.3298 ₇₁	357.8		
182	46.3	83.3	0.5146	1.0505	0.1853 ₃₉	2.968 ₆₂	5.397 ₁₁₆	0.3368 ₇₂	359.6		
183	46.4	83.4	0.5168	1.0466	0.1814 ₃₈	2.906 ₆₁	5.513 ₁₁₈	0.3441 ₇₄	361.4		
184	46.4	83.5	0.5191	1.0427	0.1776 ₃₇	2.845 ₆₀	5.631 ₁₁₉	0.3515 ₇₆	363.2		
185	46.5	83.6	0.5224	1.0389	0.1739 ₃₆	2.785 ₅₇	5.750 ₁₂₂	0.3581 ₇₅	365.0		
186	46.5	83.7	0.5246	1.0350	0.1703 ₃₆	2.728 ₅₈	5.872 ₁₂₇	0.3666 ₇₉	366.8		
187	46.6	83.8	0.5269	1.0311	0.1667 ₃₄	2.670 ₅₄	5.999 ₁₂₅	0.3745 ₈₂	368.6		
188	46.6	83.9	0.5291	1.0272	0.1633 ₃₃	2.616 ₅₃	6.124 ₁₂₆	0.3823 ₇₈	370.4		
189	46.7	84.0	0.5314	1.0234	0.1600 ₃₃	2.563 ₅₃	6.250 ₁₃₂	0.3902 ₈₂	372.2		
190	46.8	84.1	0.5336	1.0196	0.1567 ₃₂	2.510 ₅₁	5.382 ₁₃₃	0.3984 ₈₃	374.0		

SATURATED STEAM—TABLE III.

Temperature, Degrees Centi- grade.	PRESSURE			HEAT OF THE LIQUID		HEAT OF VAPORIZATION.		HEAT EQUIVA- LENT OF IN- INTERNAL WORK.		Temperature, Degrees Fahr.
	Milli- meters of Mer- cury.	Kilo- grams per Square Centi- meter.	Pounds per Square Inch.	Calories.	B.T.U.	Calories.	B.T.U.	Calories.	B.T.U.	
t	p	p	p	q	q	r	r	s	p	r
191	9633 ₂₁₁	13.097 ₂₈₇	186.28 _{4.08}	193.3	347.9	471.5	848.6	424.8	764.4	375.8
192	9844 ₂₁₄	13.384 ₂₉₁	190.36 _{4.14}	194.4	349.8	470.7	847.1	423.9	763.0	377.6
193	10058 ₂₁₈	13.675 ₂₉₇	194.50 _{4.22}	195.4	351.7	470.0	845.9	423.2	761.6	379.4
194	10276 ₂₂₂	13.972 ₃₀₁	198.72 _{4.29}	196.4	353.5	469.2	844.7	422.4	760.3	381.2
195	10498 ₂₂₆	14.273 ₃₀₈	203.01 _{4.37}	197.5	355.4	468.5	843.4	421.6	758.9	383.0
196	10724 ₂₂₉	14.581 ₃₁₁	207.38 _{4.43}	198.5	357.3	467.8	842.0	420.8	757.4	384.8
197	10953 ₂₃₃	14.892 ₃₁₇	211.81 _{4.50}	199.5	359.2	467.1	840.7	420.0	756.1	386.6
198	11186 ₂₃₈	15.205 ₃₂₄	216.31 _{4.61}	200.6	361.1	466.3	839.4	419.2	754.6	388.4
199	11424 ₂₄₀	15.533 ₃₂₆	220.92 _{4.64}	201.6	362.9	465.6	838.0	418.4	753.2	390.2
200	11664 ₂₄₅	15.859 ₃₃₄	225.56 _{4.74}	202.7	364.8	464.8	836.7	417.6	751.8	392.0
201	11909 ₂₄₉	16.193 ₃₃₇	230.30 _{4.81}	203.7	366.7	464.1	835.5	417.0	750.5	393.8
202	12158 ₂₅₃	16.530 ₃₄₅	235.11 _{4.89}	204.7	368.5	463.4	834.1	416.3	749.1	395.6
203	12411 ₂₅₇	16.875 ₃₄₈	240.00 _{4.97}	205.8	370.4	462.6	832.7	415.4	747.7	397.4
204	12668 ₂₆₂	17.223 ₃₅₇	244.97 _{5.06}	206.8	372.3	461.9	831.4	414.7	746.4	399.2
205	12930 ₂₆₅	17.580 ₃₅₉	250.03 _{5.12}	207.9	374.1	461.1	830.1	413.8	745.0	401.0
206	13195 ₂₇₀	17.939 ₃₆₈	255.15 _{5.22}	208.9	376.0	460.4	828.8	413.1	743.6	402.8
207	13465 ₂₇₄	18.307 ₃₇₂	260.37 _{5.30}	210.0	377.9	459.6	827.5	412.3	742.2	404.6
208	13739 ₂₇₉	18.679 ₃₇₉	265.67 _{5.40}	211.0	379.8	458.9	826.1	411.6	740.9	406.4
209	14018 ₂₈₃	19.058 ₃₈₄	271.07 _{5.49}	212.0	381.6	458.1	824.8	410.7	739.5	408.2
210	14301 ₂₈₇	19.442 ₃₉₀	276.54 _{5.55}	213.1	383.5	457.5	823.5	410.1	738.1	410.0
211	14588 ₂₉₂	19.832 ₃₉₈	282.09 _{5.64}	214.1	385.4	456.7	822.1	409.3	736.7	411.8
212	14880 ₂₉₇	20.230 ₄₀₄	287.73 _{5.75}	215.2	387.3	456.0	820.8	408.6	735.3	413.6
213	15177 ₃₀₁	20.634 ₄₀₉	293.48 _{5.82}	216.2	389.2	455.3	819.5	407.9	734.1	415.4
214	15478 ₃₀₇	21.043 ₄₁₈	299.30 _{5.94}	217.3	391.1	454.5	818.2	407.0	732.7	417.2
215	15785 ₃₁₁	21.461 ₄₂₃	305.24 _{6.01}	218.3	392.9	453.8	816.8	406.3	731.3	419.0
216	16096 ₃₁₅	21.884 ₄₂₈	311.25 _{6.09}	219.3	394.8	453.1	815.4	405.5	729.9	420.8
217	16411 ₃₂₁	22.312 ₄₃₆	317.34 _{6.21}	220.4	396.7	452.3	814.1	404.8	728.5	422.6
218	16732 ₃₂₆	22.748 ₄₄₃	323.55 _{6.30}	221.4	398.5	451.6	812.7	404.0	727.2	424.4
219	17058 ₃₃₁	23.191 ₄₅₁	329.85 _{6.41}	222.5	400.4	450.8	811.4	403.3	725.8	426.2
220	17389 ₃₃₁	23.642 ₄₅₁	336.26 _{6.41}	223.5	402.3	450.1	810.1	402.5	724.6	428.0

SATURATED STEAM—TABLE III.

63

Temperature, Degrees Centi- grade.	HEAT EQUIVALENCE OF EXTER- NAL WORK.			Entropy of the Liquid.	Entropy of Vaporization	SPECIFIC VOLUME.		DENSITY.			Temperature, Degrees Fahr.
	Calories.		B.T.U.			Cubic Metres per Kilo.	Cubic Feet per Pound.	Weight, in Kilos, grams, of One Cubic Meter.	Weight, in Pounds of One Cubic Foot.		
	t	Aps	Aps	s	T	s	s	y	y		
191	46.8	84.2	0.5358	1.0158	0.1535	2.459 ₃₁	6.515 ₁₃₄	0.4067 ₈₄	375.8		
192	46.9	84.3	0.5381	1.0121	0.1504 ₃₀	2.409 ₄₈	6.649 ₁₃₅	0.4151 ₈₄	377.6		
193	46.9	84.3	0.5303	1.0084	0.1474 ₃₀	2.361 ₄₈	6.784 ₁₄₁	0.4235 ₈₈	379.4		
194	46.9	84.4	0.5326	1.0047	0.1444 ₂₉	2.313 ₄₆	6.925 ₁₄₂	0.4323 ₈₈	381.2		
195	47.0	84.5	0.5448	1.0010	0.1415 ₂₈	2.267 ₄₅	7.067 ₁₄₃	0.4411 ₈₉	383.0		
196	47.0	84.6	0.5470	0.9973	0.1387 ₂₇	2.222 ₄₅	7.210 ₁₄₃	0.4500 ₈₉	384.8		
197	47.1	84.7	0.5492	0.9936	0.1360 ₂₇	2.179 ₄₄	7.353 ₁₄₉	0.4589 ₉₅	386.6		
198	47.1	84.7	0.5514	0.9899	0.1333 ₂₇	2.135 ₄₄	7.502 ₁₅₅	0.4684 ₉₆	388.4		
199	47.2	84.8	0.5536	0.9862	0.1306 ₂₆	2.092 ₄₁	7.657 ₁₅₆	0.4780 ₉₇	390.2		
200	47.2	84.9	0.5558	0.9826	0.1280 ₂₆	2.051 ₄₂	7.813 ₁₆₁	0.4877 ₁₀₁	392.0		
201	47.2	84.9	0.5580	0.9790	0.1254 ₂₄	2.009 ₃₉	7.974 ₁₅₆	0.4978 ₁₀₂	393.8		
202	47.3	85.0	0.5602	0.9754	0.1230 ₂₄	1.970 ₃₈	8.130 ₁₆₂	0.5076 ₁₀₀	395.6		
203	47.3	85.0	0.5624	0.9718	0.1206 ₂₃	1.932 ₃₇	8.292 ₁₆₁	0.5176 ₁₀₁	397.4		
204	47.3	85.1	0.5646	0.9682	0.1183 ₂₃	1.895 ₃₇	8.453 ₁₆₈	0.5277 ₁₀₅	399.2		
205	47.4	85.1	0.5668	0.9646	0.1160 ₂₃	1.858 ₃₇	8.621 ₁₇₄	0.5382 ₁₀₉	401.0		
206	47.4	85.2	0.5690	0.9610	0.1137 ₂₂	1.821 ₃₅	8.795 ₁₇₄	0.5491 ₁₀₈	402.8		
207	47.4	85.2	0.5712	0.9575	0.1115 ₂₂	1.786 ₃₃	8.969 ₁₇₂	0.5599 ₁₀₉	404.6		
208	47.4	85.3	0.5733	0.9540	0.1094 ₂₁	1.752 ₃₄	9.141 ₁₇₂	0.5708 ₁₁₁	406.4		
209	47.5	85.3	0.5755	0.9505	0.1073 ₂₁	1.719 ₃₃	9.320 ₁₈₈	0.5817 ₁₁₂	408.2		
210	47.5	85.4	0.5777	0.9470	0.1052 ₂₀	1.686 ₃₃	9.486 ₁₈₆	0.5931 ₁₁₄	410.0		
211	47.5	85.4	0.5799	0.9435	0.1032 ₁₉	1.653 ₃₀	9.650 ₁₈₄	0.6050 ₁₁₉	411.8		
212	47.5	85.4	0.5820	0.9400	0.1013 ₁₉	1.622 ₃₀	9.872 ₁₈₈	0.6163 ₁₁₈	413.6		
213	47.5	85.5	0.5842	0.9366	0.0994 ₁₉	1.592 ₃₀	10.06 ₂₀	0.6281 ₁₂₁	415.4		
214	47.6	85.5	0.5863	0.9332	0.0975 ₁₉	1.562 ₃₀	10.26 ₂₀	0.6402 ₁₂₃	417.2	*	
215	47.6	85.5	0.5885	0.9298	0.0956 ₁₈	1.532 ₂₉	10.46 ₂₀	0.6525 ₁₂₈	419.0		
216	47.6	85.5	0.5906	0.9264	0.0938 ₁₈	1.503 ₂₉	10.66 ₂₁	0.6653 ₁₃₁	420.8		
217	47.6	85.5	0.5927	0.9230	0.0920 ₁₇	1.474 ₂₈	10.87 ₂₀	0.6784 ₁₃₂	422.6		
218	47.6	85.6	0.5948	0.9196	0.0903 ₁₇	1.446 ₂₇	11.07 ₂₂	0.6916 ₁₃₁	424.4		
219	47.6	85.6	0.5969	0.9162	0.0886 ₁₇	1.419 ₂₇	11.29 ₂₃	0.7047 ₁₄₁	426.2		
220	47.6	85.6	0.5991	0.9129	0.0869 ₁₇	1.392 ₂₇	11.51 ₂₃	0.7188 ₁₄₁	428.0		

TABLE IV.

SATURATED VAPOR OF ETHER.

FRENCH UNITS.

Temperature, Degrees Centi- grade.	Pressure, Millimeters of Mercury.	Heat of the Liquid.	Total Heat.	Heat of Vaporization.	Heat equivalent of Internal Work.	Heat equivalent of External Work.	Entropy of the Liquid.	Specific Volume.	Weight, In Kilos, of One Cubic Meter.	Density.	Temperature, Degrees Centi- grade.
<i>t</i>	<i>p</i>	<i>q</i>	<i>R</i>	<i>r</i>	<i>s</i>	<i>A pu</i>	<i>s</i>	<i>s</i>	<i>y</i>	<i>t</i>	
0	184.39	0.00	94.00	94.00	86.45	7.55	0.0000	1.278	0.728	0	
10	286.83	5.32	98.44	93.12	85.37	7.75	0.01909	0.84440	1.185	10	
20	432.78	10.70	102.78	92.08	84.13	7.95	0.03772	0.5741	1.742	20	
30	634.80	16.14	107.00	90.86	82.72	8.14	0.05593	0.4013	2.492	30	
40	907.04	21.63	111.11	89.48	81.15	8.33	0.07374	0.2877	3.746	40	
50	1264.8	27.19	115.11	87.92	79.41	8.51	0.09117	0.2108	4.744	50	
60	1725.0	32.80	119.00	86.20	77.53	8.67	0.1083	0.1580	6.329	60	
70	2304.9	38.48	122.78	84.30	75.49	8.81	0.1250	0.1203	8.313	70	
80	3022.8	44.21	126.44	82.23	73.32	8.91	0.1415	0.0932	10.73	80	
90	3898.3	50.00	130.00	80.00	71.03	8.97	0.1576	0.0731	13.68	90	
100	4953.3	55.86	133.44	77.58	68.62	8.96	0.1735	0.0577	17.33	100	
110	6214.6	61.77	136.78	75.01	66.13	8.88	0.1891	0.0459	21.79	110	
120	7719.2	67.74	140.00	72.26	63.57	8.69	0.2045	0.0364	27.47	120	

TABLE V.
SATURATED VAPOR OF ALCOHOL.
FRENCH UNITS.

Temperature, Degrees Centi- grade.	Pressure, Millimeters of Mercury.	Heat of the Liquid.	<i>H</i>	<i>r</i>	Heat of Vaporization.	<i>s</i>	Heat equivalent of Internal Work.	Heat equivalent of External Work	<i>Aps</i>	<i>e</i>	Entropy of the Liquid	<i>s</i>	Density,			
													<i>w</i>	<i>z</i>	<i>y</i>	
0	12.70	0.00	236.5	236.50	223.38	13.12	0.0000	32.21	0.03105	0						
10	24.23	5.59	244.4	238.81	225.29	13.52	0.01996	17.39	0.05750	10						
20	44.46	11.42	252.0	240.58	226.56	14.02	0.04003	9.847	0.1016	20						
30	78.52	17.49	258.0	240.51	226.03	14.48	0.06029	5.753	0.1738	30						
40	133.69	23.71	262.0	238.29	223.44	14.85	0.08073	3.465	0.2886	40						
50	219.90	30.21	264.0	233.79	218.59	15.10	0.1014	2.143	0.4666	50						
60	350.21	37.37	265.0	227.63	212.38	15.25	0.1223	1.359	0.7358	60						
70	541.15	44.58	265.2	220.62	205.28	15.34	0.1435	0.8855	1.129	70						
80	812.91	52.11	265.2	213.09	197.69	15.40	0.1650	0.5921	1.689	80						
90	1189.3	59.97	266.0	206.03	190.54	15.49	0.1868	0.4073	2.455	90						
100	1697.6	68.18	267.3	199.12	183.54	15.58	0.2090	0.2874	3.479	100						
110	2367.6	76.74	269.6	192.86	177.15	15.71	0.2315	0.3083	4.801	110						
120	3231.7	85.67	272.5	186.83	170.97	15.86	0.2544	0.1544	6.477	120						
130	4323.0	94.98	276.0	181.02	164.99	16.03	0.2776	0.1170	8.547	130						
140	5674.6	104.70	280.5	175.80	159.55	16.25	0.3013	0.0905	11.05	140						
150	7318.4	114.82	285.3	170.48	154.03	16.45	0.3254	0.0714	14.01	150						

TABLE VI.
SATURATED VAPOR OF CHLOROFORM.
FRENCH UNITS.

Temperature, Degrees Centi- grade.	t	Pressure, Millimeters of Mercury.	Heat of the Liquid.	Total Heat.	Heat of Vaporization.	p	Heat equivalent of Internal Work.	A _{pu}	Entropy of the Liquid.	s	Specific Volume.	Weight, In Kilos, of One Cubic Meter.	Density.	Temperature, Degrees Centi- grade.
0	59.72	0.00	67.00	67.00	62.45	4.55	0.00000	2.377	0.4207	0				0
10	100.47	2.33	68.38	66.04	61.29	4.75	0.00836	1.475	0.6780	10				10
20	160.47	4.67	69.75	65.08	60.14	4.94	0.01646	0.9601	1.042	20				20
30	247.51	7.02	71.12	64.10	59.00	5.10	0.02432	0.6437	1.554	30				30
40	369.26	9.37	72.50	63.13	57.87	5.26	0.03196	0.4449	2.248	40				40
50	535.05	11.74	73.87	62.13	56.73	5.40	0.03940	0.3155	3.170	50				50
60	755.44	14.12	75.25	61.13	55.60	5.53	0.04664	0.2291	4.356	60				60
70	1042.1	16.51	76.62	60.11	54.45	5.66	0.05369	0.1700	5.88	70				70
80	1407.6	18.91	78.00	59.09	53.31	5.78	0.06057	0.1286	7.78	80				80
90	1865.2	21.32	79.37	58.05	52.16	5.89	0.06729	0.0991	10.09	90				90
100	2428.5	23.74	80.75	57.01	51.01	6.00	0.07386	0.0777	12.87	100				100
110	3111.0	26.17	82.12	55.95	49.84	6.11	0.08027	0.0618	16.18	110				110
120	3925.7	28.61	83.50	54.89	48.67	6.22	0.08655	0.0500	20.00	120				120
130	4885.1	31.06	84.87	53.81	47.48	6.33	0.09270	0.0410	24.39	130				130
140	6000.2	33.52	86.25	52.73	46.30	6.43	0.09872	0.0340	29.4	140				140
150	7280.6	35.99	87.62	51.63	45.10	6.53	0.10462	0.0286	35.0	150				150
160	8734.2	38.47	89.00	50.53	43.90	6.63	0.11041	0.0243	41.2	160				160

TABLE VII.
SATURATED VAPOR OF CARBON BISULPHIDE.
FRENCH UNITS.

Temperature, Degrees Centi- grade.	Pressure, Millimeters of Mercury.	Heat of the Liquid.	Total Heat.	Heat of Vaporation.	Heat equivalent of Internal Work.	Heat equivalent of External Work.	Entropy of the Liquid.	Specific Volume.	Weight, in Kilograms per Cubic Meter.	Temperature, Degrees Centi- grade.
<i>t</i>	<i>p</i>	<i>a</i>	<i>H</i>	<i>r</i>	<i>s</i>	<i>Aps</i>	<i>S</i>	<i>v</i>	<i>w</i>	<i>t</i>
0	127.91	0.00	90.00	90.00	82.76	7.24	0.00000	1.766	0.5662	0
10	198.46	2.36	91.42	89.06	81.58	7.48	0.00847	1.177	0.8496	10
20	298.03	4.74	92.76	88.02	80.31	7.71	0.01670	0.8071	1.239	20
30	434.62	7.13	94.01	86.88	78.97	7.91	0.02472	0.5684	1.759	30
40	617.53	9.54	95.18	85.64	77.54	8.10	0.03252	0.4098	2.440	40
50	857.07	11.96	96.27	84.31	76.04	8.27	0.04013	0.3017	3.315	50
60	1164.5	14.41	97.28	82.87	74.45	8.42	0.04756	0.2264	4.417	60
70	1552.1	16.86	98.20	81.34	72.78	8.56	0.05482	0.1726	5.794	70
80	2032.5	19.34	99.04	79.70	71.03	8.67	0.06192	0.1335	7.473	80
90	2619.1	21.83	99.80	77.97	69.20	8.77	0.06886	0.1052	9.51	90
100	3325.2	24.34	100.48	76.14	67.29	8.85	0.07566	0.0837	11.95	100
110	4164.1	26.86	101.07	74.21	65.31	8.90	0.08233	0.0674	14.84	110
120	5148.8	29.40	101.58	72.18	63.24	8.94	0.08886	0.0549	18.21	120
130	6291.6	31.96	102.01	70.05	61.09	8.96	0.09527	0.0452	22.12	130
140	7604.0	34.53	102.36	67.83	58.88	8.95	0.10157	0.0375	26.7	140
150	9095.9	37.12	102.62	65.50	56.58	8.92	0.10775	0.0314	31.8	150

TABLE VIII.

SATURATED VAPOR OF CARBON TETRACHLORIDE.

FRENCH UNITS.

Temperature, Degrees Centi- grade.	Pressure, Millimeters of Mercury.	Heat of the Liquid.	Total Heat.	Heat of Vaporization.	Heat equivalent of Internal Work.	Heat equivalent of External Work.	Entropy of the Liquid.	Specific Volume.	Density.		Temperature, Degrees Centi- grade.
									w	γ	
t	p	q	H	r	s	A _{Pu}	θ	w	γ	1	
0	32.95	0.00	52.00	52.00	48.54	3.46	0.00000	3.272	0.3056	0	
10	55.97	1.99	53.44	51.45	47.85	3.60	0.00714	2.005	0.4987	10	
20	90.99	3.99	54.86	50.87	47.13	3.74	0.01409	1.283	0.7794	20	
30	142.27	6.02	56.23	50.21	46.33	3.88	0.02087	0.8510	1.175	30	
40	214.81	8.06	57.58	49.52	45.51	4.01	0.02749	0.5831	1.715	40	
50	314.38	10.12	58.88	48.76	44.62	4.14	0.03396	0.4109	2.434	50	
60	447.43	12.20	60.16	47.96	43.69	4.25	0.04028	0.2969	3.368	60	
70	621.15	14.30	61.40	47.10	42.75	4.35	0.04648	0.2192	4.562	70	
80	843.29	16.42	62.60	46.18	41.74	4.44	0.04255	0.1650	6.061	80	
90	1122.3	18.55	63.77	45.22	40.50	4.72	0.05849	0.1263	7.92	90	
100	1467.1	20.70	64.90	44.20	39.62	4.58	0.06432	0.0980	10.20	100	
110	1887.4	22.87	66.01	43.14	38.52	4.62	0.07006	0.0770	12.99	110	
120	2393.7	25.06	67.07	42.01	37.36	4.65	0.07569	0.0611	16.37	120	
130	2996.9	27.27	68.10	40.83	36.18	4.65	0.08122	0.0490	20.41	130	
140	3709.0	29.49	69.10	39.61	34.95	4.63	0.08666	0.0395	25.3	140	
150	4543.1	31.73	70.07	38.34	33.75	4.59	0.09201	0.0321	31.2	150	
160	5513.1	34.00	71.00	37.00	32.47	4.53	0.09729	0.0262	38.2	160	

TABLE IX.
SATURATED VAPOR OF ACETON.
FRENCH UNITS.

Temperature, Degrees Centi- grade.	Pressure, Millimeters of Mercury.	Heat of the Liquid.	Total Heat.	Heat of Vaporization.	Heat equivalent of Internal Work.	Heat equivalent of External Work.	Entropy of the Liquid.	Specific Volume.	Weight, in Kilos, of One Cubic Meter.	Temperature, Degrees Centi- grade.
<i>t</i>	<i>p</i>	<i>q</i>	<i>H</i>	<i>r</i>	<i>s</i>	<i>Apu</i>	<i>s</i>	<i>v</i>	<i>y</i>	<i>t</i>
0	63.33	0.00	140.50	140.50	131.82	8.58	0.00000	4.275	0.2339	0
10	110.32	5.10	144.11	139.01	129.51	9.50	0.01832	2.686	0.3723	10
20	180.08	10.29	147.62	137.33	127.16	10.17	0.03627	1.758	0.5688	20
30	280.05	15.35	151.03	135.48	124.83	10.65	0.05389	1.187	0.8425	30
40	419.35	20.89	154.33	133.44	121.39	11.05	0.07119	0.8227	1.215	40
50	608.81	26.31	157.53	131.22	119.86	11.36	0.08820	0.5830	1.715	50
60	860.96	31.81	160.63	128.82	117.22	11.60	0.1049	0.4215	2.372	60
70	1189.9	37.39	163.62	126.23	114.43	11.80	0.1214	0.3106	3.220	70
80	1611.1	43.05	166.51	123.46	111.49	11.97	0.1376	0.2328	4.296	80
90	2140.8	48.79	169.30	120.51	108.41	12.10	0.1536	0.1773	5.640	90
100	2796.2	54.61	171.98	117.37	105.17	12.20	0.1694	0.1372	7.289	100
110	3594.3	60.50	174.56	114.06	101.78	12.28	0.1850	0.1076	9.294	110
120	4552.0	66.48	177.04	110.56	98.23	12.33	0.2004	0.0856	11.68	120
130	5684.9	72.54	179.42	106.88	94.53	12.35	0.2156	0.0689	14.51	130
140	7007.6	78.67	181.69	103.02	90.67	12.35	0.2306	0.0561	17.83	140

TABLE X.
SATURATED VAPOR OF AMMONIA.
ENGLISH UNITS.

Temperature, Degrees Fahr. reheit,	Pressure, Pounds per Square Inch.	Heat of the Liquid.	Total Heat.	Heat of Vaporization.	Heat equivalent of Internal Work.	Heat equivalent of External Work.	Entropy of the Liquid.	Specific Volume.	Density, In pounds of One Cubic Foot.	Temperature, Degrees Fahr. reheit.
<i>t</i>	<i>p</i>	<i>q</i>	<i>H</i>	<i>r</i>	<i>s</i>	<i>Apu</i>	<i>θ</i>	<i>n</i>	<i>γ</i>	<i>t</i>
-40	9.93	-79	519	598	550	48	-0.1737	26.1	0.0383	-40
-35	11.53	-74	520	594	546	48	-0.1607	22.6	0.0442	-35
-30	13.36	-68	522	590	541	49	-0.1482	19.7	0.0507	-30
-25	15.40	-63	523	586	537	49	-0.1354	17.3	0.0580	-25
-20	17.70	-57	525	582	532	50	-0.1229	15.2	0.0660	-20
-15	20.25	-52	526	578	528	50	-0.1102	13.3	0.0750	-15
-10	23.10	-46	528	574	524	50	-0.0982	11.8	0.0848	-10
-5	26.25	-41	529	570	519	51	-0.0859	10.5	0.0956	-5
0	29.74	-35	531	566	515	51	-0.0738	9.32	0.108	0
5	33.58	-30	532	562	511	51	-0.0619	8.31	0.120	5
10	37.80	-24	534	558	506	52	-0.0501	7.44	0.134	10
15	42.43	-19	535	554	502	52	-0.0386	6.68	0.150	15
20	47.49	-13	537	550	497	53	-0.0271	6.02	0.166	20
25	53.01	-8	538	546	493	53	-0.0157	5.43	0.184	25
30	59.01	-2	540	542	489	53	-0.0044	4.92	0.203	30
35	65.53	3	541	538	484	54	0.0067	4.46	0.225	35
40	72.59	9	543	534	480	54	0.0177	4.06	0.247	40
45	80.21	14	544	530	475	55	0.0287	3.70	0.270	45
50	88.44	20	546	526	471	55	0.0395	3.38	0.296	50
55	97.30	25	547	522	467	55	0.0502	3.09	0.323	55
60	106.82	31	549	518	462	56	0.0608	2.84	0.352	60
65	117.04	36	550	514	458	56	0.0713	2.61	0.383	65
70	127.98	42	552	510	454	56	0.0817	2.40	0.416	70
75	139.67	47	553	506	449	57	0.0921	2.22	0.451	75
80	152.15	53	555	502	445	57	0.1023	2.05	0.488	80
85	165.47	58	556	498	441	57	0.1124	1.90	0.527	85
90	179.64	64	558	494	436	58	0.1224	1.76	0.568	90
95	194.70	69	559	490	432	58	0.1324	1.63	0.612	95
100	210.70	75	561	486	428	58	0.1423	1.52	0.657	100

TABLE XI.
SATURATED VAPOR OF SULPHUR DIOXIDE.
ENGLISH UNITS.

Temperature, Degrees Fahr. and Celcius.	Pressure, Pounds per Square Inch.	Heat of the Liquid.	Total Heat.	Heat of Vaporization.	Heat equivalent of Internal Work.	Heat equivalent of External Work.	Entropy of the Liquid.	Specific Volume.	Weight, in Pounds, of One Cubic Foot.	Temperature, Degrees Fahr. and Celcius.
<i>t</i>	<i>p</i>	<i>q</i>	<i>H</i>	<i>r</i>	<i>s</i>	<i>Apu</i>	<i>e</i>	<i>s</i>	<i>y</i>	<i>t</i>
-40	3.14	-29	166	195	182	13	-0.0632	23.0	0.0434	-40
-35	3.70	-27	167	194	180	14	-0.0584	19.7	0.0507	-35
-30	4.34	-25	168	193	179	14	-0.0539	17.0	0.0590	-30
-25	5.07	-23	168	191	177	14	-0.0492	14.7	0.0682	-25
-20	5.90	-21	169	190	176	14	-0.0447	12.7	0.0785	-20
-15	6.83	-19	170	189	175	14	-0.0401	11.1	0.0901	-15
-10	7.88	-17	170	187	173	14	-0.0357	9.73	0.103	-10
-5	9.05	-15	171	186	172	14	-0.0312	8.56	0.117	-5
0	10.35	-13	172	185	170	15	-0.0268	7.54	0.133	0
5	11.81	-11	172	183	168	15	-0.0225	6.67	0.450	5
10	13.41	-9	173	182	167	15	-0.0182	5.93	0.169	10
15	15.19	-7	174	181	166	15	-0.0140	5.29	0.189	15
20	17.15	-5	174	179	164	15	-0.0098	4.72	0.212	20
25	19.30	-3	175	178	163	15	-0.0057	4.23	0.236	25
30	21.66	-1	176	177	162	15	-0.0016	3.81	0.263	30
35	24.24	1	176	175	160	15	0.0024	3.43	0.291	35
40	27.06	3	177	174	158	16	0.0064	3.10	0.322	40
45	30.12	5	177	172	156	16	0.0104	2.81	0.356	45
50	33.45	7	178	171	155	16	0.0144	2.58	0.390	50
55	37.07	9	179	170	154	16	0.0182	2.32	0.430	55
60	40.98	11	179	168	152	16	0.0221	2.11	0.473	60
65	45.20	13	180	167	151	16	0.0259	1.94	0.515	65
70	49.75	15	181	166	150	16	0.0297	1.78	0.563	70
75	54.64	17	181	164	148	16	0.0334	1.63	0.614	75
80	59.90	19	182	163	146	17	0.0372	1.50	0.668	80
85	65.54	21	183	162	145	17	0.0409	1.38	0.725	85
90	71.57	23	183	160	143	17	0.0445	1.27	0.786	90
95	78.02	25	184	159	142	17	0.0482	1.18	0.849	95
100	84.90	27	185	158	141	17	0.0518	1.09	0.917	100

TABLE XII.

SPECIFIC GRAVITY AND SPECIFIC VOLUME OF LIQUIDS.

Name of Liquid.	Specific Gravity, compared with Water at 4° C.	Specific Volume, Cubic Meters per Kilo.
Alcohol, C_2H_5O	0.80625 [Mendeleeff, 1869] . . .	0.001240
Ether, $C_2H_{10}O$	0.736 [Kopp, 1860]	0.001358
Chloroform	1.527 [Thorpe, 1880]	0.000655
Carbon bisulphide, CS_2	1.2922 [Thorpe, 1880]	0.000774
Carbon tetrachloride, CCl_4	1.6320 [Thorpe, 1880]	0.000613
Aceton, C_3H_6O	0.81 [Zander, 1882]	0.00123
Sulphur Dioxide, SO_2	1.4336 [Andréeff, 1859]	0.0006981
Ammonia, NH_3	0.6364 [Andréeff, 1859]	0.001571

TABLE XIII.

VOLUME OF WATER.

Vol. at 4° C. = 1.

[Rossetti, 1871] and [Hirn, 1867].

Temper- ature.	Volume.	Temper- ature.	Volume.	Temper- ature.	Volume.	Temper- ature.	Volume.
10	1.000253	60	1.01691	110	1.0512	160	1.1018
20	1.001744	70	1.02256	120	1.0599	170	1.1139
30	1.00425	80	1.02887	130	1.0694	180	1.1268
40	1.00770	90	1.03567	140	1.0795	190	1.1403
50	1.01195	100	1.04312	150	1.0903	200	1.1544

TABLE XIV.

CONVERSION TABLE.

INCHES OF MERCURY AND POUNDS PER SQUARE INCH.

TABLE XV.

CORRECTIVE FACTORS FOR SUPERHEATED STEAM.

Values of the factor $\frac{150,300,000}{T^3} - 0.0833$.

Temperature.		Value. of Factor.	Temperature.		Value. of Factor.	Temperature.		Value of Factor.
Fahr.	Abs.		Fahr.	Abs.		Fahr.	Abs.	
200	659.5	0.441	335	794.5	0.216	470	929.5	0.104
205	664.5	0.429	340	799.5	0.211	475	934.5	0.101
210	669.5	0.417	345	804.5	0.205	480	939.5	0.098
215	674.5	0.405	350	809.5	0.200	485	944.5	0.095
220	679.5	0.395	355	814.5	0.195	490	949.5	0.092
225	684.5	0.385	360	819.5	0.190	495	954.5	0.090
230	689.5	0.375	365	824.5	0.185	500	959.5	0.087
235	694.5	0.365	370	829.5	0.180	505	964.5	0.084
240	699.5	0.356	375	834.5	0.175	510	969.5	0.082
245	704.5	0.347	380	839.5	0.171	515	974.5	0.079
250	709.5	0.338	385	844.5	0.166	520	979.5	0.077
255	714.5	0.329	390	849.5	0.162	525	984.5	0.074
260	719.5	0.320	395	854.5	0.158	530	989.5	0.072
265	724.5	0.312	400	859.5	0.153	535	994.5	0.070
270	729.5	0.304	405	864.5	0.149	540	999.5	0.067
275	734.5	0.296	410	869.5	0.145	545	1004.5	0.065
280	739.5	0.288	415	874.5	0.141	550	1009.5	0.063
285	744.5	0.281	420	879.5	0.138	555	1014.5	0.061
290	749.5	0.274	425	884.5	0.134	560	1019.5	0.059
295	754.5	0.267	430	889.5	0.131	565	1024.5	0.057
300	759.5	0.260	435	894.5	0.127	570	1029.5	0.055
305	764.5	0.253	440	899.5	0.123	575	1034.5	0.053
310	769.5	0.247	445	904.5	0.120	580	1039.5	0.051
315	774.5	0.240	450	909.5	0.117	585	1044.5	0.049
320	779.5	0.234	455	914.5	0.113	590	1049.5	0.047
325	784.5	0.228	460	919.5	0.110	595	1054.5	0.045
330	789.5	0.222	465	924.5	0.107			

TEMPERATURE-ENTROPY TABLE.

THIS table gives the properties of moist and of superheated steam at each degree of temperature Fahrenheit, and for each hundredth of a unit of entropy.

At the left hand of each page are given the temperatures and the corresponding pressures of saturated steam; the lines across the tables are, therefore, constant pressure lines, and for moist steam are also constant temperature lines.

The table is divided by a broken line which corresponds roughly to the saturation line; properties to the left of that line are for moist steam and to the right are for superheated steam.

The triple-columns are headed with the entropy, and are constant entropy lines; they can be used for solving problems concerning adiabatic operations in a closed cylinder, and similar problems.

At any point in the table, determined by the entropy and the pressure (or the corresponding temperature of saturated steam), there are given three properties:—

(1) *The quality*, which for moist steam is the proportion of a pound that is steam, and for superheated steam is the number of degrees of superheating.

(2) *The heat contents*, or the number of thermal units required to change a pound of water at freezing into steam at the given pressure and with the given quality.

(3) *The specific volume* in cubic feet per pound.

For examples, solved by aid of the table, see page 30.

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	1.52				1.53				1.54				1.55			
		Quality,	Heat Con- tents,	Specific Volume.	Quality,												
420	308.6	3	1212	1.515	17	1221	1.555	32	1230	1.596	47	1239	1.645				
419	305.2	2	1211	1.526	16	1220	1.572	31	1229	1.610	46	1238	1.659				
418	301.9	1	1210	1.540	15	1219	1.580	30	1228	1.625	44	1237	1.672				
417	298.7	0	1209	1.555	14	1218	1.595	29	1227	1.640	43	1236	1.686				
416	295.4	9996	1208.5	1.581	13	1217	1.610	28	1226	1.654	42	1235	1.701				
415	292.2	9988	1207.5	1.597	12	1216	1.623	27	1225	1.669	41	1234	1.715				
414	289.0	9981	1206.6	1.613	11	1215	1.638	26	1224	1.682	40	1233	1.730				
413	285.9	9974	1205.7	1.629	10	1214	1.650	25	1223	1.697	39	1232	1.744				
412	282.7	9965	1204.7	1.644	9	1213	1.663	24	1222	1.711	38	1231	1.759				
411	279.6	9958	1203.8	1.661	8	1212	1.678	23	1221	1.726	37	1230	1.774				
410	276.5	9949	1202.8	1.677	7	1211	1.695	21	1220	1.740	36	1229	1.790				
409	273.5	9942	1201.9	1.694	6	1210	1.710	20	1219	1.758	35	1228	1.805				
408	270.5	9934	1201.0	1.711	5	1209	1.725	19	1218	1.772	34	1227	1.820				
407	267.5	9926	1200.0	1.728	4	1208	1.740	18	1217	1.788	32	1226	1.837				
406	264.5	9920	1199.2	1.746	3	1207	1.755	17	1216	1.803	31	1225	1.853				
405	261.6	9912	1198.2	1.763	2	1206	1.771	16	1215	1.820	30	1224	1.869				
404	258.6	9904	1197.3	1.781	1	1205	1.787	15	1214	1.836	29	1223	1.886				
403	255.7	9896	1196.3	1.799	0	1204	1.805	14	1213	1.853	28	1222	1.902				
402	252.9	9888	1195.3	1.818	9992	1204.0	1.836	13	1212	1.869	27	1221	1.920				
401	250.0	9881	1194.3	1.836	9985	1202.9	1.856	12	1211	1.885	26	1220	1.936				
400	247.2	9874	1193.4	1.854	9977	1202.0	1.875	11	1210	1.902	25	1219	1.953				
399	244.4	9865	1192.4	1.873	9968	1201.0	1.884	9	1209	1.920	24	1218	1.971				
398	241.7	9858	1191.5	1.892	9961	1200.0	1.913	8	1208	1.938	22	1217	1.990				
397	238.9	9851	1190.6	1.912	9954	1199.1	1.932	7	1207	1.946	21	1216	2.007				
396	236.2	9843	1189.6	1.931	9945	1198.1	1.951	6	1206	1.964	20	1215	2.025				
395	233.5	9835	1188.6	1.951	9938	1197.2	1.971	5	1205	1.992	19	1214	2.044				
394	230.8	9828	1187.7	1.971	9930	1196.3	1.991	4	1204	2.010	18	1213	2.063				
393	228.2	9819	1186.7	1.992	9921	1195.3	2.012	3	1203	2.030	17	1212	2.082				
392	225.6	9813	1185.8	2.012	9914	1194.3	2.033	2	1202	2.048	16	1211	2.100				
391	223.0	9804	1184.8	2.033	9905	1193.3	2.054	1	1201	2.067	15	1210	2.120				
390	220.4	9796	1183.9	2.054	9898	1192.3	2.075	9999	1200.9	2.096	14	1209	2.140				
389	217.8	9789	1182.9	2.075	9890	1191.4	2.097	9991	1199.9	2.118	12	1208	2.160				
388	215.3	9781	1181.9	2.097	9881	1190.4	2.119	9983	1198.9	2.141	11	1207	2.180				
387	212.8	9773	1180.9	2.119	9874	1189.4	2.141	9975	1197.8	2.163	10	1206	2.200				
386	210.3	9765	1179.9	2.141	9865	1188.4	2.163	9966	1196.8	2.185	9	1205	2.220				
385	207.9	9757	1179.0	2.163	9857	1187.4	2.185	9958	1195.8	2.208	8	1204	2.241				
384	205.4	9750	1178.0	2.186	9851	1186.5	2.208	9951	1194.8	2.231	7	1203	2.262				
383	203.0	9744	1177.1	2.209	9843	1185.5	2.232	9943	1193.9	2.254	6	1202	2.284				
382	200.6	9735	1176.1	2.232	9835	1184.5	2.254	9934	1192.9	2.277	5	1201	2.306				
381	198.3	9727	1175.1	2.255	9827	1183.5	2.278	9926	1191.9	2.301	4	1200	2.328				
380	195.9	9720	1174.2	2.278	9819	1182.6	2.302	9918	1190.9	2.325	2	1199	2.350				
379	193.6	9713	1173.2	2.302	9812	1181.6	2.326	9911	1190.0	2.350	1	1998	2.373				
378	191.3	9704	1172.2	2.326	9803	1180.6	2.350	9902	1189.0	2.374	0	1997	2.396				
377	189.0	9696	1171.2	2.351	9795	1179.6	2.375	9894	1188.0	2.399	9992	1196.3	2.423				
376	186.7	9689	1170.2	2.377	9788	1178.6	2.401	9886	1187.0	2.425	9985	1195.3	2.449				
375	184.5	9680	1169.2	2.402	9779	1177.5	2.426	9877	1185.9	2.450	9975	1194.2	2.475				
374	182.3	9674	1168.3	2.429	9772	1176.5	2.453	9870	1184.9	2.477	9968	1193.2	2.502				
373	180.1	9665	1167.3	2.455	9762	1175.5	2.479	9860	1183.9	2.504	9958	1192.2	2.528				

TEMPERATURE-ENTROPY TABLE.

77

Temperature Degrees Fahr. Pressure, Pounds per Square Inch.	1.54			1.57			1.58			1.59		
	Quality	Heat Co- -stants	Specific Volume									
430 308.6 64 1249 1 686 79 1258 1 728 97 1268 1 778 114 1278 1 827												
419 305.2 62 1247 1 701 78 1257 1 743 96 1267 1 792 113 1277 1 841												
418 301.9 61 1246 1 716 77 1256 1 758 95 1266 1 808 112 1276 1 855												
417 298.7 60 1245 1 731 76 1255 1 773 94 1265 1 822 110 1275 1 872												
416 295.4 59 1245 1 745 75 1254 1 788 92 1264 1 838 109 1274 1 888												
415 292.2 58 1244 1 760 73 1253 1 803 91 1263 1 854 108 1273 1 904												
414 289.0 57 1243 1 776 72 1252 1 819 90 1262 1 870 106 1272 1 920												
413 285.9 55 1242 1 791 71 1251 1 834 88 1260 1 886 105 1271 1 937												
412 282.7 54 1241 1 806 70 1250 1 851 87 1259 1 902 104 1270 1 953												
411 279.6 53 1240 1 821 68 1249 1 867 86 1258 1 919 102 1268 1 970												
410 276.5 52 1239 1 837 67 1248 1 883 85 1257 1 934 101 1267 1 986												
409 273.5 51 1238 1 853 66 1247 1 900 83 1256 1 950 100 1266 1 993												
408 270.5 49 1237 1 869 65 1246 1 916 82 1255 1 967 98 1265 1 990												
407 267.5 48 1236 1 885 63 1245 1 933 81 1254 1 984 97 1264 1 995												
406 264.5 47 1235 1 902 62 1244 1 950 79 1253 2 002 96 1263 1 996												
405 261.6 46 1234 1 918 61 1243 1 967 78 1252 2 020 94 1262 1 973												
404 258.6 45 1233 1 934 60 1242 1 984 77 1251 2 037 93 1261 1 992												
403 255.7 43 1232 1 950 59 1241 2 002 75 1250 2 055 92 1260 1 999												
402 252.9 42 1231 1 967 57 1240 2 019 74 1249 2 073 90 1258 2 128												
401 250.0 41 1230 1 984 56 1239 2 037 73 1248 2 091 89 1257 2 146												
400 247.2 40 1229 2 002 55 1238 2 054 72 1247 2 110 88 1256 2 165												
399 244.4 39 1228 2 020 54 1237 2 073 70 1246 2 129 86 1255 2 184												
398 241.7 38 1227 2 038 53 1236 2 092 69 1245 2 147 85 1254 2 203												
397 238.9 36 1225 2 057 51 1234 2 110 68 1244 2 165 84 1253 2 223												
396 236.2 35 1224 2 075 50 1233 2 139 66 1242 2 184 82 1252 2 243												
395 233.5 34 1223 2 094 49 1232 2 148 65 1241 2 204 81 1251 2 263												
394 230.8 33 1222 2 113 48 1231 2 167 64 1240 2 224 80 1250 2 283												
393 228.2 32 1221 2 131 46 1230 2 186 63 1239 2 244 78 1248 2 303												
392 225.6 30 1220 2 150 45 1229 2 205 61 1238 2 265 77 1247 2 324												
391 223.0 29 1219 2 170 44 1228 2 225 60 1237 2 286 76 1246 2 344												
390 220.4 28 1218 2 190 43 1227 2 245 59 1236 2 306 74 1245 2 365												
389 217.8 27 1217 2 210 42 1226 2 266 57 1235 2 327 73 1244 2 386												
388 215.3 26 1216 2 230 40 1225 2 287 56 1234 2 349 72 1243 2 408												
387 212.8 24 1215 2 250 39 1224 2 308 55 1233 2 370 70 1242 2 430												
386 210.3 23 1214 2 271 38 1223 2 330 54 1232 2 391 69 1241 2 451												
385 207.9 22 1213 2 293 37 1222 2 351 52 1231 2 413 68 1240 2 474												
384 205.4 21 1212 2 315 35 1221 2 372 51 1230 2 434 66 1239 2 496												
383 203.0 20 1211 2 338 34 1220 2 394 50 1229 2 458 65 1238 2 539												
382 200.6 18 1210 2 360 33 1219 2 418 48 1228 2 480 64 1237 2 542												
381 198.3 17 1209 2 383 32 1218 2 440 47 1227 2 502 62 1235 2 566												
380 195.9 16 1208 2 405 30 1217 2 463 46 1226 2 526 61 1234 2 586												
379 193.6 15 1207 2 429 29 1216 2 486 44 1224 2 550 60 1233 2 613												
378 191.3 14 1206 2 452 28 1215 2 509 43 1223 2 575 58 1232 2 630												
377 189.0 12 1205 2 476 27 1214 2 533 42 1222 2 599 57 1231 2 662												
376 186.7 11 1204 2 500 26 1213 2 556 41 1221 2 624 55 1229 2 686												
375 184.5 10 1203 2 524 24 1211 2 580 39 1220 2 648 54 1228 2 712												
374 182.3 9 1202 2 548 23 1210 2 605 38 1219 2 672 52 1227 2 739												
373 180.1 8 1201 2 572 22 1209 2 630 37 1218 2 699 51 1226 2 764												

TEMPERATURE-ENTROPY TABLE

Temperature, Degrees Fahr. Pressure, Pounds per Square Inch.	1.52			1.53			1.54			1.55		
	Quality.	Heat Con- tent.	Specific Volume.									
372 177.9 9658 1166.3 2.481 9756 1174.6 2.504 9853 1182.9 2.531 9951 1191.2 2.556												
371 175.7 9650 1165.3 2.508 9748 1173.6 2.532 9845 1181.9 2.558 9943 1190.2 2.583												
370 173.6 9642 1164.3 2.535 9739 1172.6 2.560 9836 1180.9 2.585 9934 1189.1 2.611												
369 171.5 9634 1163.3 2.563 9731 1171.6 2.588 9828 1179.9 2.613 9925 1188.1 2.639												
368 169.4 9626 1162.3 2.591 9723 1170.6 2.616 9820 1178.9 2.642 9917 1187.1 2.668												
367 167.3 9618 1161.3 2.618 9715 1169.5 2.643 9811 1177.8 2.670 9908 1186.0 2.696												
366 165.3 9611 1160.3 2.647 9708 1168.6 2.673 9804 1176.8 2.699 9901 1185.0 2.726												
365 163.2 9603 1159.3 2.676 9700 1167.6 2.701 9796 1175.8 2.728 9892 1184.0 2.755												
364 161.2 9595 1158.3 2.705 9691 1166.5 2.731 9787 1174.8 2.758 9883 1183.0 2.785												
363 159.2 9587 1157.5 2.734 9683 1165.5 2.762 9779 1173.7 2.788 9875 1182.0 2.815												
362 157.2 9580 1156.3 2.765 9676 1164.5 2.792 9772 1172.7 2.819 9867 1181.0 2.847												
361 155.3 9573 1155.3 2.795 9669 1163.5 2.822 9764 1171.7 2.850 9860 1179.9 2.878												
360 153.3 9565 1154.3 2.827 9661 1162.5 2.855 9756 1170.7 2.882 9852 1178.9 2.910												
359 151.4 9558 1153.3 2.858 9653 1161.5 2.886 9748 1169.7 2.914 9843 1177.9 2.942												
358 149.5 9550 1152.3 2.890 9645 1160.5 2.918 9740 1168.6 2.946 9834 1176.8 2.975												
357 147.6 9542 1151.3 2.921 9637 1159.5 2.951 9732 1167.6 2.979 9826 1175.8 3.008												
356 145.8 9535 1150.3 2.955 9629 1158.4 2.984 9724 1166.6 3.012 9818 1174.7 3.042												
355 143.9 9526 1149.3 2.988 9621 1157.4 3.018 9715 1165.6 3.047 9809 1173.7 3.076												
354 142.1 9518 1148.3 3.022 9612 1156.4 3.052 9706 1164.6 3.081 9801 1172.7 3.111												
353 140.3 9511 1147.3 3.055 9605 1155.4 3.086 9699 1163.5 3.115 9793 1171.7 3.145												
352 138.5 9503 1146.2 3.090 9597 1154.3 3.121 9690 1162.5 3.150 9784 1170.6 3.181												
351 136.7 9495 1145.2 3.125 9588 1153.3 3.155 9682 1161.4 3.186 9775 1169.5 3.217												
350 135.0 9487 1144.2 3.160 9581 1152.3 3.191 9674 1160.4 3.222 9767 1168.5 3.253												
349 133.2 9479 1143.2 3.195 9572 1151.3 3.228 9665 1159.3 3.259 9758 1167.4 3.290												
348 131.5 9471 1142.2 3.233 9564 1150.3 3.265 9657 1158.3 3.297 9750 1166.4 3.328												
347 129.8 9465 1141.2 3.271 9556 1149.3 3.303 9659 1157.3 3.335 9742 1165.4 3.366												
346 128.1 9456 1140.2 3.308 9548 1148.2 3.340 9641 1156.2 3.372 9733 1164.3 3.404												
345 126.4 9448 1139.1 3.346 9540 1147.2 3.378 9633 1155.2 3.411 9725 1163.2 3.443												
344 124.8 9441 1138.1 3.384 9533 1146.2 3.417 9625 1154.2 3.451 9717 1162.2 3.483												
343 123.2 9432 1137.1 3.424 9524 1145.1 3.457 9616 1153.1 3.491 9708 1161.1 3.523												
342 121.5 9425 1136.1 3.464 9516 1144.1 3.497 9608 1152.1 3.531 9700 1160.1 3.564												
341 119.9 9418 1135.0 3.504 9509 1143.0 3.538 9601 1151.0 3.572 9692 1159.0 3.605												
340 118.4 9410 1134.0 3.545 9501 1142.0 3.579 9593 1150.0 3.614 9684 1158.0 3.647												
339 116.8 9403 1133.0 3.586 9494 1140.9 3.621 9585 1148.9 3.656 9676 1156.9 3.691												
338 115.2 9394 1131.9 3.628 9485 1139.9 3.663 9576 1147.9 3.698 9667 1155.8 3.733												
337 113.7 9387 1130.9 3.671 9477 1138.8 3.707 9568 1146.8 3.742 9659 1154.8 3.778												
336 112.2 9378 1129.8 3.715 9469 1137.8 3.751 9559 1145.7 3.787 9650 1153.7 3.822												
335 110.7 9371 1128.8 3.759 9461 1136.8 3.795 9552 1144.7 3.831 9642 1152.6 3.867												
334 109.2 9363 1127.8 3.803 9453 1135.8 3.840 9544 1143.7 3.877 9634 1151.6 3.913												
333 107.7 9355 1126.7 3.849 9445 1134.7 3.886 9535 1142.6 3.923 9625 1150.5 3.960												
332 106.3 9347 1125.7 3.894 9437 1133.6 3.931 9527 1141.5 3.969 9617 1149.4 4.006												
331 104.8 9339 1124.7 3.941 9429 1132.6 3.979 9519 1140.5 4.017 9609 1148.4 4.055												
330 103.4 9332 1123.7 3.988 9421 1131.5 4.027 9511 1139.4 4.065 9600 1147.3 4.103												
329 102.0 9323 1122.6 4.037 9413 1130.5 4.076 9502 1138.4 4.114 9591 1146.2 4.153												
328 100.6 9317 1121.6 4.086 9406 1129.5 4.125 9495 1137.4 4.164 9584 1145.2 4.204												
327 99.2 9309 1120.5 4.136 9398 1128.4 4.176 9487 1136.3 4.215 9575 1144.1 4.255												
326 97.8 9300 1119.5 4.185 9389 1127.3 4.225 9478 1135.2 4.265 9566 1143.0 4.305												
325 96.5 9293 1118.4 4.237 9381 1126.3 4.277 9470 1134.1 4.317 9558 1142.0 4.358												

TEMPERATURE-ENTROPY TABLE

79

Temperature Degrees Fahr. Temperature Degrees Rankine	Pressure, Pounds per Square Inch	1.56			1.57			1.58			1.59		
		Quality	Heat Con- tents	Specific Volume.									
372	177.9	7	1200	2.546	21	1205	2.654	35	1217	2.724	50	1225	2.790
371	175.7	5	1198	2.620	19	1207	2.680	34	1216	2.751	49	1224	2.817
370	173.6	4	1197	2.646	18	1206	2.700	33	1215	2.778	47	1223	2.842
369	171.5	3	1196	2.672	17	1205	2.732	32	1214	2.802	46	1222	2.870
368	169.4	2	1195	2.700	16	1204	2.760	30	1213	2.831	45	1221	2.898
367	167.3	1	1194	2.725	14	1203	2.780	29	1212	2.859	43	1219	2.925
366	165.3	9997	1193	3.2 752	13	1202	2.814	28	1211	2.886	42	1218	2.953
365	163.2	9988	1192	3.2 782	12	1201	2.842	26	1209	2.913	41	1217	2.982
364	161.2	9979	1191	2.2 812	11	1200	2.870	25	1208	2.941	39	1216	3.011
363	159.2	9971	1190	2.2 843	10	1199	2.899	24	1207	2.970	38	1215	3.042
362	157.2	9963	1189	2.2 874	8	1198	2.928	23	1206	2.999	37	1214	3.070
361	155.3	9955	1188	2.2 906	7	1197	2.957	21	1205	3.027	35	1213	3.100
360	153.3	9946	1187	1.2 938	6	1196	2.986	20	1204	3.055	34	1212	3.129
359	151.4	9938	1186	1.2 971	5	1195	3.017	19	1203	3.086	33	1211	3.160
358	149.5	9929	1185	0.3 004	3	1193	3.047	17	1202	3.118	31	1209	3.192
357	147.6	9921	1183	9.3 037	2	1192	3.079	16	1201	3.149	30	1208	3.222
356	145.8	9913	1182	9.3 070	1	1191	3.108	15	1200	3.181	29	1207	3.253
355	143.9	9904	1181	9.3 105	9998	1190	0.3 135	13	1198	3.211	27	1206	3.286
354	142.1	9895	1180	8.3 141	9989	1189	0.3 170	12	1197	3.243	26	1205	3.319
353	140.3	9887	1179	8.3 176	9980	1187	0.3 206	11	1196	3.275	25	1204	3.350
352	138.5	9878	1178	7.3 211	9971	1186	0.3 242	10	1195	3.308	23	1203	3.383
351	136.7	9860	1177	6.3 247	9962	1185	7.3 278	8	1194	3.342	22	1202	3.417
350	135.0	9851	1176	6.3 294	9954	1184	7.3 315	7	1193	3.377	21	1201	3.450
349	133.2	9851	1175	5.3 321	9945	1183	6.3 352	6	1192	3.411	19	1199	3.487
348	131.5	9843	1174	5.3 359	9936	1182	6.3 391	4	1190	3.447	18	1198	3.524
347	129.8	9835	1173	5.3 398	9928	1181	6.3 430	3	1189	3.481	17	1197	3.560
346	128.1	9826	1172	4.3 436	9919	1180	5.3 468	2	1188	3.518	15	1196	3.595
345	126.4	9817	1171	3.3 475	9910	1179	4.3 508	0	1187	3.552	14	1195	3.632
344	124.8	9809	1170	3.3 516	9901	1178	3.3 549	9994	1186	3.582	13	1194	3.671
343	123.2	9800	1169	2.3 556	9892	1177	2.3 590	9984	1185	2.3 623	11	1193	3.710
342	121.5	9792	1168	1.3 597	9884	1176	1.3 631	9975	1184	1.3 665	10	1192	3.750
341	119.9	9785	1167	1.3 639	9876	1175	1.3 673	9968	1183	0.3 707	9	1191	3.790
340	118.4	9776	1166	0.3 681	9867	1174	0.3 716	9955	1182	0.3 750	7	1189	3.830
339	116.8	9767	1164	9.3 724	9859	1172	9.3 759	9950	1180	9.3 794	6	1188	3.870
338	115.2	9758	1163	8.3 768	9849	1171	8.3 803	9940	1179	8.3 838	5	1187	3.910
337	113.7	9750	1162	7.3 812	9841	1170	7.3 848	9932	1178	7.3 883	3	1186	3.955
336	112.2	9741	1161	6.3 857	9831	1169	6.3 893	9922	1177	6.3 929	2	1185	3.995
335	110.7	9732	1160	6.3 903	9823	1168	5.3 939	9913	1176	5.3 975	1	1184	4.035
334	109.2	9724	1159	6.3 949	9814	1167	5.3 986	9904	1175	4.4 022	9995	1183	4.4 059
333	107.7	9715	1158	5.3 996	9805	1166	4.4 033	9895	1174	3.4 070	9985	1182	3.4 107
332	106.3	9707	1157	4.4 043	9796	1165	3.4 080	9886	1173	2.4 118	9976	1181	2.4 155
331	104.8	9698	1156	3.4 092	9788	1164	2.4 130	9878	1172	1.4 167	9967	1180	0.4 205
330	103.4	9690	1155	2.4 140	9779	1163	1.4 179	9869	1171	0.4 217	9958	1178	9.4 255
329	102.0	9680	1154	1.4 192	9770	1162	1.4 229	9859	1170	0.4 268	9949	1177	8.4 207
328	100.6	9673	1153	1.4 243	9762	1161	0.4 281	9851	1168	9.4 320	9940	1176	7.4 339
327	99.2	9665	1152	0.4 294	9754	1159	9.4 333	9843	1167	8.4 372	9932	1175	6.4 412
326	97.8	9655	1150	9.4 346	9744	1158	8.4 384	9833	1166	6.4 424	9921	1174	5.4 463
325	96.5	9647	1149	8.4 398	9735	1157	7.4 437	9824	1165	5.4 478	9913	1173	4.4 518

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	1.52			1.53			1.54			1.55		
		Quality.	Heat Con- tents.	Specific Volume	Quality.	Heat Con- tents.	Specific Volume	Quality.	Heat Con- tents.	Specific Volume	Quality.	Heat Con- tents.	Specific Volume
324 95.1	9284	1117.3 4.288	9372	1125.2 4.329	9461	1133.0 4.370	9549	1140.8 4.411					
323 93.8	9276	1116.3 4.340	9364	1124.1 4.382	9452	1131.9 4.423	9541	1139.8 4.464					
322 92.5	9268	1115.2 4.395	9356	1123.1 4.437	9444	1130.9 4.479	9532	1138.7 4.520					
321 91.2	9262	1114.2 4.449	9349	1122.0 4.492	9437	1129.8 4.534	9525	1137.6 4.576					
320 90.0	9255	1113.2 4.595	9342	1121.0 4.548	9430	1128.8 4.591	9518	1136.6 4.633					
319 88.7	9246	1112.1 4.560	9333	1119.9 4.603	9421	1127.7 4.646	9508	1135.5 4.690					
318 87.4	9238	1111.1 4.617	9325	1118.8 4.661	9413	1126.6 4.705	9500	1134.4 4.748					
317 86.2	9230	1110.0 4.675	9317	1117.8 4.719	9405	1125.5 4.763	9492	1133.3 4.808					
316 85.0	9222	1108.9 4.733	9308	1116.6 4.778	9395	1124.4 4.823	9482	1132.1 4.867					
315 83.8	9215	1107.9 4.793	9301	1115.6 4.839	9388	1123.4 4.884	9475	1131.1 4.929					
314 82.6	9207	1106.8 4.855	9293	1114.6 4.900	9380	1122.3 4.946	9466	1130.0 4.992					
313 81.4	9199	1105.8 4.916	9285	1113.5 4.962	9372	1121.2 5.008	9458	1128.9 5.054					
312 80.2	9191	1104.7 4.979	9277	1112.4 5.025	9363	1120.1 5.072	9449	1127.8 5.119					
311 79.1	9183	1103.6 5.042	9269	1111.3 5.090	9355	1119.0 5.137	9441	1126.7 5.184					
310 77.9	9175	1102.5 5.106	9261	1110.2 5.154	9347	1117.9 5.201	9432	1125.6 5.249					
309 76.8	9167	1101.5 5.171	9253	1109.2 5.220	9338	1116.8 5.268	9424	1124.5 5.317					
308 75.7	9159	1100.4 5.238	9244	1108.1 5.287	9330	1115.7 5.336	9415	1123.4 5.385					
307 74.6	9151	1099.3 5.307	9236	1107.0 5.356	9322	1114.6 5.406	9407	1122.3 5.455					
306 73.5	9144	1098.3 5.376	9229	1106.0 5.426	9314	1113.6 5.476	9399	1121.3 5.526					
305 72.4	9135	1097.1 5.444	9220	1104.8 5.495	9305	1112.4 5.546	9390	1120.1 5.596					
304 71.4	9127	1096.0 5.515	9211	1103.7 5.567	9296	1111.3 5.618	9381	1118.9 5.669					
303 70.3	9120	1095.0 5.588	9204	1102.7 5.639	9289	1110.3 5.691	9373	1117.9 5.743					
302 69.3	9111	1093.9 5.662	9196	1101.6 5.714	9280	1109.2 5.767	9365	1116.8 5.819					
301 68.2	9104	1092.8 5.737	9188	1100.4 5.790	9273	1108.0 5.843	9357	1115.6 5.896					
300 67.2	9096	1091.7 5.812	9180	1099.3 5.865	9264	1106.9 5.918	9348	1114.5 6.973					
299 66.2	9089	1090.7 5.890	9173	1098.3 5.944	9257	1105.9 5.998	9341	1113.5 6.053					
298 65.2	9081	1089.6 5.968	9164	1097.2 6.023	9248	1104.8 6.078	9332	1112.3 6.433					
297 64.3	9072	1088.5 6.048	9156	1096.1 6.102	9240	1103.7 6.159	9323	1111.2 6.215					
296 63.3	9064	1087.4 6.128	9148	1095.0 6.185	9231	1102.5 6.241	9314	1110.0 6.297					
295 62.3	9057	1086.3 6.212	9140	1093.9 6.268	9223	1101.4 6.325	9306	1108.9 6.382					
294 61.4	9049	1085.2 6.296	9132	1092.8 6.353	9215	1100.3 6.411	9298	1107.8 6.469					
293 60.5	9041	1084.1 6.382	9124	1091.7 6.439	9207	1099.2 6.498	9290	1106.7 6.556					
292 59.5	9033	1083.1 6.469	9116	1090.6 6.527	9198	1098.1 6.586	9281	1105.6 6.645					
291 58.6	9026	1082.0 6.556	9108	1089.5 6.615	9191	1097.0 6.675	9273	1104.5 6.735					
290 57.7	9017	1080.9 6.645	9100	1088.4 6.705	9182	1095.9 6.765	9264	1103.4 6.826					
289 56.8	9010	1079.8 6.737	9092	1087.3 6.797	9174	1094.8 6.859	9256	1102.2 6.920					
288 56.0	9001	1078.7 6.830	9083	1086.2 6.891	9165	1093.6 6.953	9246	1101.1 7.015					
287 55.1	8993	1077.6 6.924	9075	1085.1 6.986	9157	1092.5 7.049	9238	1100.0 7.112					
286 54.2	8986	1076.5 7.020	9067	1084.0 7.083	9149	1091.4 7.146	9230	1098.9 7.210					
285 53.4	8978	1075.4 7.118	9060	1082.9 7.188	9141	1090.3 7.246	9222	1097.7 7.311					
284 52.6	8969	1074.3 7.216	9050	1081.7 7.281	9131	1089.1 7.345	9213	1096.5 7.411					
283 51.7	8961	1073.2 7.316	9042	1080.6 7.382	9123	1088.0 7.447	9204	1095.4 7.514					
282 50.9	8954	1072.1 7.420	9035	1079.5 7.487	9115	1086.9 7.553	9196	1094.3 7.620					
281 50.1	8947	1071.0 7.526	9028	1078.4 7.594	9109	1085.8 7.661	9189	1093.2 7.729					
280 49.33	8939	1069.9 7.633	9020	1077.3 7.701	9101	1084.7 7.769	9181	1092.1 7.838					
279 48.55	8930	1068.8 7.739	9010	1076.2 7.809	9091	1083.6 7.877	9171	1090.9 7.947					
278 47.77	8922	1067.6 7.850	9003	1075.0 7.921	9083	1082.4 7.990	9163	1089.7 8.061					
277 47.01	8915	1066.5 7.963	8995	1073.9 8.034	9075	1081.3 8.104	9155	1088.6 8.176					

TEMPERATURE-ENTROPY TABLE

81

Temperature Degrees F. air	Pressure, Pounds per Square Inch.	1.56			1.57			1.58			1.59		
		Quality	Heat Cap- tents	Specific Volume									
324 95.1	9637	1148.7	4.452	9726	1156.5	4.491	9814	1164.3	4.532	9903	1172.2	4.573	
323 93.8	9629	1147.6	4.503	9717	1155.4	4.546	9805	1163.2	4.587	9893	1171.1	4.626	
322 92.5	9620	1146.5	4.562	9708	1154.3	4.603	9796	1162.1	4.645	9885	1169.9	4.686	
321 91.2	9613	1145.4	4.618	9701	1153.2	4.659	9889	1161.0	4.702	9877	1168.8	4.744	
320 90.0	9605	1144.4	4.676	9693	1152.2	4.718	9781	1160.0	4.760	9868	1167.8	4.803	
319 88.0	9596	1143.2	4.733	9683	1151.0	4.776	9770	1158.8	4.818	9858	1166.6	4.861	
318 87.4	9587	1142.2	4.792	9675	1149.9	4.835	9762	1157.7	4.878	9849	1165.5	4.922	
317 86.2	9579	1141.0	4.852	9666	1148.8	4.886	9753	1156.6	4.939	9840	1164.4	4.983	
316 85.0	9569	1139.9	4.912	9656	1147.6	4.957	9743	1155.4	5.000	9830	1163.1	5.045	
315 83.8	9562	1138.9	4.974	9648	1146.6	5.019	9735	1154.3	5.053	9822	1162.1	5.108	
314 82.6	9553	1137.8	5.037	9640	1145.5	5.063	9726	1153.2	5.128	9813	1161.0	5.173	
313 81.4	9544	1136.7	5.101	9631	1144.4	5.147	9717	1152.1	5.192	9804	1159.8	5.238	
312 82.2	9536	1135.5	5.165	9622	1143.2	5.212	9708	1151.0	5.258	9794	1158.7	5.305	
311 79.1	9527	1134.4	5.231	9613	1142.1	5.279	9699	1149.8	5.325	9785	1157.5	5.372	
310 77.9	9518	1133.3	5.297	9604	1141.0	5.345	9690	1148.7	5.391	9776	1156.4	5.439	
309 76.8	9510	1132.2	5.364	9595	1139.9	5.413	9681	1147.6	5.461	9767	1155.3	5.508	
308 75.7	9501	1131.1	5.434	9588	1138.8	5.482	9672	1146.4	5.531	9757	1154.1	5.579	
307 74.6	9492	1130.0	5.505	9577	1137.6	5.554	9663	1145.3	5.603	9748	1153.0	5.652	
306 73.5	9484	1128.9	5.576	9569	1136.6	5.626	9655	1144.2	5.676	9740	1151.9	5.725	
305 72.4	9474	1127.7	5.647	9559	1135.3	5.697	9644	1143.0	5.748	9729	1150.8	5.798	
304 71.4	9466	1126.6	5.720	9551	1134.2	5.771	9635	1141.8	5.823	9720	1149.5	5.873	
303 70.3	9458	1125.5	5.795	9542	1133.2	5.847	9627	1140.8	5.899	9712	1148.4	5.949	
302 69.3	9449	1124.4	5.872	9534	1132.0	5.924	9618	1139.5	5.977	9702	1147.2	6.028	
301 68.2	9441	1123.2	5.949	9525	1130.8	6.002	9610	1138.5	6.055	9694	1145.1	6.107	
300 67.2	9432	1122.1	6.026	9516	1129.7	6.080	9600	1137.3	6.134	9685	1144.9	6.187	
299 66.2	9424	1121.1	6.107	9508	1128.6	6.161	9592	1136.2	6.216	9676	1143.8	6.279	
298 65.2	9416	1119.9	6.188	9499	1127.5	6.243	9583	1135.0	6.298	9667	1142.6	6.353	
297 64.3	9407	1118.8	6.270	9490	1126.4	6.326	9574	1133.9	6.382	9657	1141.5	6.477	
296 63.3	9398	1117.6	6.353	9481	1125.2	6.410	9564	1132.7	6.466	9648	1140.3	6.523	
295 62.3	9390	1116.5	6.439	9473	1124.1	6.497	9556	1131.6	6.554	9639	1139.1	6.611	
294 61.4	9381	1115.4	6.526	9464	1122.9	6.584	9547	1130.5	6.642	9630	1138.0	6.696	
293 60.5	9373	1114.3	6.614	9456	1121.8	6.673	9538	1129.4	6.731	9621	1136.9	6.790	
292 59.5	9364	1113.1	6.704	9446	1120.6	6.764	9529	1128.2	6.823	9611	1135.7	6.880	
291 58.6	9355	1112.0	6.795	9438	1119.5	6.855	9520	1127.1	6.915	9603	1134.6	6.975	
290 57.7	9347	1110.9	6.887	9429	1118.4	6.947	9511	1125.9	7.008	9593	1133.4	7.068	
289 56.8	9338	1109.7	6.981	9421	1117.2	7.043	9503	1124.7	7.104	9585	1132.2	7.166	
288 56.0	9328	1108.5	7.078	9410	1116.0	7.140	9492	1123.5	7.202	9574	1131.0	7.264	
287 55.1	9320	1107.4	7.175	9402	1114.9	7.238	9484	1122.4	7.301	9566	1129.9	7.364	
286 54.2	9312	1106.3	7.274	9394	1113.8	7.337	9475	1121.2	7.401	9557	1128.7	7.465	
285 53.4	9304	1105.2	7.375	9385	1112.6	7.440	9467	1120.0	7.504	9548	1127.5	7.569	
284 52.6	9294	1104.0	7.476	9375	1111.4	7.541	9456	1118.9	7.607	9537	1126.3	7.672	
283 51.7	9286	1102.9	7.580	9367	1110.3	7.646	9448	1117.7	7.712	9529	1125.2	7.778	
282 50.9	9277	1101.8	7.687	9358	1109.2	7.754	9439	1116.6	7.821	9520	1124.0	7.888	
281 50.1	9270	1100.7	7.797	9351	1108.1	7.865	9431	1115.5	7.933	9512	1123.9	8.001	
280 49.33	9262	1099.5	7.907	9342	1106.9	7.976	9423	1114.3	8.044	9503	1121.7	8.113	
279 48.55	9252	1098.2	8.017	9332	1105.7	8.086	9412	1113.1	8.156	9493	1120.5	8.225	
278 47.77	9243	1097.1	8.131	9323	1104.5	8.211	9404	1111.9	8.272	9484	1119.3	8.343	
277 47.01	9235	1096.0	8.248	9315	1104.3	8.319	9395	1110.7	8.390	9475	1118.0	8.462	

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	1.52				1.53				1.54				1.55			
		Quality.	Heat Con- tents.	Specific Volume.													
276	46.26	8907	1065.4	8.077	8987	1072.8	8.149	9067	1080.2	8.221	9147	1087.5	8.293				
275	45.52	8898	1064.3	8.192	8978	1071.7	8.265	9058	1079.0	8.339	9137	1086.4	8.411				
274	44.78	8891	1063.2	8.310	8970	1070.5	8.385	9050	1077.8	8.450	9129	1085.2	8.532				
273	44.06	8883	1062.1	8.431	8962	1069.4	8.506	9042	1076.7	8.582	9121	1084.1	8.656				
272	43.35	8875	1061.0	8.555	8954	1068.3	8.631	9033	1075.6	8.708	9113	1082.9	8.783				
271	42.64	8867	1059.9	8.679	8946	1067.2	8.756	9025	1074.5	8.833	9104	1081.8	8.910				
270	41.95	8859	1058.7	8.805	8937	1066.0	8.883	9016	1073.3	8.961	9095	1080.6	9.039				
269	41.26	8851	1057.6	8.932	8929	1064.9	9.012	9008	1072.2	9.091	9087	1079.5	9.170				
268	40.58	8843	1056.5	9.066	8921	1063.8	9.146	9000	1071.0	9.227	9078	1078.3	9.306				
267	39.91	8835	1055.4	9.199	8913	1062.6	9.281	8992	1069.9	9.362	9070	1077.1	9.443				
266	39.26	8826	1054.2	9.331	8904	1061.4	9.414	8983	1068.7	9.497	9061	1075.9	9.579				
265	38.60	8818	1053.1	9.473	8896	1060.3	9.557	8974	1067.6	9.640	9052	1074.8	9.724				
264	37.96	8810	1051.9	9.614	8888	1059.2	9.699	8966	1066.4	9.784	9044	1073.6	9.869				
263	37.33	8803	1050.8	9.755	8880	1058.1	9.841	8958	1065.3	9.927	9036	1072.5	10.01				
262	36.71	8795	1049.7	9.905	8872	1056.9	9.992	8950	1064.1	10.08	9027	1071.3	10.16				
261	36.09	8788	1048.6	10.05	8865	1055.8	10.14	8942	1063.0	10.23	9020	1070.2	10.32				
260	35.48	8780	1047.4	10.20	8857	1054.6	10.29	8934	1061.8	10.38	9011	1069.0	10.47				
259	34.88	8771	1046.3	10.36	8848	1053.4	10.45	8925	1060.6	10.54	9002	1067.8	10.63				
258	34.29	8763	1045.1	10.52	8839	1052.2	10.61	8916	1059.4	10.70	8993	1066.6	10.79				
257	33.71	8755	1044.0	10.67	8832	1051.1	10.77	8909	1058.3	10.86	8985	1065.5	10.95				
256	33.14	8747	1042.9	10.84	8823	1050.0	10.93	8900	1057.2	11.03	8977	1064.3	11.12				
255	32.57	8738	1041.7	11.01	8815	1048.8	11.11	8891	1056.0	11.20	8967	1063.1	11.30				
254	32.01	8730	1040.5	11.18	8806	1047.6	11.28	8883	1054.7	11.38	8959	1061.9	11.48				
253	31.46	8722	1039.4	11.36	8798	1046.5	11.46	8874	1053.6	11.55	8950	1060.8	11.65				
252	30.92	8714	1038.2	11.54	8791	1045.4	11.64	8866	1052.5	11.74	8942	1059.6	11.84				
251	30.38	8707	1037.1	11.72	8782	1044.2	11.82	8858	1051.3	11.92	8934	1058.4	12.02				
250	29.86	8698	1035.9	11.90	8774	1043.0	12.00	8849	1050.1	12.11	8925	1057.2	12.21				
249	29.34	8690	1034.8	12.09	8765	1041.9	12.19	8841	1048.9	12.30	8916	1056.0	12.40				
248	28.82	8682	1033.6	12.27	8757	1040.7	12.38	8832	1047.7	12.49	8907	1054.8	12.59				
247	28.32	8674	1032.5	12.47	8749	1039.6	12.57	8825	1046.6	12.68	8900	1053.7	12.79				
246	27.82	8666	1031.3	12.66	8741	1038.4	12.77	8816	1045.4	12.88	8891	1052.5	12.99				
245	27.33	8658	1030.2	12.85	8733	1037.3	12.96	8807	1044.3	13.09	8882	1051.3	13.18				
244	26.85	8650	1029.0	13.07	8725	1036.1	13.18	8800	1043.1	13.30	8874	1050.1	13.41				
243	26.37	8642	1027.9	13.28	8717	1035.0	13.40	8791	1042.0	13.51	8865	1049.0	13.63				
242	25.90	8635	1026.8	13.50	8709	1033.8	13.61	8783	1040.8	13.73	8857	1047.8	13.84				
241	25.44	8626	1025.6	13.72	8700	1032.6	13.83	8774	1039.6	13.95	8848	1046.6	14.07				
240	24.98	8619	1024.4	13.94	8693	1031.4	14.06	8766	1038.3	14.18	8840	1045.3	14.29				
239	24.53	8610	1023.2	14.16	8684	1030.2	14.29	8758	1037.2	14.41	8832	1044.2	14.53				
238	24.09	8603	1022.0	14.40	8676	1029.0	14.52	8750	1036.0	14.65	8823	1043.0	14.77				
237	23.66	8594	1020.9	14.64	8668	1027.9	14.76	8741	1034.8	14.89	8815	1041.8	15.01				
236	23.23	8587	1019.7	14.88	8660	1026.7	15.01	8733	1033.6	15.13	8806	1040.6	15.26				
235	22.80	8578	1018.5	15.12	8651	1025.5	15.25	8724	1032.4	15.38	8797	1039.4	15.51				
234	22.39	8570	1017.3	15.37	8642	1024.2	15.50	8715	1031.2	15.64	8788	1038.1	15.77				
233	21.98	8562	1016.1	15.63	8635	1023.1	15.77	8707	1030.0	15.90	8780	1036.9	16.03				
232	21.57	8553	1014.9	15.89	8626	1021.9	16.03	8699	1028.8	16.16	8771	1035.7	16.30				
231	21.18	8546	1013.8	16.16	8618	1020.8	16.30	8690	1027.7	16.43	8763	1034.5	16.57				
230	20.78	8538	1012.7	16.43	8610	1019.6	16.57	8682	1026.5	16.70	8755	1033.3	16.84				
229	20.40	8529	1011.4	16.70	8601	1018.3	16.84	8674	1025.2	16.98	8746	1032.1	17.12				

TEMPERATURE-ENTROPY TABLE

83

Temperature, Degrees Fahr. [See Square inch]	Pressure Points [See Square inch]	1.56			1.57			1.58			1.59		
		Quality	Heat Con- tents	Specific Volume									
276 46.26	9226	1094.9	8.356	9306	1102.2	8.438	9386	1109.6	8.518	9466	1116.9	8.588	
275 45.92	9217	1093.7	8.484	9297	1101.1	8.558	9377	1108.4	8.631	9456	1115.7	8.704	
274 44.78	9209	1092.5	8.607	9288	1099.9	8.681	9368	1107.2	8.755	9447	1114.5	8.825	
273 44.06	9200	1091.4	8.731	9280	1098.8	8.806	9359	1106.1	8.882	9438	1113.4	8.957	
272 43.35	9192	1090.3	8.859	9271	1097.6	8.935	9350	1104.9	9.012	9429	1112.2	9.088	
271 42.64	9183	1089.1	8.987	9262	1096.4	9.064	9341	1103.7	9.142	9420	1111.0	9.216	
270 41.95	9174	1087.9	9.117	9253	1095.2	9.196	9332	1102.5	9.274	9410	1109.8	9.352	
269 41.26	9165	1086.8	9.249	9244	1094.1	9.328	9323	1101.3	9.406	9401	1106.6	9.487	
268 40.58	9157	1085.6	9.387	9235	1092.9	9.467	9314	1100.1	9.548	9392	1107.4	9.628	
267 39.91	9148	1084.4	9.525	9227	1091.7	9.606	9305	1098.9	9.688	9383	1106.2	9.766	
266 39.26	9139	1083.2	9.661	9217	1090.4	9.743	9295	1097.7	9.826	9373	1104.9	9.894	
265 38.60	9130	1082.1	9.807	9208	1089.3	9.891	9286	1096.5	9.975	9364	1103.8	10.06	
264 37.96	9122	1080.9	9.953	9200	1088.1	10.04	9277	1095.3	10.12	9355	1102.6	10.21	
263 37.33	9113	1079.7	10.10	9191	1087.0	10.18	9269	1094.2	10.27	9346	1101.4	10.36	
262 36.71	9105	1078.5	10.25	9182	1085.8	10.34	9260	1093.9	10.43	9337	1100.2	10.51	
261 36.09	9097	1077.4	10.41	9174	1084.6	10.50	9252	1091.8	10.58	9329	1099.0	10.67	
260 35.48	9088	1076.2	10.56	9165	1083.4	10.65	9243	1090.6	10.74	9320	1097.8	10.83	
259 34.88	9079	1075.0	10.72	9156	1082.2	10.81	9233	1089.4	10.90	9310	1096.6	10.99	
258 34.29	9070	1073.8	10.88	9147	1080.9	10.98	9224	1088.1	11.07	9301	1095.3	11.16	
257 33.71	9062	1072.7	11.05	9139	1079.5	11.14	9215	1087.9	11.23	9292	1094.1	11.33	
256 33.14	9053	1071.5	11.22	9130	1078.6	11.31	9206	1085.8	11.41	9283	1092.9	11.50	
255 32.57	9044	1070.3	11.39	9120	1077.4	11.49	9196	1084.6	11.59	9273	1091.7	11.68	
254 32.01	9035	1069.0	11.57	9111	1076.1	11.67	9187	1083.3	11.77	9263	1090.4	11.87	
253 31.46	9026	1067.9	11.75	9102	1075.0	11.85	9178	1082.1	11.95	9254	1089.2	12.05	
252 30.92	9018	1066.7	11.94	9094	1073.8	12.04	9170	1080.9	12.14	9246	1088.0	12.24	
251 30.38	9009	1065.5	12.13	9085	1072.6	12.23	9161	1079.7	12.33	9236	1086.8	12.43	
250 29.86	9001	1064.3	12.31	9076	1071.4	12.42	9152	1078.5	12.52	9227	1085.6	12.62	
249 29.34	8992	1063.1	12.51	9067	1070.2	12.61	9142	1077.3	12.72	9218	1084.4	12.82	
248 28.82	8983	1061.9	12.70	9058	1069.0	12.81	9133	1076.0	12.91	9208	1083.1	13.02	
247 28.32	8975	1060.7	12.90	9050	1067.8	13.01	9125	1074.8	13.11	9200	1081.9	13.22	
246 27.82	8966	1059.5	13.10	9041	1066.6	13.21	9115	1073.6	13.32	9190	1080.7	13.43	
245 27.33	8957	1058.4	13.29	9031	1065.4	13.41	9106	1072.5	13.52	9181	1079.5	13.63	
244 26.85	8949	1057.2	13.52	9023	1064.2	13.63	9098	1071.3	13.75	9172	1078.3	13.86	
243 26.37	8940	1056.0	13.74	9014	1063.0	13.85	9088	1070.1	13.97	9163	1077.1	14.08	
242 25.90	8931	1054.8	13.96	9006	1061.8	14.08	9080	1068.5	14.19	9154	1075.9	14.31	
241 25.44	8923	1052.6	14.19	8997	1060.6	14.30	9071	1067.6	14.42	9145	1074.6	14.54	
240 24.98	8914	1052.3	14.41	8988	1059.3	14.53	9062	1066.3	14.65	9136	1073.3	14.77	
239 24.53	8905	1051.1	14.65	8979	1058.1	14.77	9053	1065.1	14.89	9127	1072.1	15.01	
238 24.09	8897	1049.9	14.89	8971	1056.9	15.02	9044	1053.9	15.14	9118	1070.9	15.26	
237 23.66	8888	1048.7	15.14	8961	1055.7	15.26	9035	1062.7	15.39	9108	1069.7	15.51	
236 23.23	8880	1047.5	15.39	8953	1054.5	15.52	9026	1061.5	15.64	9099	1068.4	15.77	
235 22.80	8871	1046.3	15.64	8944	1053.3	15.77	9017	1060.2	15.90	9090	1067.1	16.03	
234 22.39	8861	1045.0	15.90	8934	1052.0	16.03	9007	1058.9	16.16	9080	1065.8	16.29	
233 21.95	8853	1043.8	16.17	8926	1050.8	16.30	8998	1057.7	16.43	9071	1064.6	16.56	
232 21.57	8844	1042.6	16.43	8916	1049.5	16.57	8989	1056.4	16.70	9062	1063.3	16.84	
231 21.18	8835	1041.4	16.71	8908	1048.3	16.84	8980	1055.2	16.98	9053	1062.1	17.12	
230 20.75	8827	1040.2	16.98	8899	1047.1	17.12	8972	1054.0	17.26	9044	1060.9	17.40	
229 20.40	8818	1039.0	17.27	8890	1045.9	17.41	8962	1052.8	17.55	9034	1059.6	17.69	

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr. 1.52	Pressure, Pounds per Square Inch.	1.52				1.53				1.54				1.55.			
		Quality.	Heat Con- tents.	Specific Volume.													
228	20.02	8521	1010.2	16.98	8503	1017.1	17.13	8665	1024.0	17.27	8737	1030.8	17.41				
227	19.64	8513	1009.1	17.27	8584	1015.9	17.42	8656	1022.8	17.56	8728	1029.6	17.71				
226	19.28	8505	1007.9	17.58	8576	1014.7	17.73	8648	1021.6	17.88	8720	1028.4	18.02				
225	18.91	8496	1006.7	17.88	8568	1013.5	18.03	8639	1020.4	18.18	8711	1027.2	18.33				
224	18.56	8488	1005.5	18.18	8560	1012.3	18.33	8631	1019.2	18.49	8702	1026.0	18.64				
223	18.21	8480	1004.4	18.50	8552	1011.2	18.65	8623	1018.0	18.81	8694	1024.8	18.96				
222	17.86	8472	1003.2	18.81	8543	1010.0	18.97	8614	1016.8	19.12	8686	1023.6	19.28				
221	17.52	8465	1002.0	19.14	8536	1008.8	19.30	8607	1015.6	19.46	8678	1022.4	19.62				
220	17.19	8457	1000.8	19.48	8528	1007.6	19.64	8599	1014.4	19.80	8670	1021.2	19.97				
219	16.86	8449	999.6	19.82	8519	1006.4	19.99	8590	1013.1	20.15	8660	1019.9	20.32				
218	16.53	8440	998.3	20.17	8510	1005.1	20.34	8581	1011.8	20.51	8651	1018.6	20.68				
217	16.21	8432	997.1	20.52	8502	1003.9	20.69	8572	1010.6	20.86	8642	1017.4	21.04				
216	15.90	8424	995.9	20.88	8494	1002.7	21.06	8564	1009.4	21.23	8634	1016.2	21.40				
215	15.59	8416	994.7	21.25	8485	1001.5	21.43	8555	1008.2	21.60	8625	1015.0	21.78				
214	15.29	8407	993.5	21.63	8477	1000.3	21.81	8547	1007.0	21.99	8617	1013.7	22.17				
213	14.99	8399	992.3	22.01	8469	999.1	22.20	8539	1005.8	22.38	8608	1012.5	22.56				
212	14.70	8391	991.1	22.37	8461	997.9	22.56	8530	1004.6	22.74	8600	1011.3	22.93				
211	14.41	8383	989.9	22.73	8452	996.7	22.92	8522	1004.4	23.10	8591	1010.1	23.29				
210	14.12	8375	988.7	23.14	8444	995.4	23.33	8513	1002.1	23.52	8582	1008.8	23.71				
209	13.84	8366	987.5	23.56	8435	994.2	23.75	8504	1000.9	23.95	8574	1007.5	24.14				
208	13.57	8358	986.3	23.99	8427	993.0	24.19	8496	999.6	24.38	8565	1006.3	24.58				
207	13.29	8350	985.1	24.43	8419	991.7	24.63	8487	998.4	24.83	8556	1005.1	25.04				
206	13.03	8342	983.8	24.88	8410	990.5	25.09	8479	997.2	25.29	8547	1003.8	25.50				
205	12.77	8333	982.6	25.33	8402	989.3	25.54	8470	995.9	25.75	8539	1002.6	25.96				
204	12.51	8325	981.4	25.80	8393	988.0	26.01	8462	994.7	26.22	8530	1001.3	26.43				
203	12.25	8317	980.2	26.27	8385	986.8	26.49	8453	993.4	26.70	8521	1000.1	26.92				
202	12.01	8309	979.0	26.76	8377	985.6	26.97	8445	992.2	27.19	8513	998.9	27.41				
201	11.76	8302	977.8	27.26	8369	984.4	27.49	8437	991.0	27.71	8505	997.6	27.93				
200	11.52	8293	976.5	27.77	8361	983.1	27.99	8429	989.7	28.22	8496	996.3	28.45				
199	11.28	8285	975.3	28.28	8352	981.9	28.52	8420	988.5	28.75	8487	995.1	28.98				
198	11.05	8277	974.1	28.81	8345	980.7	29.05	8412	987.3	29.28	8479	993.9	29.52				
197	10.82	8268	972.8	29.35	8335	979.4	29.59	8402	985.9	29.83	8470	992.5	30.07				
196	10.60	8259	971.5	29.91	8327	978.1	30.15	8394	984.7	30.39	8461	991.2	30.64				
195	10.38	8252	970.4	30.48	8319	976.9	30.73	8385	983.4	30.98	8452	990.0	31.22				
194	10.16	8243	969.1	31.06	8310	975.6	31.31	8377	982.2	31.56	8443	988.7	31.81				
193	9.95	8235	967.9	31.66	8302	974.4	31.91	8369	981.0	32.17	8435	987.5	32.42				
192	9.74	8227	966.7	32.27	8293	973.2	32.53	8360	979.7	32.79	8426	986.2	33.05				
191	9.53	8218	965.4	32.88	8285	971.9	33.15	8351	978.4	33.41	8417	984.9	33.68				
190	9.33	8210	964.2	33.52	8277	970.7	33.79	8343	977.2	34.06	8409	983.7	34.33				
189	9.13	8202	963.0	34.17	8268	969.5	34.45	8334	976.0	34.72	8400	982.4	35.00				
188	8.94	8194	961.7	34.83	8260	968.2	35.11	8326	974.7	35.39	8291	981.1	35.67				
187	8.75	8186	960.5	35.51	8252	967.0	35.80	8317	973.4	36.08	8283	979.9	36.37				
186	8.56	8177	959.2	36.21	8243	965.7	36.50	8308	972.1	36.79	8374	978.6	37.08				
185	8.37	8169	958.0	36.92	8235	964.5	37.22	8300	970.9	37.52	8365	977.4	37.81				
184	8.19	8161	956.7	37.66	8226	963.2	37.96	8291	969.6	38.26	8356	976.0	38.56				
183	8.01	8153	955.5	38.41	8218	961.9	38.71	8283	968.4	39.02	8348	974.8	39.33				
182	7.84	8144	954.3	39.17	8209	960.7	39.48	8274	967.1	39.79	8339	973.5	40.10				
181	7.67	8136	953.0	39.95	8201	959.4	40.27	8266	965.8	40.59	8331	972.4	40.90				

TEMPERATURE-ENTROPY TABLE.

85

Temperature Degrees Water [or Square Inch]	Pressure, Pounds	1.56			1.57			1.58			1.59		
		Quality	Heat Con- tent*	Specific Volume	Quality	Heat Con- tent	Specific Volume	Quality	Heat Con- tent	Specific Volume	Quality	Heat Con- tent	Specific Volume
228	20.02	8809	1037.7	17.56	8881	1044.6	17.70	8953	1051.5	17.84	9025	1058.3	17.99
227	19.64	8800	1036.5	17.86	8872	1043.4	18.00	8944	1050.3	18.15	9015	1057.1	18.29
226	19.28	8791	1035.3	18.17	8863	1042.2	18.32	8935	1049.0	18.47	9006	1055.9	18.62
225	18.91	8782	1034.1	18.48	8854	1041.0	18.63	8925	1047.8	18.78	8997	1054.6	18.93
224	18.56	8774	1032.8	18.79	8845	1039.7	18.95	8916	1045.5	19.10	8988	1053.3	19.25
223	18.21	8765	1031.6	19.12	8836	1038.5	19.27	8908	1045.3	19.43	8979	1052.1	19.56
222	17.86	8757	1030.4	19.44	8828	1037.2	19.60	8899	1044.0	19.76	8970	1050.9	19.91
221	17.52	8749	1029.2	19.78	8820	1036.0	19.94	8891	1042.8	20.10	8962	1049.7	20.26
220	17.19	8740	1028.0	20.13	8811	1034.8	20.29	8881	1041.6	20.45	8952	1048.4	20.62
219	16.86	8731	1026.7	20.48	8802	1033.5	20.65	8872	1041.3	20.81	8943	1047.1	20.98
218	16.53	8721	1025.4	20.84	8792	1032.2	21.01	8862	1039.0	21.18	8933	1045.8	21.35
217	16.21	8713	1024.2	21.21	8783	1031.0	21.38	8853	1037.7	21.55	8924	1044.5	21.72
216	15.90	8704	1022.9	21.58	8774	1029.7	21.75	8844	1036.4	21.92	8914	1043.2	22.10
215	15.59	8695	1021.7	21.96	8765	1028.5	22.13	8835	1035.2	22.31	8905	1042.9	22.49
214	15.29	8687	1020.5	22.35	8756	1027.2	22.53	8826	1033.9	22.71	8896	1040.7	22.89
213	14.99	8678	1019.3	22.74	8748	1026.0	22.93	8817	1032.7	23.11	8887	1039.4	23.29
212	14.70	8669	1018.0	23.11	8739	1024.7	23.30	8808	1031.4	23.48	8878	1038.1	23.67
211	14.41	8660	1016.8	23.48	8730	1023.5	23.67	8799	1030.2	23.86	8868	1036.9	24.04
210	14.12	8652	1015.5	23.90	8721	1022.2	24.10	8790	1028.9	24.29	8859	1035.6	24.48
209	13.84	8643	1014.2	24.34	8712	1020.9	24.53	8781	1027.6	24.73	8850	1034.3	24.92
208	13.57	8634	1013.0	24.78	8703	1019.7	24.98	8771	1026.3	25.17	8840	1033.0	25.37
207	13.29	8625	1011.7	25.24	8694	1018.4	25.44	8762	1025.1	25.64	8831	1031.7	25.84
206	13.03	8616	1010.5	25.70	8685	1017.1	25.91	8753	1023.8	26.11	8822	1030.4	26.32
205	12.77	8607	1009.2	26.17	8676	1015.9	26.37	8744	1022.5	26.58	8812	1029.1	26.79
204	12.51	8598	1007.9	26.65	8666	1014.6	26.86	8735	1021.2	27.07	8803	1027.8	27.28
203	12.25	8589	1006.7	27.13	8657	1013.3	27.35	8725	1019.9	27.56	8794	1026.6	27.78
202	12.01	8581	1005.5	27.63	8649	1012.1	27.85	8717	1018.7	28.07	8785	1025.3	28.29
201	11.76	8573	1004.2	28.15	8641	1010.8	28.38	8709	1017.4	28.60	8776	1024.0	28.82
200	11.52	8564	1002.9	28.67	8632	1009.5	28.90	8699	1016.1	29.13	8767	1022.7	29.35
199	11.28	8555	1001.7	29.21	8622	1008.2	29.44	8690	1014.8	29.67	8758	1021.4	29.90
198	11.05	8547	1000.4	29.75	8614	1007.0	29.99	8681	1013.6	30.22	8749	1020.2	30.45
197	10.82	8537	999.1	30.31	8604	1005.6	30.54	8671	1012.2	30.78	8738	1018.7	31.02
196	10.60	8528	997.8	30.88	8595	1004.3	31.12	8662	1010.9	31.36	8729	1017.4	31.61
195	10.38	8519	996.5	31.47	8586	1003.1	31.72	8653	1009.6	31.96	8720	1016.2	32.21
194	10.16	8510	995.2	32.07	8577	1001.8	32.32	8644	1008.3	32.57	8710	1014.9	32.82
193	9.95	8502	994.0	32.68	8568	1000.5	32.94	8635	1007.1	33.19	8702	1013.6	33.45
192	9.74	8493	992.7	33.31	8559	999.2	33.57	8626	1005.7	33.83	8692	1012.3	34.09
191	9.53	8483	991.4	33.94	8550	997.9	34.21	8616	1004.4	34.47	8682	1010.9	34.74
190	9.33	8475	990.2	34.60	8541	996.7	34.87	8607	1003.2	35.14	8673	1009.7	35.41
189	9.13	8466	988.9	35.27	8532	995.4	35.55	8598	1001.9	35.82	8664	1008.4	36.10
188	8.94	8457	987.6	35.95	8523	994.1	36.23	8589	1000.6	36.51	8655	1007.0	36.79
187	8.75	8449	986.4	36.65	8514	992.8	36.94	8580	999.3	37.22	8646	1005.8	37.51
186	8.56	8439	985.1	37.37	8505	991.5	37.66	8571	998.0	37.95	8636	1004.4	38.24
185	8.37	8431	983.8	38.11	8496	990.2	38.40	8562	996.7	38.70	8627	1003.1	38.99
184	8.19	8422	982.5	38.87	8487	988.9	39.17	8552	995.3	39.47	8617	1001.8	39.77
183	8.01	8413	981.2	39.63	8478	987.6	39.94	8543	994.1	40.25	8608	1000.5	40.55
182	7.84	8404	979.9	40.42	8469	986.4	40.73	8534	992.8	41.04	8599	999.2	41.35
181	7.67	8396	978.6	41.22	8460	985.0	41.54	8525	991.4	41.86	8590	997.8	42.18

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr. 1.52	Pressure, Pounds per Square Inch.	1.52			1.53			1.54			1.55		
		Quality.	Heat Con- tents.	Specific Volume.									
180 7.50	8128	951.7	40.75	8192	958.1	41.08	8257	964.5	41.40	8322	970.8	41.72	
179 7.34	8119	950.4	41.56	8184	956.8	41.89	8249	963.2	42.22	8313	969.6	42.55	
178 7.17	8111	949.2	42.40	8176	955.6	42.73	8240	961.9	43.07	8304	968.3	43.41	
177 7.01	8103	947.9	43.26	8167	954.3	43.61	8232	960.7	43.95	8296	967.0	44.29	
176 6.86	8094	946.6	44.15	8158	953.0	44.50	8223	959.3	44.85	8287	965.7	45.20	
175 6.70	8086	945.4	45.04	8150	951.7	45.40	8214	958.1	45.75	8278	964.4	46.11	
174 6.55	8078	944.1	45.96	8142	950.5	46.33	8206	956.8	46.69	8269	963.1	47.05	
173 6.41	8070	942.9	46.91	8133	949.2	47.28	8197	955.5	47.65	8261	961.9	48.02	
172 6.26	8061	941.6	47.88	8125	947.9	48.25	8188	954.3	48.63	8252	960.6	49.01	
171 6.12	8052	940.3	48.85	8116	946.6	49.24	8179	952.9	49.62	8243	959.2	50.01	
170 5.98	8044	939.0	49.87	8107	945.3	50.27	8171	951.6	50.66	8234	957.9	51.05	
169 5.84	8036	937.8	50.92	8099	944.1	51.32	8162	950.3	51.72	8225	956.6	52.12	
168 5.71	8027	936.5	51.99	8090	942.8	52.40	8153	949.1	52.81	8216	955.3	53.22	
167 5.58	8019	935.2	53.09	8082	941.5	53.51	8144	947.8	53.93	8207	954.0	54.34	
166 5.45	8011	934.0	54.21	8073	940.2	54.63	8136	946.5	55.06	8199	952.7	55.48	
165 5.32	8002	932.7	55.35	8065	938.9	55.78	8127	945.2	56.22	8190	951.4	56.65	
164 5.20	7994	931.4	56.53	8056	937.6	56.97	8119	943.9	57.41	8181	950.1	57.86	
163 5.08	7985	930.1	57.73	8048	936.3	58.18	8110	942.6	58.63	8172	948.8	59.08	
162 4.960	7977	928.8	58.97	8039	935.0	59.43	8101	941.2	59.89	8163	947.5	60.35	
161 4.844	7970	927.6	60.25	8032	933.8	60.72	8094	940.0	61.19	8156	946.2	61.66	
160 4.729	7961	926.3	61.55	8023	932.5	62.03	8085	938.7	62.50	8147	944.9	62.98	
159 4.617	7953	925.0	62.88	8014	931.2	63.37	8076	937.4	63.86	8138	943.5	64.35	
158 4.508	7944	923.7	64.25	8006	929.9	64.75	8067	936.0	65.25	8129	942.2	65.75	
157 4.400	7936	922.4	65.67	7998	928.6	66.17	8059	934.8	66.68	8120	940.9	67.19	
156 4.295	7928	921.1	67.12	7989	927.3	67.63	8050	933.4	68.15	8111	939.6	68.67	
155 4.191	7919	919.8	68.59	7980	926.0	69.12	8041	932.1	69.65	8102	938.3	70.17	
154 4.090	7910	918.5	70.10	7971	924.6	70.64	8032	930.8	71.18	8093	936.9	71.72	
153 3.991	7902	917.2	71.66	7963	923.4	72.21	8024	929.5	72.76	8085	935.6	73.31	
152 3.894	7894	915.9	73.26	7954	922.0	73.82	8015	928.2	74.39	8076	934.3	74.95	
151 3.799	7885	914.6	74.90	7946	920.7	75.48	8006	926.8	76.05	8067	932.9	76.62	
150 3.706	7877	913.3	76.60	7937	919.4	77.18	7998	925.5	77.77	8058	931.6	78.36	
149 3.615	7868	912.0	78.32	7928	918.1	78.92	7989	924.2	79.52	8049	930.3	80.12	
148 3.526	7860	910.7	80.09	7920	916.8	80.71	7980	922.9	81.32	8040	929.0	81.93	
147 3.439	7851	909.4	81.89	7911	915.5	82.51	7971	921.5	83.14	8031	927.6	83.76	
146 3.353	7843	908.1	83.76	7903	914.2	84.40	7963	920.2	85.04	8023	926.3	85.68	
145 3.270	7834	906.8	85.71	7894	912.8	86.36	7954	918.9	87.02	8013	924.9	87.67	
144 3.188	7826	905.5	87.65	7886	911.5	88.32	7945	917.6	88.98	8005	923.6	89.65	
143 3.108	7817	904.1	89.66	7877	910.2	90.34	7936	916.2	91.03	7995	922.2	91.71	
142 3.029	7809	902.8	91.75	7868	908.9	92.45	7927	914.9	93.15	7987	920.9	93.84	
141 2.953	7801	901.5	93.93	7860	907.5	94.64	7920	913.5	95.35	7979	919.6	96.06	
140 2.877	7792	900.2	96.16	7851	906.2	96.89	7910	912.2	97.61	7969	918.2	98.34	
139 2.804	7784	898.9	98.47	7843	904.9	99.21	7902	910.8	99.96	7961	916.8	100.7	
138 2.732	7776	897.6	100.8	7834	903.5	101.5	7893	909.5	102.3	7952	915.5	103.1	
137 2.662	7767	896.2	103.1	7825	902.2	103.9	7884	908.1	104.7	7942	914.1	105.5	
136 2.593	7758	894.9	105.6	7817	908.8	106.4	7875	906.8	107.2	7934	912.7	108.0	
135 2.526	7750	893.6	108.1	7808	899.5	108.9	7866	905.5	109.7	7925	911.4	110.5	
134 2.460	7741	892.2	110.8	7799	898.1	111.6	7857	904.1	112.4	7915	910.0	113.3	
133 2.396	7732	890.9	113.4	7790	896.8	114.3	7848	902.7	115.1	7906	908.6	116.0	

TEMPERATURE-ENTROPY TABLE

87

Temperature Degrees Fahr. Pressure, Pounds per Square Inch.	1.56				1.57				1.58				1.59			
	Quality	Heat Contents	Specific Volume													
180 7 50	S386	977.2	42.05	S451	983.6	42.37	S516	990.3	42.70	S580	996.4	43.02				
179 7 34	S378	976.0	42.88	S442	982.3	43.22	S507	988.7	43.55	S571	995.1	43.88				
178 7 17	S369	974.7	43.74	S433	981.1	44.08	S498	987.4	44.42	S562	993.8	44.75				
177 7 01	S360	973.4	44.63	S424	979.8	44.98	S489	986.1	45.32	S553	992.5	45.65				
176 6 86	S351	972.1	45.54	S415	978.4	45.89	S479	984.8	46.24	S543	991.1	46.36				
175 6 70	S342	970.8	46.46	S406	977.1	46.82	S470	983.5	47.18	S534	989.8	47.53				
174 6 55	S333	969.5	47.42	S397	975.8	47.78	S461	982.1	48.14	S525	988.5	48.50				
173 6 41	S324	968.2	48.39	S388	974.5	48.76	S452	980.8	49.13	S515	987.2	49.39				
172 6 26	S315	966.9	49.30	S379	973.2	49.76	S442	979.5	50.14	S506	985.8	50.52				
171 6 12	S306	965.5	50.39	S360	971.8	50.78	S433	978.1	51.16	S496	984.4	51.55				
170 5 98	S297	964.2	51.44	S360	970.5	51.83	S423	976.8	52.23	S487	983.1	52.92				
169 5 84	S288	962.9	52.52	S351	969.2	52.92	S414	975.5	53.32	S477	981.8	53.72				
168 5 71	S279	961.6	53.62	S342	967.9	54.03	S405	974.2	54.44	S466	980.4	54.85				
167 5 58	S270	960.3	54.76	S333	966.6	55.17	S396	972.8	55.59	S459	979.1	56.00				
166 5 45	S261	959.0	55.90	S324	965.2	56.33	S387	971.5	56.75	S449	977.7	57.18				
165 5 32	S252	957.7	57.05	S315	963.9	57.51	S377	970.1	57.95	S440	976.4	58.38				
164 5 20	S243	956.3	58.30	S306	962.6	58.74	S368	968.8	59.18	S430	975.0	59.82				
163 5 08	S234	955.0	59.53	S296	961.2	59.98	S359	967.5	60.43	S421	973.7	60.88				
162 4 960	S225	953.7	60.81	S287	959.9	61.27	S349	966.1	61.73	S411	972.3	62.19				
161 4 844	S218	952.4	62.13	S280	958.6	62.59	S341	964.8	63.06	S403	971.0	63.53				
160 4 729	S209	951.1	63.46	S270	957.3	63.94	S332	963.5	64.42	S394	969.7	64.89				
159 4 617	S199	949.7	64.83	S261	955.9	65.32	S323	962.1	65.81	S384	968.3	66.29				
158 4 508	S190	948.4	66.24	S252	954.6	66.74	S313	960.7	67.24	S375	966.9	67.74				
157 4 400	S182	947.1	67.70	S243	953.3	68.20	S304	959.4	68.71	S366	965.6	69.22				
156 4 295	S173	945.8	69.19	S234	951.9	69.71	S295	958.1	70.23	S356	964.2	70.74				
155 4 191	S163	944.4	70.70	S224	950.5	71.23	S286	956.7	71.76	S347	962.8	72.29				
154 4 090	S154	943.0	72.26	S215	949.2	72.80	S276	955.3	73.34	S337	961.5	73.88				
153 3 991	S146	941.7	73.86	S206	947.9	74.42	S267	954.0	74.97	S328	960.1	75.52				
152 3 894	S136	940.4	75.51	S197	946.5	76.08	S258	952.6	76.64	S318	958.7	77.20				
151 3 799	S127	939.0	77.20	S188	945.1	77.77	S248	951.2	78.35	S309	957.3	78.92				
150 3 706	S118	937.7	78.94	S179	943.8	79.53	S239	949.9	80.12	S300	956.0	80.70				
149 3 615	S109	936.3	80.72	S169	942.4	81.32	S230	948.5	81.92	S290	954.6	82.52				
148 3 526	S100	935.0	82.54	S160	941.1	83.16	S221	947.2	83.77	S281	953.3	84.38				
147 3 439	S091	933.7	84.39	S151	939.7	85.01	S211	945.8	85.64	S271	951.8	86.27				
146 3 353	S082	932.3	86.32	S142	938.4	86.96	S202	944.4	87.60	S262	950.5	88.24				
145 3 270	S073	930.9	88.32	S133	937.0	88.97	S192	943.0	89.63	S232	949.1	90.28				
144 3 188	S064	929.6	90.32	S124	935.7	90.99	S183	941.7	91.65	S243	947.7	92.32				
143 3 108	S055	928.2	92.39	S114	934.3	93.07	S173	940.3	93.75	S223	946.3	94.43				
142 3 029	S046	926.9	94.54	S105	932.9	95.23	S164	938.9	95.93	S224	944.9	96.63				
141 2 953	S038	925.6	96.77	S097	931.6	97.49	S156	937.6	98.20	S215	943.6	98.91				
140 2 877	S028	924.2	99.07	S087	930.2	99.80	S146	936.1	100.5	S205	942.1	101.3				
139 2 804	S019	922.8	101.4	S078	928.8	102.2	S137	934.8	102.9	S186	940.8	103.7				
138 2 732	S010	921.5	103.8	S060	927.4	104.6	S128	933.4	105.3	S187	939.4	106.1				
137 2 662	S001	920.1	106.3	S050	926.0	107.0	S118	932.0	107.8	S177	938.0	108.6				
136 2 593	7992	918.7	108.8	S050	924.7	109.6	S109	930.6	110.4	S167	936.6	111.2				
135 2 526	7983	917.3	111.4	S041	923.3	112.2	S100	929.2	113.0	S158	935.2	113.8				
134 2 460	7973	915.9	114.1	S032	921.0	114.9	S090	927.8	115.8	S148	933.7	115.6				
133 2 396	7964	914.6	116.8	S022	920.5	117.7	S080	926.4	118.5	S138	932.3	119.4				

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	1.52			1.53			1.54			1.55		
		Quality.	Heat Con- tent.	Specific Volume.									
132	2.333	7724	889.5	116.2	7782	895.4	117.0	7840	901.4	117.9	7897	907.3	118.8
131	2.272	7715	888.2	119.0	7773	894.1	119.9	7831	900.0	120.8	7889	905.9	121.6
130	2.212	7707	886.9	121.8	7764	892.8	122.8	7822	898.7	123.7	7880	904.6	124.6
129	2.153	7698	885.5	124.9	7756	891.4	125.9	7813	897.3	126.8	7871	903.2	127.7
128	2.096	7690	884.2	128.0	7747	890.1	128.9	7804	895.9	129.9	7862	901.8	130.8
127	2.040	7681	882.9	131.1	7738	888.8	132.1	7795	894.6	133.1	7853	900.5	134.0
126	1.985	7672	881.5	134.4	7729	887.4	135.4	7787	893.2	136.4	7844	899.1	137.4
125	1.932	7664	880.2	137.8	7721	886.1	138.8	7778	891.9	139.8	7834	897.8	140.9
124	1.880	7655	878.8	141.2	7712	884.6	142.3	7769	890.5	143.3	7825	896.3	144.4
123	1.829	7646	877.5	144.7	7703	883.3	145.8	7760	889.1	146.9	7816	895.0	148.0
122	1.779	7638	876.1	148.4	7694	881.9	149.5	7751	887.7	150.6	7807	893.5	151.7
121	1.730	7630	874.8	152.2	7687	880.6	153.3	7743	886.4	154.5	7799	892.2	155.6
120	1.683	7622	873.4	156.1	7678	879.2	157.2	7734	885.0	158.4	7790	890.8	159.5
119	1.636	7613	872.1	160.1	7669	877.9	161.3	7725	883.7	162.5	7781	889.4	163.6
118	1.591	7604	870.7	164.3	7660	876.5	165.5	7716	882.3	166.7	7772	888.0	167.9
117	1.547	7596	869.3	168.5	7651	875.1	169.7	7707	880.9	170.9	7763	886.6	172.2
116	1.504	7587	867.9	172.8	7642	873.7	174.1	7698	879.4	175.4	7754	885.2	176.6
115	1.462	7579	866.6	177.3	7634	872.4	178.6	7690	878.1	179.9	7745	883.8	181.2
114	1.421	7570	865.2	182.0	7625	871.0	183.3	7680	876.7	184.6	7736	882.4	186.0
113	1.381	7561	863.9	186.7	7616	869.6	188.1	7671	875.3	189.5	7727	881.0	190.8
112	1.342	7552	862.5	191.7	7608	868.2	193.1	7663	873.9	194.5	7718	879.6	195.9
111	1.304	7543	861.2	196.8	7598	866.8	198.2	7653	872.5	199.7	7708	878.2	201.1
110	1.266	7535	859.8	202.0	7590	865.4	203.5	7645	871.1	205.0	7700	876.8	206.4
109	1.230	7526	858.4	207.4	7581	864.1	208.9	7635	869.7	210.4	7690	875.4	211.9
108	1.195	7518	857.0	213.0	7572	862.7	214.5	7627	868.3	216.1	7681	874.0	217.6
107	1.160	7508	855.6	218.6	7563	861.3	220.2	7617	866.9	221.8	7672	872.6	223.4
106	1.127	7500	854.2	224.5	7554	859.9	226.2	7609	865.5	227.8	7663	871.2	229.4
105	1.094	7491	852.8	230.7	7546	858.5	232.4	7600	864.1	234.1	7654	869.8	235.7
104	1.062	7482	851.4	237.0	7536	857.1	238.8	7591	862.7	240.5	7645	868.3	242.2
103	1.031	7474	850.1	243.6	7528	855.7	245.3	7582	861.3	247.1	7636	866.9	248.8
102	1.000	7465	848.7	250.2	7519	854.3	252.0	7573	859.9	253.8	7627	865.5	255.6
101	0.971	7457	847.3	257.1	7511	852.9	259.0	7565	858.5	260.8	7618	864.1	262.7
100	0.942	7448	845.9	264.2	7502	851.5	266.1	7555	857.1	268.0	7609	862.7	269.9
99	0.914	7439	844.5	271.7	7493	850.1	273.6	7546	856.7	275.6	7600	861.3	277.5
98	0.887	7431	843.1	279.3	7484	848.7	281.3	7537	854.2	283.3	7591	859.8	285.3
97	0.860	7422	841.8	287.2	7475	847.4	289.2	7528	852.9	291.3	7581	858.5	293.3
96	0.834	7414	840.4	295.4	7467	846.0	297.5	7520	851.5	299.6	7573	857.1	301.7
95	0.809	7405	839.0	303.8	7458	844.6	305.9	7511	850.1	308.1	7564	855.7	310.3
94	0.784	7396	837.6	312.4	7449	843.1	314.7	7502	848.7	316.9	7555	854.2	319.1
93	0.761	7388	836.2	321.4	7440	841.7	323.6	7493	847.3	325.9	7546	852.8	328.2
92	0.737	7379	834.8	330.6	7431	840.3	333.0	7484	845.8	335.3	7536	851.3	337.7
91	0.715	7370	833.4	340.3	7422	838.9	342.7	7475	844.4	345.1	7527	849.9	347.5
90	0.693	7361	832.0	350.1	7413	837.5	352.6	7466	843.0	355.1	7518	848.4	357.5
89	0.671	7352	830.6	360.3	7404	836.1	362.8	7456	841.6	365.4	7509	847.0	367.9
88	0.650	7343	829.1	370.7	7395	834.6	373.3	7447	840.1	375.9	7499	845.5	378.6
87	0.630	7335	827.7	381.7	7387	833.2	384.4	7439	838.7	387.1	7490	844.1	389.8
86	0.610	7326	826.3	393.0	7378	831.8	395.7	7429	837.2	398.5	7481	842.7	401.3
85	0.591	7317	824.9	404.6	7368	830.3	407.5	7420	835.8	410.3	7472	841.2	413.2

TEMPERATURE-ENTROPY TABLE

89

Temperature Degrees Fahr.	Pressure, Pounds per Square Inch	1.56			1.57			1.58			1.59		
		Quality	Heat Capacity units	Specific Volume									
132.2	732	7955	913.2	119.6	8013	919.1	120.5	8071	925.0	121.4	8129	930.9	122.3
131.2	727	7946	911.8	122.5	8084	917.7	123.4	8062	923.6	124.3	8119	929.5	125.2
130.2	722	7937	910.4	125.5	7995	916.3	126.4	8052	922.2	127.3	8110	928.1	128.3
129.2	153	7928	909.1	128.7	7986	915.0	129.6	8043	920.8	130.5	8100	926.7	131.5
128.2	686	7910	907.7	131.8	7976	913.6	132.7	8031	919.4	133.7	8081	923.3	134.6
127.2	640	7910	906.3	135.0	7967	912.2	136.0	8024	918.0	137.0	8081	923.9	137.9
126.1	985	7901	904.9	138.4	7958	910.8	139.4	8015	916.6	140.4	8072	922.5	141.4
125.1	972	7891	903.6	141.9	7948	906.4	142.9	8005	915.3	143.9	8062	921.1	145.6
124.1	880	7882	902.1	145.4	7939	905.0	146.5	7996	913.8	147.5	8052	919.6	148.6
123.1	829	7873	900.8	149.0	7930	906.6	150.1	7986	912.5	151.2	8043	918.3	152.3
122.1	779	7864	899.3	152.8	7920	905.1	153.9	7977	911.0	155.0	8033	918.8	156.1
121.1	730	7856	898.0	156.7	7912	903.8	157.8	7968	909.6	159.0	8025	915.4	160.1
120.1	683	7846	896.6	160.7	7903	902.4	161.8	7959	908.2	163.0	8015	914.0	164.2
119.1	636	7837	895.2	164.8	7893	901.0	166.0	7949	905.8	167.2	8005	912.6	168.4
118.1	591	7828	893.8	169.1	7884	899.6	170.3	7940	905.4	171.5	7996	911.1	172.7
117.1	547	7819	892.4	173.4	7875	898.2	174.7	7931	903.9	175.9	7986	909.7	177.1
116.1	504	7809	890.9	177.9	7865	896.7	179.2	7921	902.4	180.4	7976	908.2	181.7
115.1	462	7801	889.6	182.5	7856	895.3	183.8	7912	901.0	185.1	7967	906.8	186.4
114.1	421	7791	888.2	187.3	7847	893.9	188.6	7902	899.6	190.0	7958	905.4	191.3
113.1	381	7782	886.8	192.2	7837	892.5	193.6	7892	898.2	194.9	7948	904.0	195.3
112.1	342	7773	885.4	197.3	7828	891.1	198.7	7883	896.9	200.1	7938	902.5	201.5
111.1	304	7763	884.0	202.5	7819	890.7	204.0	7874	895.4	205.4	7929	901.1	206.9
110.1	266	7755	882.6	207.9	7809	888.2	209.4	7864	893.9	210.8	7919	906.6	212.3
109.1	230	7745	881.1	213.5	7800	886.8	215.0	7855	892.5	216.5	7909	882.2	218.0
108.1	195	7736	879.7	219.2	7790	885.4	220.7	7845	891.0	222.3	7900	886.7	223.8
107.1	160	7726	878.3	225.0	7781	884.0	226.6	7835	889.6	228.2	7880	885.3	229.8
106.1	127	7717	876.8	231.1	7772	882.5	232.7	7826	888.1	234.3	7880	883.8	236.9
105.1	924	7708	875.4	237.4	7763	881.1	239.1	7817	886.7	240.8	7871	882.4	242.4
104.1	862	7699	874.0	243.9	7753	879.6	245.6	7807	885.2	247.3	7861	880.9	249.0
103.1	831	7690	872.6	250.6	7744	878.2	252.4	7798	883.8	254.1	7851	885.5	255.9
102.1	800	7680	871.1	257.4	7734	876.8	259.3	7788	882.4	261.1	7842	888.0	262.9
101.0	971	7672	869.7	264.5	7726	875.3	266.4	7779	880.0	268.2	7813	886.5	270.1
100.0	942	7662	868.3	271.8	7716	873.8	273.7	7769	879.4	275.6	7823	885.0	277.5
99.0	914	7653	866.9	279.5	7707	872.4	281.4	7760	878.0	283.4	7813	883.6	285.3
98.0	887	7644	865.4	287.3	7697	871.0	289.3	7751	876.5	291.3	7834	882.1	293.3
97.0	860	7635	864.0	295.4	7688	869.6	297.4	7741	875.1	299.5	7794	880.7	301.6
96.0	834	7626	862.6	303.8	7670	868.2	305.9	7732	873.7	308.1	7785	879.3	310.2
95.0	809	7617	861.2	312.4	7670	866.8	314.6	7733	872.3	316.8	7776	877.9	317.0
94.0	784	7608	859.7	321.3	7660	865.3	323.6	7713	870.8	325.8	7766	876.4	328.0
93.0	761	7598	858.3	330.5	7651	863.9	332.8	7704	869.4	335.1	7756	874.9	337.4
92.0	737	7589	856.9	340.1	7641	862.4	342.4	7694	867.9	344.8	7746	873.4	347.1
91.0	715	7579	855.4	349.9	7632	860.9	352.4	7684	866.4	354.8	7737	871.9	357.2
90.0	693	7570	853.9	360.0	7622	859.4	362.5	7675	864.9	365.0	7727	870.4	367.5
89.0	671	7561	852.5	370.5	7613	858.0	373.0	7665	865.5	375.6	7717	868.9	378.1
88.0	650	7551	851.0	381.2	7603	856.5	383.8	7655	862.0	386.4	7707	867.4	389.1
87.0	630	7542	849.5	392.5	7594	855.1	395.2	7646	860.5	397.9	7698	866.0	400.6
86.0	610	7533	848.1	404.1	7585	853.6	406.8	7637	859.0	409.6	7688	864.5	412.4
85.0	591	7523	846.7	416.0	7575	852.1	418.9	7627	857.5	421.7	7675	863.0	424.6

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr. Pressure, Pounds per Square Inch.	1. 60				1. 61				1. 62				1. 63			
	Quality.	Heat Con- tents.	Specific Volume.													
420 308.6	134	1289	1.872	152	1298	1.920	172	1309	1.970	191	1319	2.015				
419 305.2	132	1287	1.888	150	1297	1.935	170	1307	1.985	190	1318	2.030				
418 301.9	131	1286	1.903	149	1296	1.952	169	1306	2.001	188	1317	2.047				
417 298.7	129	1285	1.920	147	1294	1.960	167	1305	2.019	187	1316	2.064				
416 295.4	128	1284	1.935	146	1293	1.984	166	1304	2.035	185	1314	2.080				
415 292.2	127	1283	1.951	144	1292	2.002	164	1303	2.051	183	1313	2.097				
414 289.0	125	1281	1.969	143	1291	2.019	163	1302	2.069	182	1312	2.115				
413 285.9	124	1280	1.986	142	1290	2.036	161	1300	2.085	180	1310	2.131				
412 282.7	122	1279	2.003	140	1289	2.053	160	1299	2.103	179	1309	2.150				
411 279.6	121	1278	2.020	139	1288	2.071	158	1298	2.120	177	1308	2.168				
410 276.5	119	1277	2.036	137	1287	2.089	157	1297	2.138	175	1307	2.186				
409 273.5	118	1276	2.054	136	1286	2.106	155	1296	2.156	174	1306	2.204				
408 270.5	117	1275	2.072	134	1284	2.124	154	1295	2.175	172	1304	2.222				
407 267.5	115	1273	2.090	133	1283	2.141	152	1294	2.194	171	1303	2.241				
406 264.5	114	1272	2.109	131	1282	2.160	151	1293	2.211	169	1302	2.261				
405 261.6	112	1271	2.127	130	1281	2.178	149	1291	2.230	168	1301	2.281				
404 258.6	111	1270	2.145	129	1280	2.197	148	1290	2.250	166	1300	2.300				
403 255.7	110	1269	2.164	127	1279	2.216	146	1289	2.270	165	1299	2.319				
402 252.9	108	1268	2.183	126	1278	2.235	145	1288	2.290	163	1297	2.339				
401 250.0	107	1267	2.202	124	1276	2.254	143	1287	2.309	161	1296	2.360				
400 247.2	105	1266	2.220	123	1275	2.273	142	1286	2.329	160	1295	2.380				
399 244.4	104	1265	2.240	121	1274	2.292	140	1284	2.350	158	1294	2.400				
398 241.7	103	1264	2.260	120	1273	2.312	139	1283	2.370	157	1293	2.420				
397 238.9	101	1262	2.280	118	1272	2.332	137	1282	2.390	155	1291	2.441				
396 236.2	100	1261	2.301	117	1271	2.352	136	1281	2.411	154	1290	2.463				
395 233.5	98	1260	2.322	115	1269	2.374	134	1280	2.432	152	1289	2.486				
394 230.8	97	1259	2.343	114	1268	2.395	133	1279	2.454	151	1288	2.508				
393 228.2	96	1258	2.365	113	1267	2.416	131	1277	2.476	149	1287	2.530				
392 225.6	94	1257	2.387	111	1266	2.437	130	1276	2.499	147	1285	2.552				
391 223.0	93	1256	2.409	110	1265	2.459	128	1275	2.520	146	1284	2.574				
390 220.4	92	1255	2.430	108	1264	2.482	127	1274	2.542	144	1283	2.596				
389 217.8	90	1253	2.450	107	1263	2.504	125	1273	2.564	143	1282	2.620				
388 215.3	89	1252	2.472	105	1261	2.526	123	1271	2.587	141	1281	2.645				
387 212.8	87	1251	2.494	104	1260	2.550	122	1270	2.610	140	1280	2.660				
386 210.3	86	1250	2.518	102	1259	2.572	120	1269	2.634	138	1278	2.692				
385 207.9	84	1249	2.540	101	1258	2.595	119	1268	2.658	136	1277	2.718				
384 205.4	83	1248	2.563	99	1257	2.620	117	1267	2.680	135	1276	2.742				
383 203.0	82	1247	2.586	98	1256	2.643	116	1266	2.705	133	1275	2.768				
382 200.6	80	1246	2.610	97	1255	2.669	114	1264	2.730	132	1274	2.792				
381 198.3	79	1245	2.623	95	1254	2.693	113	1263	2.755	130	1272	2.819				
380 195.9	77	1243	2.656	94	1253	2.717	111	1262	2.782	129	1271	2.844				
379 193.6	76	1242	2.680	92	1251	2.744	110	1261	2.808	127	1270	2.870				
378 191.3	75	1241	2.706	91	1250	2.769	108	1259	2.833	126	1269	2.897				
377 189.0	73	1240	2.730	89	1249	2.794	107	1258	2.860	124	1268	2.923				
376 186.7	72	1239	2.757	88	1248	2.820	105	1257	2.887	122	1266	2.952				
375 184.5	70	1238	2.781	86	1247	2.849	104	1256	2.914	121	1265	2.979				
374 182.3	69	1237	2.809	85	1246	2.874	102	1255	2.940	119	1264	3.007				
373 180.1	68	1236	2.835	83	1244	2.900	101	1254	2.968	118	1263	3.032				

TEMPERATURE-ENTROPY TABLE

91

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch	1 64			1 65			1 66			1 67		
		Quality	Heat Content, Btu/lb	Specific Volume									
420	308.6	212	1330	2.045	233	1341	2.117	255	1352	2.166	277	1363	2.223
419	305.2	210	1328	2.083	231	1339	2.133	254	1351	2.184	275	1362	2.249
418	301.9	209	1327	2.099	230	1338	2.151	252	1349	2.202	273	1360	2.260
417	298.7	207	1326	2.116	228	1337	2.170	250	1348	2.220	272	1359	2.279
416	295.4	206	1325	2.143	226	1335	2.186	248	1347	2.238	270	1358	2.297
415	292.2	204	1324	2.150	224	1334	2.204	247	1346	2.256	268	1356	2.315
414	289.0	202	1322	2.160	223	1333	2.222	245	1345	2.274	266	1355	2.333
413	285.9	201	1321	2.186	221	1332	2.240	243	1343	2.293	264	1353	2.352
412	282.7	199	1320	2.204	219	1330	2.260	241	1342	2.311	263	1352	2.370
411	279.6	198	1319	2.222	218	1329	2.278	240	1341	2.330	261	1351	2.390
410	276.5	196	1318	2.240	216	1328	2.296	238	1339	2.349	259	1350	2.410
409	273.5	194	1316	2.260	214	1326	2.314	236	1338	2.369	257	1348	2.429
408	270.5	193	1315	2.279	213	1325	2.333	234	1336	2.389	256	1347	2.449
407	267.5	191	1314	2.297	211	1324	2.352	233	1335	2.408	254	1346	2.469
406	264.5	189	1313	2.316	209	1323	2.372	231	1334	2.428	252	1345	2.489
405	261.6	188	1312	2.335	208	1322	2.392	229	1333	2.449	250	1343	2.510
404	258.6	186	1310	2.354	206	1320	2.412	227	1331	2.469	248	1342	2.530
403	255.7	185	1309	2.374	204	1319	2.433	226	1330	2.489	246	1340	2.550
402	252.9	183	1308	2.394	203	1318	2.454	224	1329	2.511	245	1339	2.571
401	250.0	181	1307	2.415	201	1317	2.475	223	1328	2.533	243	1338	2.593
400	247.2	180	1306	2.437	199	1315	2.496	221	1327	2.554	241	1337	2.606
399	244.4	178	1304	2.459	198	1314	2.518	219	1326	2.577	239	1335	2.639
398	241.7	176	1303	2.480	196	1313	2.539	217	1324	2.600	237	1334	2.661
397	238.9	175	1302	2.502	194	1312	2.560	215	1323	2.620	236	1333	2.684
396	236.2	173	1301	2.523	193	1311	2.582	213	1321	2.644	234	1332	2.709
395	233.5	172	1300	2.546	191	1309	2.605	212	1320	2.668	232	1330	2.733
394	230.8	170	1298	2.569	189	1308	2.629	210	1319	2.690	230	1329	2.757
393	228.2	168	1297	2.591	188	1307	2.650	208	1318	2.715	228	1327	2.781
392	225.6	167	1296	2.614	186	1306	2.675	207	1317	2.740	227	1326	2.805
391	223.0	165	1295	2.638	184	1304	2.700	205	1315	2.764	225	1325	2.831
390	220.4	163	1293	2.660	183	1303	2.724	203	1314	2.788	223	1324	2.856
389	217.8	162	1292	2.685	181	1302	2.748	201	1312	2.815	221	1322	2.881
388	215.3	160	1291	2.710	179	1300	2.772	200	1311	2.840	220	1321	2.909
387	212.8	159	1290	2.734	177	1299	2.798	198	1310	2.866	218	1320	2.935
386	210.3	157	1289	2.759	176	1298	2.822	196	1309	2.892	216	1319	2.960
385	207.9	155	1287	2.784	174	1297	2.850	194	1307	2.919	214	1317	2.987
384	205.4	154	1286	2.809	173	1296	2.876	193	1306	2.945	212	1316	3.015
383	203.0	152	1285	2.835	171	1295	2.902	191	1305	2.973	210	1315	3.041
382	200.6	150	1283	2.861	169	1293	2.930	189	1304	3.000	209	1314	3.070
381	198.3	149	1282	2.889	167	1292	2.958	187	1302	3.029	207	1312	3.098
380	195.9	147	1281	2.914	166	1291	2.984	186	1301	3.056	205	1311	3.128
379	193.6	146	1280	2.942	164	1290	2.013	184	1300	3.084	203	1310	3.155
378	191.3	144	1279	2.970	162	1288	3.040	182	1298	3.112	201	1308	3.182
377	189.0	142	1277	3.000	161	1287	3.070	180	1297	3.140	200	1307	3.210
376	186.7	141	1276	3.029	159	1286	3.100	179	1286	3.170	198	1306	3.241
375	184.5	139	1275	3.057	157	1285	3.129	177	1295	3.199	196	1305	3.270
374	182.3	137	1273	3.085	156	1284	3.158	175	1293	3.228	194	1303	3.300
373	180.1	136	1272	3.113	154	1282	3.186	173	1292	3.258	192	1302	3.330

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	1.60			1.61			1.62			1.63		
		Quality.	Heat Con- tent,	Specific Volume									
372	177.9	66	1235	2.860	82	1243	2.927	99	1253	2.996	116	1262	3.060
371	175.7	65	1234	2.888	81	1242	2.954	98	1252	3.024	115	1261	3.087
370	173.6	63	1232	2.914	79	1241	2.980	96	1250	3.052	113	1259	3.017
369	171.5	62	1231	2.941	78	1240	3.010	94	1249	3.080	111	1258	3.147
368	169.4	61	1230	2.970	76	1239	3.039	93	1248	3.110	100	1257	3.177
367	167.3	59	1229	2.998	75	1238	3.069	91	1246	3.140	108	1256	3.206
366	165.3	58	1228	3.027	73	1236	3.098	90	1245	3.170	107	1255	3.237
365	163.2	56	1226	3.055	72	1235	3.127	88	1244	3.200	105	1253	3.267
364	161.2	55	1226	3.084	70	1234	3.155	87	1243	3.229	104	1252	3.300
363	159.2	54	1225	3.114	69	1233	3.185	85	1242	3.260	102	1251	3.332
362	157.2	52	1223	3.142	67	1232	3.215	84	1241	3.291	100	1250	3.364
361	155.3	51	1222	3.175	66	1231	3.246	82	1239	3.322	99	1249	3.397
360	153.3	49	1221	3.206	65	1230	3.277	81	1238	3.354	97	1247	3.430
359	151.4	48	1220	3.238	63	1228	3.310	79	1237	3.388	96	1246	3.463
358	149.5	46	1218	3.269	62	1227	3.340	78	1236	3.422	94	1245	3.498
357	147.6	45	1217	3.300	60	1226	3.374	76	1235	3.457	93	1244	3.532
356	145.8	44	1216	3.333	59	1225	3.406	75	1234	3.490	91	1243	3.569
355	143.9	42	1215	3.366	57	1224	3.440	73	1233	3.525	89	1241	3.605
354	142.1	41	1214	3.399	56	1223	3.473	72	1232	3.561	88	1240	3.641
353	140.3	39	1213	3.433	54	1221	3.509	70	1230	3.597	86	1239	3.680
352	138.5	38	1212	3.467	53	1220	3.543	69	1229	3.633	85	1238	3.716
351	136.7	37	1211	3.500	51	1219	3.579	67	1228	3.670	83	1237	3.754
350	135.0	35	1209	3.536	50	1218	3.615	66	1227	3.707	82	1236	3.790
349	133.2	34	1208	3.571	49	1217	3.651	64	1226	3.745	80	1234	3.829
348	131.5	32	1207	3.608	47	1216	3.690	63	1225	3.782	78	1233	3.867
347	129.8	31	1206	3.644	46	1215	3.727	61	1223	3.820	77	1232	3.906
346	128.1	30	1205	3.680	44	1213	3.761	59	1222	3.860	75	1231	3.945
345	126.4	28	1204	3.719	43	1212	3.800	58	1221	3.898	74	1230	3.985
344	124.8	27	1203	3.758	41	1211	3.840	56	1219	3.939	72	1229	4.024
343	123.2	25	1201	3.795	40	1210	3.880	55	1218	3.979	71	1228	4.063
342	121.5	24	1200	3.833	38	1209	3.920	53	1217	4.019	69	1226	4.105
341	119.9	23	1199	3.873	37	1208	3.960	52	1216	4.059	67	1225	4.145
340	118.4	21	1198	3.913	36	1207	4.000	50	1215	4.099	66	1224	4.188
339	116.8	20	1197	3.951	34	1206	4.040	49	1214	4.140	64	1222	4.230
338	115.2	18	1196	3.996	33	1205	4.080	47	1213	4.181	63	1221	4.275
337	113.7	17	1195	4.040	31	1203	4.120	46	1212	4.223	61	1220	4.320
336	112.2	16	1194	4.080	30	1202	4.165	44	1210	4.269	60	1219	4.365
335	110.7	14	1192	4.122	28	1201	4.209	43	1209	4.310	58	1218	4.410
334	109.2	13	1191	4.168	27	1200	4.250	41	1208	4.355	56	1216	4.458
333	107.7	11	1190	4.210	25	1198	4.295	40	1207	4.400	55	1215	4.503
332	106.3	10	1189	4.255	24	1197	4.343	38	1206	4.447	53	1214	4.551
331	104.8	9	1188	4.300	22	1196	4.390	37	1205	4.495	52	1213	4.600
330	103.4	7	1187	4.345	21	1195	4.435	35	1203	4.542	50	1212	4.646
329	102.0	6	1186	4.390	20	1194	4.485	34	1202	4.590	49	1211	4.695
328	100.6	4	1184	4.440	18	1193	4.533	32	1201	4.635	47	1209	4.747
327	99.2	3	1183	4.490	17	1192	4.582	31	1200	4.688	46	1208	4.799
326	97.8	2	1182	4.540	15	1190	4.631	29	1199	4.740	44	1207	4.850
325	96.5	0	1181	4.589	14	1189	4.685	28	1198	4.795	42	1206	4.900

TEMPERATURE-ENTROPY TABLE.

93

Temperature Degrees Fahr. Pressure Pounds per Square Inch	1.64				1.65				1.66				1.67			
	Quality	Heat Con- tents	Specific Volume													
372	177.9	134	1271	3.142	152	1281	3.215	172	1291	3.287	191	1301	3.360			
371	175.7	133	1270	3.171	151	1280	3.243	170	1290	3.315	189	1299	3.389			
370	173.6	131	1269	3.200	149	1279	3.272	168	1288	3.345	187	1298	3.421			
369	171.5	129	1267	3.230	147	1277	3.303	166	1287	3.377	185	1297	3.453			
368	169.4	128	1266	3.260	146	1276	3.334	165	1286	3.409	183	1296	3.487			
367	167.3	126	1265	3.290	144	1275	3.365	163	1285	3.440	181	1294	3.519			
366	165.3	124	1264	3.320	142	1274	3.395	161	1283	3.470	180	1293	3.550			
365	163.2	123	1263	3.350	141	1273	3.429	159	1282	3.503	178	1292	3.584			
364	161.2	121	1261	3.383	139	1271	3.461	158	1281	3.538	176	1290	3.618			
363	159.2	120	1260	3.414	137	1270	3.495	156	1280	3.570	174	1289	3.650			
362	157.2	118	1259	3.447	135	1269	3.527	154	1278	3.604	172	1288	3.685			
361	155.3	116	1258	3.480	134	1268	3.560	152	1277	3.638	171	1287	3.720			
360	153.3	115	1257	3.512	132	1266	3.594	151	1276	3.673	169	1285	3.755			
359	151.4	113	1254	3.545	130	1265	3.628	149	1275	3.707	167	1284	3.790			
358	149.5	111	1254	3.580	129	1264	3.662	147	1273	3.740	165	1283	3.828			
357	147.6	110	1253	3.615	127	1263	3.699	145	1272	3.779	163	1281	3.865			
356	145.8	108	1252	3.650	125	1261	3.735	144	1271	3.813	162	1280	3.903			
355	143.9	107	1251	3.685	124	1260	3.771	142	1269	3.850	160	1279	3.939			
354	142.1	105	1249	3.720	122	1259	3.806	140	1268	3.886	158	1277	3.978			
353	140.3	103	1248	3.757	120	1258	3.843	138	1267	3.931	156	1276	4.019			
352	138.5	102	1247	3.795	119	1257	3.882	137	1266	3.970	154	1275	4.058			
351	136.7	100	1246	3.832	117	1255	3.920	135	1264	4.010	153	1274	4.097			
350	135.0	98	1244	3.870	115	1254	3.960	133	1263	4.050	151	1273	4.137			
349	133.2	97	1243	3.910	114	1253	3.999	131	1262	4.090	149	1271	4.179			
348	131.5	95	1242	3.949	112	1252	4.038	130	1261	4.130	147	1270	4.222			
347	129.8	93	1241	3.990	100	1250	4.079	128	1256	4.172	145	1268	4.266			
346	128.1	92	1240	4.030	109	1249	4.120	126	1255	4.215	144	1267	4.309			
345	126.4	90	1238	4.070	107	1248	4.161	124	1257	4.258	142	1266	4.351			
344	124.8	89	1237	4.110	105	1246	4.204	123	1256	4.300	140	1265	4.397			
343	123.2	87	1236	4.152	104	1245	4.248	121	1254	4.345	138	1263	4.440			
342	121.5	85	1235	4.198	102	1244	4.292	119	1253	4.392	136	1262	4.488			
341	119.9	84	1234	4.240	100	1243	4.337	117	1252	4.440	135	1261	4.531			
340	118.4	82	1232	4.284	99	1242	4.382	116	1251	4.486	133	1260	4.580			
339	116.8	80	1231	4.330	97	1240	4.429	114	1249	4.533	131	1258	4.629			
338	115.2	79	1230	4.375	95	1239	4.475	112	1248	4.580	129	1257	4.680			
337	113.7	77	1229	4.420	93	1238	4.520	110	1246	4.630	127	1255	4.729			
336	112.2	76	1228	4.465	92	1237	4.568	109	1245	4.677	126	1254	4.780			
335	110.7	74	1226	4.510	90	1235	4.618	107	1244	4.725	124	1253	4.830			
334	109.2	72	1225	4.560	88	1234	4.668	105	1243	4.773	122	1252	4.880			
333	107.7	71	1224	4.607	87	1233	4.717	103	1241	4.820	120	1250	4.930			
332	106.3	69	1223	4.655	85	1231	4.765	102	1240	4.870	118	1249	4.983			
331	104.8	67	1221	4.705	83	1230	4.815	100	1239	4.920	116	1247	5.005			
330	103.4	66	1220	4.755	82	1229	4.865	98	1237	4.970	115	1246	5.090			
329	102.0	64	1219	4.805	80	1228	4.917	96	1236	5.020	113	1245	5.145			
328	100.6	63	1218	4.855	78	1226	4.969	95	1235	5.072	111	1244	5.198			
327	99.2	61	1217	4.905	77	1225	5.023	93	1234	5.125	109	1242	5.253			
326	97.8	59	1215	4.960	75	1224	5.077	91	1232	5.178	107	1241	5.309			
325	96.5	58	1214	5.010	73	1223	5.130	89	1231	5.235	106	1240	5.365			

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr. Pressure, Pounds per Square Inch.	1. 60	1. 61				1. 62				1. 63			
		Quality.	Heat Con- tents.	Specific Volume.	Quality.	Heat Con- tents.	Specific Volume.	Quality.	Heat Con- tents.	Specific Volume.	Quality.	Heat Con- tents.	Specific Volume.
324 95. 1	9991	1180.0 4.614	12	1188 4.737	26	1196 4.845	41	1205	4.955				
323 93. 8	9982	1178.9 4.670	11	1187 4.790	25	1195 4.900	29	1203	5.010				
322 92. 5	9973	1177.8 4.728	9	1186 4.845	23	1194 4.955	38	1202	5.066				
321 91. 2	9964	1176.6 4.786	8	1185 4.900	22	1193 5.010	36	1201	5.123				
320 90. 0	9956	1175.6 4.846	7	1184 4.957	20	1192 5.064	35	1200	5.179				
319 88. 7	9946	1174.4 4.904	5	1182 5.012	19	1191 5.122	33	1199	5.236				
318 87. 4	9937	1173.3 4.965	4	1181 5.068	17	1189 5.178	31	1197	5.294				
317 86. 2	9927	1172.1 5.027	2	1180 5.125	16	1188 5.237	30	1196	5.351				
316 85. 0	9917	1170.9 5.089	1	1179 5.182	14	1187 5.295	28	1195	5.410				
315 83. 8	9909	1169.8 5.153	9995	1177.5 5.199	13	1186 5.353	27	1194	5.470				
314 82. 6	9899	1168.7 5.219	9986	1176.4 5.265	11	1184 5.412	25	1193	5.530				
313 81. 4	9890	1167.6 5.284	9976	1175.3 5.330	10	1183 5.473	24	1192	5.590				
312 80. 2	9880	1166.4 5.351	9967	1174.1 5.398	8	1182 5.537	22	1190	5.655				
311 79. 1	9871	1165.3 5.419	9957	1173.0 5.466	7	1181 5.599	20	1189	5.718				
310 77. 9	9862	1164.1 5.487	9948	1171.8 5.535	5	1180 5.663	19	1188	5.780				
309 76. 8	9852	1163.0 5.557	9938	1170.6 5.605	4	1179 5.729	17	1186	5.850				
308 75. 7	9843	1161.8 5.628	9928	1169.5 5.677	2	1177 5.793	16	1185	5.910				
307 74. 6	9833	1160.6 5.701	9919	1168.3 5.751	1	1176 5.860	14	1184	5.980				
306 73. 5	9825	1159.5 5.775	9910	1167.2 5.825	9995	1174.8 5.875	13	1183	6.04				
305 72. 4	9814	1158.3 5.848	9899	1165.9 5.899	9984	1173.6 5.950	11	1182	6.11				
304 71. 4	9805	1157.1 5.924	9890	1164.8 5.975	9974	1172.4 6.026	10	1181	6.18				
303 70. 3	9796	1156.0 6.001	9881	1163.7 6.053	9965	1171.3 6.105	8	1179	6.25				
302 69. 3	9787	1154.9 6.080	9871	1162.5 6.133	9956	1170.1 6.185	6	1178	6.33				
301 68. 2	9778	1153.7 6.160	9862	1161.3 6.213	9947	1168.9 6.266	5	1177	6.40				
300 67. 2	9769	1152.5 6.240	9853	1160.1 6.294	9937	1167.7 6.348	3	1175	6.48				
299 66. 2	9760	1151.4 6.323	9844	1159.0 6.378	9928	1166.6 6.432	2	1174	6.57				
298 65. 2	9750	1150.2 6.407	9834	1157.8 6.462	9918	1165.4 6.517	0	1173	6.65				
297 64. 3	9741	1149.0 6.492	9824	1156.6 6.548	9908	1164.2 6.603	9991	1171.7 6.659					
296 63. 3	9731	1147.8 6.578	9814	1155.4 6.634	9898	1162.9 6.691	9981	1170.5 6.747					
295 62. 3	9722	1146.7 6.667	9805	1154.3 6.724	9889	1161.8 6.781	9972	1169.3 6.838					
294 61. 4	9713	1145.5 6.756	9796	1153.1 6.814	9879	1160.6 6.872	9962	1168.1 6.929					
293 60. 5	9704	1144.4 6.847	9787	1151.9 6.906	9870	1159.4 6.964	9952	1166.9 7.022					
292 59. 5	9694	1143.2 6.940	9777	1150.7 6.999	9859	1158.2 7.058	9942	1165.7 7.118					
291 58. 6	9685	1142.0 7.034	9768	1149.6 7.093	9850	1157.1 7.153	9933	1164.5 7.213					
290 57. 7	9676	1140.9 7.129	9758	1148.4 7.189	9840	1155.9 7.249	9923	1163.3 7.310					
289 56. 8	9667	1139.7 7.227	9749	1147.2 7.287	9831	1154.7 7.349	9913	1162.1 7.410					
288 56. 0	9656	1138.5 7.326	9738	1146.0 7.387	9820	1153.5 7.449	9902	1160.9 7.512					
287 55. 1	9647	1137.3 7.426	9729	1144.8 7.488	9811	1152.3 7.551	9893	1159.7 7.614					
286 54. 2	9638	1136.2 7.529	9720	1143.6 7.591	9802	1151.1 7.655	9883	1158.5 7.719					
285 53. 4	9629	1135.0 7.633	9711	1142.4 7.697	9792	1159.9 7.761	9874	1157.3 7.826					
284 52. 6	9619	1133.8 7.737	9700	1141.2 7.802	9781	1148.6 7.867	9863	1156.1 7.932					
283 51. 7	9610	1132.6 7.844	9691	1140.0 7.910	9772	1147.4 7.976	9853	1154.9 8.042					
282 50. 9	9601	1131.4 7.955	9682	1138.8 8.022	9763	1146.2 8.088	9844	1153.7 8.155					
281 50. 1	9593	1130.3 8.069	9674	1137.6 8.137	9754	1145.1 8.203	9835	1152.5 8.271					
280 49. 33	9584	1129.1 8.182	9664	1136.5 8.251	9745	1143.9 8.318	9826	1151.3 8.387					
279 48. 55	9573	1127.9 8.295	9653	1135.2 8.365	9734	1142.6 8.433	9814	1150.0 8.503					
278 47. 77	9564	1126.6 8.414	9644	1134.0 8.484	9725	1141.4 8.554	9805	1148.7 8.624					
277 47. 01	9555	1125.4 8.533	9635	1132.8 8.605	9715	1140.2 8.676	9795	1147.5 8.747					

TEMPERATURE-ENTROPY TABLE.

95

Temperature Degrees Fahr. Pressure, Pounds per Square Inch.	1.64			1.65			1.66			1.67		
	Quality	Heat Capa- cacity	Specific Volume									
324 95.1	56	1213	5.065	72	1222	5.185	88	1230	5.295	104	1239	5.420
323 95.8	54	1211	5.119	70	1220	5.237	86	1229	5.330	102	1237	5.478
322 92.5	53	1210	5.173	68	1219	5.297	84	1227	5.405	100	1235	5.533
321 91.2	51	1209	5.230	67	1228	5.357	83	1226	5.465	98	1234	5.590
320 90.0	50	1208	5.289	65	1227	5.415	81	1225	5.530	97	1233	5.650
319 88.7	48	1207	5.347	63	1225	5.475	79	1224	5.590	95	1232	5.710
318 87.4	46	1206	5.405	61	1224	5.535	77	1222	5.650	93	1231	5.770
317 86.2	45	1205	5.464	60	1223	5.595	76	1221	5.715	91	1229	5.835
316 85.0	43	1203	5.520	58	1221	5.655	74	1220	5.780	89	1228	5.900
315 83.8	41	1202	5.585	56	1220	5.715	72	1218	5.840	88	1226	5.965
314 82.6	40	1201	5.645	55	1209	5.779	70	1217	5.900	86	1225	6.030
313 81.4	38	1199	5.705	53	1208	5.840	68	1216	5.965	84	1224	6.100
312 80.2	36	1198	5.767	51	1206	5.905	67	1215	6.035	82	1223	6.170
311 79.1	35	1197	5.830	50	1205	5.970	65	1213	6.10	80	1221	6.240
310 77.9	33	1196	5.899	48	1204	6.035	63	1212	6.18	79	1220	6.310
309 76.8	32	1195	5.966	46	1202	6.10	61	1210	6.25	77	1219	6.390
308 75.7	30	1193	6.04	45	1201	6.17	60	1209	6.31	75	1218	6.460
307 74.6	28	1192	6.10	43	1200	6.24	58	1208	6.39	73	1216	6.530
306 73.5	27	1191	6.17	41	1199	6.32	57	1207	6.46	71	1215	6.600
305 72.4	25	1190	6.25	40	1198	6.39	55	1206	6.54	70	1214	6.670
304 71.4	23	1188	6.33	38	1196	6.46	53	1204	6.61	68	1213	6.750
303 70.3	22	1187	6.40	36	1195	6.54	51	1203	6.69	66	1211	6.840
302 69.3	20	1186	6.47	35	1194	6.62	50	1202	6.76	64	1210	6.920
301 68.2	19	1185	6.55	33	1193	6.70	48	1201	6.84	62	1208	6.990
300 67.2	17	1183	6.63	31	1191	6.77	46	1199	6.92	61	1207	7.070
299 66.2	15	1182	6.70	30	1190	6.85	44	1198	7.00	59	1206	7.150
298 65.2	14	1181	6.79	28	1189	6.93	43	1197	7.08	57	1205	7.240
297 64.3	12	1179	6.87	26	1188	7.01	41	1196	7.16	55	1203	7.330
296 63.3	10	1178	6.94	25	1187	7.10	39	1194	7.24	54	1202	7.400
295 62.3	9	1177	7.03	23	1185	7.19	37	1193	7.33	52	1201	7.490
294 61.4	7	1176	7.12	21	1184	7.27	36	1192	7.41	50	1200	7.580
293 60.5	6	1175	7.20	20	1183	7.35	34	1191	7.50	48	1198	7.670
292 59.5	4	1173	7.29	18	1181	7.44	32	1189	7.59	46	1197	7.760
291 58.6	2	1172	7.38	16	1180	7.53	30	1188	7.68	44	1196	7.850
290 57.7	1	1171	7.46	14	1178	7.63	29	1187	7.77	43	1195	7.950
289 56.8	9995	1169.5	7.471	13	1177	7.72	27	1185	7.86	41	1193	8.040
288 56.0	9984	1168.3	7.574	11	1176	7.81	25	1184	7.96	39	1192	8.140
287 55.1	9974	1167.1	7.677	9	1175	7.91	23	1183	8.05	37	1190	8.240
286 54.2	9965	1166.0	7.782	8	1174	8.00	22	1182	8.15	36	1189	8.330
285 53.4	9955	1165.7	7.890	6	1172	8.10	20	1180	8.25	34	1188	8.430
284 52.6	9944	1163.4	7.995	4	1171	8.20	18	1179	8.35	32	1187	8.540
283 51.7	9934	1162.2	8.108	3	1170	8.30	16	1178	8.45	30	1185	8.640
282 50.9	9924	1161.1	8.222	1	1169	8.39	15	1177	8.56	29	1184	8.740
281 50.1	9916	1159.9	8.339	9997	1167.4	8.407	13	1175	8.66	27	1183	8.840
280 49.33	9906	1158.7	8.456	9987	1166.1	8.525	11	1174	8.77	25	1182	8.950
279 48.55	9895	1157.4	8.573	9975	1164.8	8.642	9	1172	8.88	23	1180	9.050
278 47.77	9885	1156.1	8.695	9965	1163.5	8.765	8	1171	8.99	21	1179	9.170
277 47.01	9875	1154.9	8.819	9955	1162.3	8.890	6	1170	9.10	20	1178	9.290

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	1.60			1.61			1.62			1.63		
		Quality.	Heat Conten-	Specific Volume.									
276 46.26	9546	1124.3	8.655	9626	1131.7	8.728	9706	1139.0	8.799	9786	1146.4	8.872	
275 45.52	9536	1123.1	8.778	9616	1130.5	8.851	9695	1137.8	8.924	9775	1145.2	8.997	
274 44.78	9527	1121.9	8.904	9606	1129.2	8.978	9686	1136.5	9.051	9765	1143.9	9.126	
273 44.06	9518	1120.7	9.032	9597	1128.0	9.108	9676	1135.3	9.182	9756	1142.7	9.257	
272 43.35	9509	1119.5	9.164	9588	1126.8	9.241	9667	1134.1	9.316	9746	1141.5	9.392	
271 42.64	9499	1118.3	9.296	9579	1125.6	9.374	9658	1132.9	9.450	9737	1140.2	9.527	
270 41.95	9489	1117.1	9.431	9568	1124.3	9.509	9647	1131.6	9.586	9726	1138.9	9.665	
269 41.26	9480	1115.9	9.567	9559	1123.2	9.646	9638	1130.4	9.724	9716	1137.7	9.804	
268 40.58	9471	1114.7	9.709	9550	1122.0	9.789	9628	1129.2	9.869	9707	1136.5	9.949	
267 39.91	9462	1113.5	9.851	9540	1120.8	9.932	9619	1128.0	10.02	9697	1135.3	10.09	
266 39.26	9452	1112.2	9.991	9530	1119.5	10.07	9608	1126.7	10.16	9686	1134.0	10.24	
265 38.60	9442	1111.0	10.14	9520	1118.3	10.22	9598	1125.5	10.31	9676	1132.8	10.39	
264 37.96	9433	1109.8	10.29	9511	1117.0	10.38	9589	1124.3	10.46	9667	1131.5	10.55	
263 37.33	9424	1108.6	10.44	9502	1115.8	10.53	9579	1123.1	10.61	9657	1130.3	10.70	
262 36.71	9415	1107.4	10.60	9492	1114.6	10.69	9570	1121.8	10.78	9647	1129.1	10.86	
261 36.09	9406	1106.2	10.76	9484	1113.4	10.85	9561	1120.6	10.94	9638	1127.9	11.03	
260 35.48	9397	1105.0	10.92	9474	1112.2	11.01	9551	1119.4	11.10	9629	1126.6	11.19	
259 34.88	9387	1103.8	11.09	9464	1109.9	11.18	9541	1118.1	11.27	9618	1125.3	11.36	
258 34.29	9377	1102.5	11.25	9454	1109.6	11.35	9531	1116.8	11.44	9608	1124.0	11.53	
257 33.71	9369	1101.3	11.42	9445	1108.5	11.52	9522	1115.6	11.61	9599	1122.8	11.70	
256 33.14	9359	1100.1	11.60	9436	1107.3	11.69	9512	1114.4	11.79	9589	1121.6	11.88	
255 32.57	9349	1098.9	11.78	9425	1106.0	11.88	9502	1113.1	11.97	9578	1120.3	12.07	
254 32.01	9340	1097.6	11.96	9416	1104.7	12.06	9492	1111.8	12.16	9568	1119.0	12.26	
253 31.46	9330	1096.4	12.15	9406	1103.5	12.25	9482	1110.6	12.34	9558	1117.8	12.44	
252 30.92	9322	1095.2	12.34	9397	1102.3	12.44	9473	1109.4	12.54	9549	1116.5	12.64	
251 30.38	9312	1094.0	12.53	9388	1101.1	12.64	9463	1108.2	12.74	9539	1115.3	12.84	
250 29.86	9303	1092.7	12.73	9378	1099.8	12.83	9454	1106.9	12.93	9529	1114.0	13.04	
249 29.34	9293	1091.5	12.93	9368	1098.6	13.03	9444	1105.6	13.14	9519	1112.7	13.24	
248 28.82	9283	1090.2	13.13	9359	1097.3	13.23	9434	1104.3	13.34	9509	1111.4	13.44	
247 28.32	9275	1089.0	13.33	9350	1096.1	13.44	9425	1103.1	13.54	9500	1110.2	13.65	
246 27.82	9265	1087.8	13.54	9340	1094.8	13.65	9415	1101.9	13.76	9490	1108.9	13.86	
245 27.33	9256	1086.6	13.74	9330	1093.6	13.85	9405	1100.7	13.96	9480	1107.7	14.07	
244 26.85	9247	1085.3	13.97	9321	1092.4	14.08	9396	1099.4	14.20	9470	1106.4	14.31	
243 26.37	9237	1084.1	14.20	9312	1091.2	14.31	9386	1098.2	14.43	9460	1105.2	14.54	
242 25.90	9228	1082.9	14.42	9303	1089.9	14.54	9377	1096.9	14.66	9451	1103.9	14.77	
241 25.44	9219	1081.6	14.66	9293	1088.6	14.78	9367	1095.6	14.89	9441	1102.6	15.01	
240 24.98	9210	1080.3	14.89	9284	1087.3	15.01	9358	1094.3	15.13	9432	1101.3	15.25	
239 24.53	9200	1079.1	15.13	9274	1086.1	15.26	9348	1091.1	15.38	9421	1100.1	15.50	
238 24.09	9191	1077.8	15.39	9265	1084.8	15.51	9339	1091.8	15.63	9412	1098.8	15.76	
237 23.66	9182	1076.6	15.64	9255	1083.6	15.76	9329	1090.6	15.89	9402	1097.5	16.01	
236 23.23	9173	1075.4	15.90	9246	1082.3	16.02	9319	1089.3	16.15	9393	1096.2	16.28	
235 22.80	9163	1074.1	16.15	9236	1081.0	16.28	9309	1088.0	16.41	9382	1094.9	16.54	
234 22.39	9153	1072.8	16.42	9226	1079.7	16.55	9299	1086.6	16.68	9372	1093.6	16.81	
233 21.98	9144	1071.6	16.70	9217	1078.5	16.83	9290	1085.4	16.96	9362	1092.3	17.10	
232 21.57	9134	1070.3	16.97	9207	1077.2	17.11	9280	1084.1	17.24	9352	1091.0	17.38	
231 21.18	9125	1069.1	17.26	9198	1076.0	17.39	9270	1082.9	17.53	9343	1089.8	17.67	
230 20.78	9116	1067.8	17.54	9189	1074.7	17.68	9261	1081.6	17.82	9333	1088.5	17.96	
229 20.40	9106	1066.5	17.83	9179	1073.4	17.97	9251	1080.3	18.11	9323	1087.2	18.25	

TEMPERATURE-ENTROPY TABLE

9

Temperature Degrees Fahr	Pressure, Pounds per Square Inch	1-64			1-65			1-66			1-67		
		Quality,	Heat Cap- tains,	Specific Volume									
276 46 26	9866	1153 7	8.944	9945	1161 1	9.016	4	1168	9.22	18	1177	9.42	
276 45 52	9845	1152 .5	9.070	9934	1159 .8	9.184	2	1167	9.33	16	1176	9.51	
274 44 78	9845	1151 2	9.200	9924	1158 5	9.274	1	1166	9.45	14	1175	9.65	
273 44 06	9835	1150 0	9.331	9915	1157 3	9.408	9904	1164 6	9.483	12	1172	9.78	
272 43 35	9825	1148 8	9.469	9905	1156 1	9.545	9984	1163 4	9.621	11	1171	9.90	
271 42 64	9816	1147 5	9.605	9895	1154 8	9.682	9974	1162 1	9.750	9	1170	10.03	
270 41 95	9805	1146 2	9.743	9884	1153 .5	9.821	9962	1160 8	9.900	7	1168	10.16	
269 41 26	9795	1145 0	9.882	9874	1152 3	9.902	9952	1156 6	10.04	5	1167	10.29	
268 40 58	9785	1143 8	10.03	9864	1151 1	10.11	9942	1158 3	10.19	3	1166	10.43	
267 39 91	9775	1142 5	10.18	9854	1149 8	10.26	9932	1157 0	10.34	2	1165	10.56	
266 39 26	9764	1141 2	10.32	9842	1148 5	10.40	9921	1155 7	10.49	9999	1164 0	10.67	
265 38 60	9754	1140 0	10.48	9832	1147 3	10.56	9910	1154 5	10.64	9988	1161 8	10.73	
264 37 96	9744	1138 7	10.63	9822	1146 0	10.72	9800	1153 2	10.80	9978	1160 5	10.89	
263 37 33	9735	1137 5	10.79	9812	1144 8	10.87	9789	1152 0	10.96	9958	1159 2	11.04	
262 36 71	9725	1136 3	10.95	9802	1143 5	11.04	9780	1150 7	11.12	9957	1157 9	11.21	
261 36 09	9716	1135 1	11.11	9793	1142 3	11.20	9870	1149 5	11.29	9948	1156 7	11.38	
260 35 48	9706	1133 8	11.28	9783	1141 0	11.37	9860	1148 2	11.46	9937	1155 4	11.56	
259 34 88	9695	1132 5	11.45	9772	1139 7	11.54	9849	1146 9	11.63	9926	1154 1	11.72	
258 34 29	9685	1131 2	11.62	9762	1138 3	11.71	9838	1145 5	11.81	9915	1152 7	11.90	
257 33 71	9676	1130 0	11.80	9752	1137 1	11.89	9829	1144 3	11.98	9906	1151 5	12.08	
256 33 14	9665	1128 7	11.98	9742	1135 9	12.07	9819	1143 0	12.17	9895	1150 2	12.26	
255 32 57	9654	1127 4	12.16	9731	1134 6	12.26	9807	1141 7	12.36	9883	1148 9	12.45	
254 32 01	9644	1126 1	12.35	9721	1133 2	12.45	9797	1140 4	12.55	9873	1147 5	12.65	
253 31 46	9634	1124 9	12.54	9710	1132 0	12.64	9786	1139 2	12.74	9862	1146 3	12.84	
252 30 92	9625	1123 6	12.74	9701	1130 7	12.84	9777	1137 9	12.94	9853	1145 0	13.04	
251 30 38	9615	1122 4	12.94	9691	1129 5	13.04	9766	1136 6	13.15	9842	1143 7	13.25	
250 29 86	9605	1121 1	13.14	9680	1128 2	13.24	9756	1135 3	13.35	9831	1142 4	13.45	
249 29 34	9594	1119 8	13.35	9670	1126 9	13.45	9745	1134 0	13.56	9820	1141 1	13.66	
248 28 82	9584	1118 5	13.55	9659	1125 6	13.66	9735	1132 6	13.76	9810	1139 7	13.87	
247 28 32	9575	1117 3	13.76	9650	1124 3	13.87	9725	1131 4	13.97	9800	1138 4	14.06	
246 27 82	9565	1116 0	13.97	9639	1123 0	14.08	9714	1130 1	14.19	9789	1137 1	14.30	
245 27 33	9554	1114 8	14.18	9629	1121 8	14.29	9704	1128 8	14.40	9779	1135 9	14.52	
244 26 85	9545	1113 5	14.42	9620	1120 5	14.54	9694	1127 5	14.65	9769	1134 6	14.76	
243 26 37	9535	1112 2	14.65	9609	1119 2	14.77	9684	1126 3	14.88	9758	1133 3	15.00	
242 25 90	9525	1110 9	14.89	9600	1117 9	15.00	9674	1125 0	15.12	9748	1132 0	15.24	
241 25 44	9515	1109 6	15.13	9589	1116 6	15.25	9663	1123 7	15.36	9737	1130.7	15.48	
240 24 98	9506	1108 3	15.37	9570	1115 3	15.49	9653	1122 3	15.61	9727	1129 3	15.73	
239 24 53	9495	1107 0	15.62	9569	1114 0	15.74	9643	1121 0	15.86	9716	1128 0	15.98	
238 24 09	9486	1105 7	15.88	9559	1112 7	16.00	9633	1119 7	16.13	9706	1126 7	16.25	
237 23 66	9475	1104 5	16.14	9549	1111 4	16.26	9622	1118 4	16.39	9606	1125 4	16.51	
236 23 23	9466	1103 2	16.40	9539	1110 1	16.53	9612	1117 1	16.66	9586	1124 0	16.79	
235 22 80	9455	1101 9	16.67	9529	1108 8	16.80	9602	1115 8	16.93	9575	1122 7	17.06	
234 22 39	9445	1100 5	16.94	9518	1107 4	17.07	9591	1114 4	17.21	9564	1121 3	17.34	
233 21 98	9435	1099 2	17.23	9508	1106 1	17.36	9551	1113 1	17.49	9554	1120 0	17.63	
232 21 57	9425	1097 9	17.51	9497	1104 8	17.65	9570	1111 8	17.78	9543	1118 7	17.92	
231 21 18	9415	1096 7	17.80	9488	1103 6	17.94	9560	1110 5	18.08	9533	1117 4	18.22	
230 20 78	9405	1095 4	18.10	9478	1102 3	18.24	9550	1109 2	18.37	9522	1116 1	18.51	
229 20 40	9395	1094 1	18.40	9467	1100 9	18.54	9539	1107 8	18.68	9511	1114 7	18.82	

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	1. 60				1. 61				1. 62				1. 63			
		Quality.	Heat Con- tent.	Specific Volume.													
228	20.02	9097	1065.2	18.13	9169	1072.1	18.27	9241	1079.0	18.42	9313	1085.8	18.56				
227	19.64	9087	1064.0	18.44	9159	1070.9	18.58	9231	1077.7	18.73	9303	1084.6	18.88				
226	19.28	9078	1062.7	18.76	9150	1069.6	18.91	9221	1076.4	19.06	9293	1083.3	19.21				
225	18.91	9068	1061.5	19.08	9140	1068.3	19.23	9211	1075.1	19.38	9283	1082.0	19.53				
224	18.56	9059	1060.2	19.40	9130	1067.0	19.56	9202	1073.8	19.71	9273	1080.7	19.86				
223	18.21	9050	1059.0	19.74	9121	1065.8	19.89	9192	1072.6	20.05	9264	1079.4	20.20				
222	17.86	9041	1057.7	20.07	9112	1064.5	20.23	9183	1071.3	20.39	9254	1078.1	20.54				
221	17.52	9032	1056.5	20.42	9103	1063.3	20.58	9174	1070.1	20.74	9245	1076.9	20.90				
220	17.19	9023	1055.2	20.78	9094	1062.0	20.94	9165	1068.8	21.11	9235	1075.6	21.27				
219	16.86	9013	1053.9	21.15	9084	1060.7	21.31	9154	1067.4	21.48	9225	1074.2	21.64				
218	16.53	9003	1052.6	21.52	9073	1059.3	21.69	9144	1066.0	21.85	9214	1072.8	22.02				
217	16.21	8994	1051.3	21.89	9064	1058.0	22.06	9134	1064.8	22.23	9205	1071.5	22.40				
216	15.90	8984	1050.0	22.27	9055	1056.7	22.45	9125	1063.5	22.62	9195	1070.2	22.79				
215	15.59	8975	1048.7	22.66	9045	1055.4	22.84	9115	1062.2	23.02	9185	1068.9	23.19				
214	15.29	8966	1047.4	23.07	9036	1054.1	23.25	9105	1060.9	23.43	9175	1067.6	23.61				
213	14.99	8956	1046.2	23.47	9026	1052.9	23.66	9096	1059.6	23.84	9165	1066.3	24.02				
212	14.70	8947	1044.9	23.85	9017	1051.6	24.04	9086	1058.3	24.22	9156	1065.0	24.41				
211	14.41	8938	1043.6	24.23	9007	1050.3	24.42	9076	1057.0	24.61	9146	1063.7	24.79				
210	14.12	8928	1042.3	24.67	8997	1049.0	24.86	9067	1055.7	25.05	9136	1062.4	25.24				
209	13.84	8919	1041.0	25.11	8988	1047.7	25.31	9057	1054.3	25.50	9126	1061.0	25.70				
208	13.57	8909	1039.7	25.57	8978	1046.4	25.77	9047	1053.0	25.96	9116	1059.7	26.16				
207	13.29	8900	1038.4	26.04	8968	1045.0	26.24	9037	1051.7	26.44	9106	1058.4	26.64				
206	13.03	8890	1037.1	26.52	8959	1043.7	26.72	9027	1050.4	26.93	9096	1057.1	27.13				
205	12.77	8881	1035.8	27.00	8949	1042.4	27.21	9018	1049.1	27.41	9086	1055.7	27.62				
204	12.51	8871	1034.5	27.49	8939	1041.1	27.70	9008	1047.8	27.92	9076	1054.4	28.13				
203	12.25	8862	1033.2	27.99	8930	1039.8	28.21	8998	1046.4	28.42	9066	1053.1	28.64				
202	12.01	8853	1031.9	28.51	8921	1038.6	28.72	8989	1045.2	28.94	9057	1051.8	29.16				
201	11.76	8844	1030.6	29.04	8912	1037.2	29.27	8980	1043.8	29.49	9048	1050.4	29.71				
200	11.52	8835	1029.3	29.58	8902	1035.9	29.80	8970	1042.5	30.03	9038	1049.1	30.26				
199	11.28	8825	1028.0	30.13	8893	1034.6	30.36	8960	1041.2	30.59	9028	1047.7	30.82				
198	11.05	8816	1026.7	30.69	8883	1033.3	30.92	8951	1039.9	31.16	9018	1046.5	31.39				
197	10.82	8806	1025.3	31.26	8873	1031.9	31.50	8940	1038.4	31.74	9007	1045.0	31.98				
196	10.60	8796	1024.0	31.85	8863	1030.5	32.09	8930	1037.1	32.34	8997	1043.6	32.58				
195	10.38	8787	1022.7	32.46	8854	1029.3	32.71	8921	1035.8	32.95	8988	1042.4	33.20				
194	10.16	8777	1021.4	33.07	8844	1027.9	33.32	8911	1034.5	33.58	8977	1041.0	33.83				
193	9.95	8768	1020.1	33.70	8835	1026.6	33.96	8901	1033.2	34.22	8968	1039.7	34.47				
192	9.74	8758	1018.8	34.35	8825	1025.3	34.61	8891	1031.8	34.87	8958	1038.3	35.13				
191	9.53	8749	1017.4	35.00	8815	1023.9	35.27	8881	1030.4	35.53	8948	1037.0	35.80				
190	9.33	8740	1016.2	35.68	8806	1022.6	35.95	8872	1029.1	36.22	8938	1035.6	36.49				
189	9.13	8730	1014.9	36.37	8796	1021.4	36.65	8863	1027.8	36.92	8929	1034.3	37.20				
188	8.94	8721	1013.5	37.07	8787	1020.0	37.35	8852	1026.5	37.63	8918	1032.9	37.91				
187	8.75	8712	1012.2	37.79	8777	1018.7	38.08	8843	1025.2	38.36	8909	1031.6	38.65				
186	8.56	8702	1010.9	38.53	8767	1017.3	38.82	8833	1023.8	39.11	8898	1030.2	39.40				
185	8.37	8693	1009.6	39.29	8758	1016.0	39.59	8823	1022.5	39.88	8889	1028.9	40.18				
184	8.19	8683	1008.2	40.07	8748	1014.6	40.37	8813	1021.1	40.67	8878	1027.5	40.97				
183	8.01	8673	1006.9	40.86	8739	1013.3	41.17	8804	1019.8	41.47	8869	1026.2	41.78				
182	7.84	8664	1005.6	41.67	8729	1012.0	41.98	8794	1018.4	42.29	8859	1024.8	42.60				
181	7.67	8655	1004.2	42.50	8720	1010.6	42.81	8785	1017.0	43.13	8849	1023.4	43.45				

TEMPERATURE-ENTROPY TABLE

99

Temperature Degrees Fahr.	Pressure, Pounds per Square inch	1.64			1.65			1.66			1.67		
		Quality	Heat Con- tents	Specific Volume									
228	20.02	9385	1092.7	18.70	9457	1099.6	18.85	9529	1106.5	18.99	9601	1113.3	19.13
227	19.64	9375	1091.4	19.02	9446	1098.3	19.17	9518	1105.2	19.31	9580	1112.0	19.45
226	19.28	9365	1090.1	19.36	9436	1097.0	19.51	9508	1103.9	19.65	9580	1110.7	19.80
225	18.91	9354	1088.8	19.68	9426	1095.7	19.83	9497	1102.6	19.98	9569	1109.4	20.13
224	18.56	9345	1087.5	20.02	9416	1094.3	20.17	9487	1101.2	20.26	9559	1108.8	20.47
223	18.21	9335	1086.2	20.36	9406	1093.1	20.51	9477	1099.9	20.67	9548	1106.7	20.82
222	17.86	9325	1084.9	20.70	9396	1091.8	20.86	9467	1098.6	21.02	9538	1105.4	21.17
221	17.52	9316	1083.6	21.06	9387	1090.5	21.22	9458	1097.3	21.38	9529	1104.1	21.54
220	17.19	9306	1082.3	21.43	9377	1089.1	21.60	9448	1095.9	21.76	9518	1102.7	21.92
219	16.86	9296	1081.0	21.81	9366	1087.8	21.97	9437	1094.5	22.14	9507	1101.3	22.30
218	16.53	9285	1079.6	22.19	9355	1086.4	22.36	9426	1093.1	22.53	9496	1099.9	22.70
217	16.21	9275	1078.3	22.57	9345	1085.1	22.75	9415	1091.8	22.92	9486	1098.6	23.09
216	15.90	9265	1077.0	22.97	9335	1083.7	23.14	9405	1090.5	23.32	9475	1097.2	23.49
215	15.69	9255	1076.7	23.37	9325	1082.4	23.55	9395	1089.2	23.72	9465	1095.9	23.90
214	15.29	9245	1074.4	23.79	9315	1081.1	23.97	9385	1087.8	24.15	9454	1094.6	24.33
213	14.99	9235	1073.1	24.20	9305	1079.8	24.39	9374	1086.5	24.57	9444	1093.3	24.75
212	14.70	9225	1071.7	24.59	9295	1078.4	24.78	9364	1085.1	24.96	9434	1091.9	25.15
211	14.41	9215	1070.4	24.98	9284	1077.1	25.17	9354	1083.8	25.36	9423	1090.6	25.55
210	14.12	9205	1069.1	25.43	9274	1075.8	25.62	9343	1082.5	25.82	9413	1089.2	26.01
209	13.84	9195	1067.7	25.89	9264	1074.4	26.09	9333	1081.1	26.28	9402	1087.8	26.48
208	13.57	9185	1066.4	26.36	9254	1073.1	26.56	9322	1079.7	26.76	9391	1086.4	26.95
207	13.29	9175	1065.0	26.84	9243	1071.7	27.05	9312	1078.4	27.25	9381	1085.0	27.45
206	13.03	9165	1063.7	27.34	9233	1070.4	27.54	9302	1077.0	27.75	9370	1083.7	27.95
205	12.77	9154	1062.4	27.83	9223	1069.0	28.04	9291	1075.7	28.25	9360	1082.3	28.45
204	12.51	9144	1061.0	28.34	9213	1067.7	28.55	9281	1074.3	28.76	9349	1080.9	28.97
203	12.25	9134	1059.7	28.85	9202	1066.3	29.07	9270	1072.9	29.29	9338	1079.6	29.50
202	12.01	9125	1058.4	29.38	9193	1065.0	29.60	9261	1071.6	29.82	9329	1078.2	29.04
201	11.76	9115	1057.0	29.94	9183	1063.6	30.16	9251	1070.3	30.38	9319	1076.9	30.60
200	11.52	9105	1055.7	30.48	9173	1062.3	30.71	9241	1068.9	30.94	9308	1075.5	31.16
199	11.28	9095	1054.3	31.01	9163	1060.9	31.28	9230	1067.5	31.51	9298	1074.1	31.74
198	11.05	9086	1053.0	31.63	9153	1059.6	31.86	9220	1066.2	32.10	9288	1072.8	32.33
197	10.82	9074	1051.6	32.21	9142	1058.1	32.45	9209	1064.7	32.69	9276	1071.3	32.93
196	10.60	9064	1050.2	32.82	9131	1056.8	33.06	9195	1063.3	33.31	9265	1069.9	33.55
195	10.38	9054	1048.9	33.45	9121	1055.4	33.69	9188	1062.0	33.94	9255	1068.5	34.19
194	10.16	9044	1047.5	34.08	9111	1054.1	34.33	9178	1060.6	34.58	9244	1067.1	34.83
193	9.95	9035	1046.2	34.73	9101	1052.7	34.98	9168	1059.3	35.24	9234	1065.8	35.50
192	9.74	9024	1044.8	35.39	9091	1051.4	35.65	9157	1057.9	35.91	9224	1064.4	36.18
191	9.53	9014	1043.5	36.06	9080	1050.0	36.33	9147	1056.5	36.60	9213	1063.0	36.86
190	9.33	9004	1042.1	36.76	9070	1048.6	37.03	9137	1055.1	37.30	9203	1061.6	37.57
189	9.13	8995	1040.8	37.47	9061	1047.3	37.75	9127	1053.8	38.02	9193	1060.3	38.30
188	8.94	8984	1039.4	38.19	9050	1045.9	38.47	9116	1052.4	38.75	9182	1058.8	38.03
187	8.75	8974	1038.1	38.93	9040	1044.6	39.22	9106	1051.0	39.50	9172	1057.5	39.79
186	8.56	8964	1036.7	39.69	9030	1043.1	39.98	9095	1049.6	40.27	9161	1056.1	40.56
185	8.37	8954	1035.4	40.47	9020	1041.8	40.77	9085	1048.2	41.06	9150	1054.7	41.36
184	8.19	8944	1034.0	41.25	9009	1040.4	41.55	9074	1046.8	41.85	9140	1053.2	42.18
183	8.01	8934	1032.6	42.09	8999	1039.0	42.39	9064	1045.5	42.70	9129	1051.9	43.01
182	7.84	8924	1031.3	42.91	8989	1037.7	43.23	9054	1044.1	43.54	9119	1050.5	43.85
181	7.67	8914	1029.8	43.77	8979	1036.2	44.03	9044	1042.6	44.41	9109	1049.0	44.72

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr. Pressure, Pounds per Square Inch.	1.60				1.61				1.62				1.63			
	Quality.	Heat Con- tents.	Specific Volume.													
180 7.50	8645	1002.8	43.35	8710	1009.2	43.67	8774	1015.6	43.99	8839	1022.0	44.32				
179 7.34	8636	1001.5	44.21	8700	1007.9	44.54	8765	1014.3	44.87	8829	1020.7	45.20				
178 7.17	8626	1000.2	45.09	8691	1006.6	45.43	8755	1012.9	45.76	8820	1019.3	46.10				
177 7.01	8617	998.9	46.01	8681	1005.2	46.35	8746	1011.6	46.69	8810	1018.0	47.04				
176 6.86	8607	997.5	46.94	8671	1003.8	47.29	8735	1010.2	47.64	8799	1016.5	47.99				
175 6.70	8598	996.1	47.89	8662	1002.5	48.25	8726	1008.8	48.60	8790	1015.2	48.96				
174 6.55	8588	994.8	48.87	8652	1001.2	49.23	8716	1007.5	49.59	8780	1013.8	49.96				
173 6.41	8579	993.5	49.87	8643	999.8	50.24	8706	1006.1	50.61	8770	1012.5	50.98				
172 6.26	8569	992.1	50.89	8633	998.5	51.27	8696	1004.8	51.65	8760	1011.1	52.03				
171 6.12	8559	990.7	51.93	8623	997.0	52.31	8686	1003.4	52.70	8749	1009.7	53.08				
170 5.98	8550	989.4	53.01	8613	995.7	53.40	8676	1002.0	53.79	8740	1008.3	54.19				
169 5.84	8540	988.1	54.12	8603	994.3	54.52	8667	1000.6	54.92	8730	1006.9	55.32				
168 5.71	8531	986.7	55.25	8594	993.0	55.66	8657	999.3	56.07	8720	1005.5	56.48				
167 5.58	8521	985.3	56.42	8584	991.6	56.84	8647	997.9	57.25	8710	1004.1	57.67				
166 5.45	8512	984.0	57.60	8574	990.2	58.02	8637	996.5	58.45	8700	1002.8	58.87				
165 5.32	8502	982.6	58.81	8565	988.9	59.24	8627	995.1	59.67	8690	1001.4	60.11				
164 5.20	8493	981.3	60.06	8555	987.5	60.50	8617	993.7	60.94	8680	1000.0	61.38				
163 5.08	8483	979.9	61.33	8545	986.1	61.78	8607	992.4	62.23	8670	998.6	62.68				
162 4.960	8473	978.5	62.64	8536	984.7	63.10	8598	991.0	63.56	8660	997.2	64.02				
161 4.844	8465	977.2	64.00	8527	983.4	64.47	8589	989.6	64.93	8651	995.8	65.40				
160 4.729	8456	975.8	65.37	8517	982.0	65.85	8579	988.2	66.33	8641	994.4	66.80				
159 4.617	8446	974.5	66.78	8508	980.7	67.27	8569	986.8	67.76	8631	993.0	68.24				
158 4.508	8436	973.1	68.23	8498	979.3	68.73	8559	985.4	69.23	8621	991.6	69.72				
157 4.400	8427	971.8	69.73	8489	977.9	70.23	8550	984.1	70.74	8611	990.3	71.25				
156 4.295	8417	970.4	71.26	8479	976.5	71.78	8540	982.7	72.30	8601	988.8	72.82				
155 4.191	8408	969.0	72.82	8469	975.1	73.35	8530	981.3	73.88	8591	987.4	74.41				
154 4.090	8398	967.6	74.42	8459	973.7	74.96	8520	979.9	75.50	8581	986.0	76.04				
153 3.991	8389	966.2	76.07	8450	972.4	76.62	8510	978.5	77.17	8571	984.6	77.72				
152 3.894	8379	964.8	77.76	8440	971.0	78.33	8500	977.1	78.89	8561	983.2	79.45				
151 3.799	8369	963.4	79.50	8430	969.5	80.07	8490	975.7	80.65	8551	981.8	81.22				
150 3.706	8360	962.1	81.29	8420	968.2	81.88	8480	974.3	82.47	8541	980.4	83.05				
149 3.615	8350	960.7	83.12	8410	966.8	83.72	8470	972.9	84.31	8531	978.9	84.91				
148 3.526	8341	959.3	84.99	8401	965.4	85.60	8461	971.5	86.22	8521	977.6	86.83				
147 3.439	8331	957.9	86.89	8391	964.0	87.52	8451	970.0	88.14	8511	976.1	88.77				
146 3.353	8322	956.6	88.87	8381	962.6	89.51	8441	968.7	90.15	8501	974.7	90.79				
145 3.270	8312	955.1	90.93	8371	961.2	91.59	8431	967.2	92.24	8491	973.3	92.89				
144 3.188	8302	953.8	92.99	8362	959.8	93.65	8421	965.8	94.32	8481	971.9	94.99				
143 3.108	8292	952.3	95.11	8352	958.4	95.79	8411	964.4	96.47	8470	970.4	97.16				
142 3.029	8283	951.0	97.32	8342	957.0	98.02	8401	963.0	98.72	8461	969.0	99.41				
141 2.953	8274	949.6	99.62	8333	955.6	100.3	8392	961.6	101.0	8452	967.6	101.8				
140 2.877	8264	948.1	102.0	8323	954.1	102.7	8382	960.1	103.4	8441	966.1	104.2				
139 2.804	8255	946.8	104.4	8314	952.7	105.2	8372	958.7	105.9	8431	964.7	106.7				
138 2.732	8245	945.4	106.9	8304	951.3	107.6	8363	957.3	108.4	8421	963.3	109.1				
137 2.662	8235	943.9	109.4	8294	949.9	110.1	8352	955.8	110.9	8411	961.8	111.7				
136 2.593	8226	942.5	112.0	8284	948.5	112.7	8342	954.4	113.5	8401	960.4	114.3				
135 2.526	8216	941.1	114.6	8274	947.1	115.4	8333	953.0	116.2	8391	959.0	117.1				
134 2.460	8206	939.7	117.4	8264	945.6	118.3	8322	951.5	119.1	8380	957.5	119.9				
133 2.396	8196	938.3	120.2	8254	944.2	121.1	8312	950.1	121.9	8370	956.0	122.8				

TEMPERATURE-ENTROPY TABLE.

101

Temperature Degrees Fahr.	Pressure Pounds per Square Inch	1.64			1.65			1.66			1.67		
		Quality	Heat Con- tents	Specific Volume									
180 7 50	8804	1028.4	44.64	8968	1034.8	44.97	9033	1041.2	45.29	9098	1047.6	45.62	
179 7 34	8804	1027.0	45.53	8958	1033.4	45.86	9023	1038.8	46.19	9087	1046.2	46.52	
178 7 17	8804	1025.7	46.44	8948	1032.1	46.77	9013	1038.4	47.11	9077	1044.8	47.43	
177 7 01	8874	1024.3	47.38	8938	1030.7	47.72	9002	1037.1	48.06	9067	1043.4	48.41	
176 6 86	8803	1022.9	48.34	8928	1029.3	48.69	8992	1035.6	49.04	9056	1042.0	49.78	
175 6 70	8853	1021.5	49.31	8917	1027.9	49.67	8981	1034.2	50.03	9045	1040.6	50.38	
174 6 55	8843	1020.2	50.32	8907	1026.5	50.68	8971	1032.8	51.05	9035	1039.2	51.41	
173 6 41	8833	1018.8	51.35	8897	1025.1	51.72	8951	1031.4	52.09	9024	1037.8	52.40	
172 6 26	8823	1017.4	52.40	8887	1023.7	52.78	8940	1030.0	53.16	9014	1036.4	53.53	
171 6 12	8813	1016.0	53.47	8876	1022.3	53.85	8940	1028.6	54.24	9003	1034.9	54.62	
170 5 98	8803	1014.6	54.58	8866	1020.9	54.97	8929	1027.2	55.36	8992	1033.5	55.72	
169 5 84	8793	1013.2	55.72	8856	1019.5	56.12	8919	1025.8	56.52	8982	1032.0	56.92	
168 5 71	8783	1011.8	56.88	8846	1018.1	57.29	8908	1024.4	57.70	8971	1030.6	58.11	
167 5 58	8773	1010.4	58.08	8836	1016.7	58.50	8898	1022.9	58.91	8961	1029.2	59.22	
166 5 45	8762	1009.0	59.30	8825	1015.3	59.72	8888	1021.5	60.14	8950	1027.8	60.57	
165 5 32	8752	1007.6	60.54	8815	1013.9	60.97	8877	1020.1	61.40	8940	1026.3	61.84	
164 5 20	8742	1006.2	61.82	8804	1012.4	62.22	8867	1018.7	62.71	8929	1024.9	63.15	
163 5 08	8732	1004.8	63.13	8794	1011.0	63.58	8856	1017.3	64.03	8919	1023.5	64.48	
162 4 960	8722	1003.4	64.48	8784	1009.6	64.94	8846	1015.8	65.40	8908	1022.0	65.86	
161 4 844	8713	1002.0	65.87	8775	1008.2	66.34	8837	1014.5	66.81	8899	1020.7	67.27	
160 4 729	8703	1000.6	67.28	8765	1006.8	67.76	8826	1013.0	68.24	8888	1019.2	68.71	
159 4 617	8693	999.2	68.73	8754	1005.4	69.22	8816	1011.6	69.71	8877	1017.8	70.19	
158 4 508	8682	997.8	70.22	8744	1004.0	70.72	8805	1010.1	71.22	8867	1016.3	71.71	
157 4 400	8673	996.4	71.76	8734	1002.6	72.26	8793	1008.8	72.77	8857	1014.9	73.28	
156 4 295	8662	995.0	73.33	8724	1001.1	73.85	8785	1007.3	74.37	8846	1013.5	74.89	
155 4 191	8652	993.6	74.93	8713	999.7	75.46	8774	1003.9	75.99	8835	1012.0	76.52	
154 4 090	8642	992.1	76.58	8703	998.3	77.12	8764	1004.4	77.66	8824	1010.5	78.20	
153 3 991	8632	990.7	78.27	8693	996.9	78.83	8753	1003.0	79.38	8814	1009.1	79.93	
152 3 894	8622	989.3	80.02	8682	995.4	80.58	8743	1001.5	81.14	8803	1007.7	81.70	
151 3 799	8611	987.9	81.80	8672	994.0	82.37	8732	1000.1	82.95	8793	1006.2	83.52	
150 3 706	8601	986.5	83.64	8662	992.6	84.23	8722	998.7	84.81	8782	1004.8	85.40	
149 3 615	8591	985.0	85.51	8651	991.1	86.11	8711	997.2	86.71	8772	1003.3	87.31	
148 3 526	8581	983.6	87.44	8641	989.7	88.05	8701	995.8	88.67	8761	1001.9	89.28	
147 3 439	8571	982.2	89.39	8531	988.2	90.02	8690	994.3	90.64	8750	1000.4	91.27	
146 3 353	8561	980.8	91.43	8621	986.8	92.07	8680	992.9	92.71	8740	998.9	93.34	
145 3 270	8550	979.3	93.54	8610	985.4	94.20	8670	991.4	94.85	8729	997.4	95.50	
144 3 188	8540	977.9	95.65	8600	983.9	96.32	8650	990.0	96.99	8719	996.0	97.65	
143 3 108	8530	976.4	97.84	8589	982.5	98.52	8649	988.5	99.20	8798	994.5	99.88	
142 3 029	8520	975.0	100.1	8579	981.0	100.5	8638	987.0	101.5	8698	993.1	102.2	
141 2 953	8511	973.6	102.5	8570	979.6	103.2	8629	985.6	103.9	8688	991.6	104.6	
140 2 877	8500	972.1	104.9	8559	978.1	105.6	8618	984.1	106.3	8677	990.1	107.0	
139 2 804	8490	970.7	107.4	8549	976.7	108.1	8608	982.7	108.9	8667	988.6	109.6	
138 2 732	8480	969.3	109.9	8539	975.2	110.7	8597	981.2	111.4	8656	987.2	112.2	
137 2 662	8469	967.8	112.5	8528	973.7	113.3	8587	979.7	114.0	8645	985.7	114.8	
136 2 593	8459	966.3	115.1	8518	972.3	115.9	8576	978.3	116.7	8635	984.2	117.5	
135 2 526	8449	964.9	117.9	8508	970.9	118.7	8566	976.8	119.5	8624	982.7	120.3	
134 2 460	8439	963.4	120.7	8437	969.3	121.6	8525	975.3	122.4	8613	981.2	123.2	
133 2 396	8428	962.0	123.6	8486	967.9	124.5	8544	973.8	125.3	8602	979.7	126.2	

TEMPERATURE-ENTROPY TABLE

Temperature Degrees Fahr.	Pressure Pounds per square Inch.	1.60			1.61			1.62			1.63		
		Quality.	Heat Con- tents.	Specific Volume.									
132 2.333	8187	936.9	123.1	8245	942.8	124.0	8303	948.7	124.9	8360	954.6	125.7	
131 2.272	8177	935.4	126.1	8235	941.3	127.0	8293	947.3	127.9	8350	953.2	128.8	
130 2.212	8168	934.0	129.1	8225	939.9	130.0	8283	945.8	130.9	8340	951.7	131.9	
129 2.153	8158	932.6	132.4	8215	938.5	133.3	8273	944.4	134.3	8330	950.3	135.2	
128 2.096	8148	931.2	135.6	8206	937.1	136.5	8263	942.9	137.5	8320	948.8	138.4	
127 2.040	8139	929.8	138.9	8196	935.7	139.9	8253	941.5	140.9	8310	947.4	141.9	
126 1.985	8129	928.3	142.4	8186	934.2	143.4	8243	940.0	144.4	8300	945.9	145.4	
125 1.932	8119	926.9	146.0	8176	932.8	147.0	8233	938.6	148.0	8290	944.5	149.0	
124 1.880	8109	925.5	149.6	8166	931.3	150.7	8223	937.1	151.7	8280	943.0	152.8	
123 1.829	8100	924.1	153.3	8156	929.9	154.4	8213	935.7	155.5	8269	941.6	156.5	
122 1.779	8090	922.6	157.2	8146	928.4	158.3	8203	934.2	159.4	8259	940.1	160.5	
121 1.730	8081	921.2	161.2	8138	927.0	162.3	8194	932.8	163.5	8250	938.6	164.6	
120 1.683	8071	919.8	165.3	8128	925.6	166.5	8184	931.3	167.6	8240	937.1	168.8	
119 1.636	8062	918.4	169.5	8118	924.2	170.7	8174	929.9	171.9	8230	935.7	173.1	
118 1.591	8052	916.9	173.9	8108	922.7	175.1	8164	928.5	176.3	8220	934.2	177.6	
117 1.547	8042	915.5	178.4	8098	921.2	179.6	8154	927.0	180.9	8210	932.7	182.1	
116 1.504	8032	914.0	183.0	8088	919.7	184.2	8144	925.5	185.5	8199	931.2	186.8	
115 1.462	8023	912.6	187.7	8079	918.3	189.0	8134	926.1	190.3	8190	929.8	191.6	
114 1.421	8013	911.1	192.6	8068	916.8	194.0	8124	922.6	195.3	8179	928.3	196.6	
113 1.381	8003	909.7	197.7	8058	915.4	199.0	8114	921.1	200.4	8169	926.9	201.8	
112 1.342	7994	908.2	202.9	8049	913.9	204.3	8104	919.6	205.7	8159	925.4	207.1	
111 1.304	7984	906.8	208.3	8039	912.5	209.7	8094	918.2	211.2	8149	923.9	212.6	
110 1.266	7974	905.3	213.8	8029	911.0	215.3	8084	916.7	216.7	8139	922.4	218.2	
109 1.230	7964	903.9	219.5	8019	909.6	221.0	8074	915.2	222.5	8128	920.9	224.0	
108 1.195	7955	902.4	225.4	8009	908.1	226.9	8064	913.7	228.4	8118	919.4	230.0	
107 1.160	7944	901.0	231.3	7999	906.6	232.9	8053	912.3	234.5	8108	917.9	236.1	
106 1.127	7935	899.5	237.6	7989	905.1	239.2	8044	910.8	240.8	8098	916.4	242.5	
105 1.094	7925	898.0	244.1	7979	903.6	245.8	8034	909.3	247.4	8088	914.9	249.1	
104 1.062	7915	896.5	250.7	7969	902.1	252.5	8023	907.8	254.2	8077	913.4	255.9	
103 1.031	7905	895.1	257.6	7959	900.7	259.4	8013	906.3	261.1	8067	911.9	262.9	
102 1.000	7896	893.6	264.7	7950	899.2	266.5	8003	904.8	268.3	8057	910.4	270.1	
101 0.971	7887	892.1	271.9	7941	897.7	273.8	7994	903.3	275.6	8048	908.9	277.5	
100 0.942	7877	890.6	279.4	7930	896.2	281.3	7984	901.8	283.2	8037	907.4	285.1	
99 0.914	7867	889.2	287.3	7920	894.8	289.3	7974	900.3	291.2	8027	905.9	293.2	
98 0.887	7857	887.7	295.3	7910	893.3	297.4	7964	898.8	299.4	8017	904.4	301.4	
97 0.860	7847	886.3	303.6	7901	891.9	305.7	7954	897.4	307.7	8007	903.0	309.8	
96 0.834	7838	884.9	312.3	7891	890.4	314.4	7944	896.0	316.5	7997	901.5	318.6	
95 0.809	7829	883.4	321.1	7881	888.9	323.3	7934	894.5	325.5	7987	900.0	327.6	
94 0.784	7819	881.9	330.3	7871	887.4	332.5	7924	893.0	334.7	7977	898.5	337.0	
93 0.761	7809	880.4	339.7	7861	885.9	342.0	7914	891.5	344.3	7967	897.0	346.6	
92 0.737	7799	878.9	349.5	7851	884.4	351.8	7904	889.9	354.2	7957	895.5	356.5	
91 0.715	7789	877.4	359.6	7841	882.9	362.0	7894	888.4	364.5	7946	894.0	366.9	
90 0.693	7779	875.9	370.0	7831	881.4	372.5	7884	886.9	374.9	7936	892.4	377.4	
89 0.671	7769	874.4	380.7	7821	879.9	383.2	7873	885.4	385.8	7926	890.9	388.4	
88 0.650	7759	872.9	391.7	7811	878.4	394.3	7863	883.9	396.9	7915	889.3	399.6	
87 0.630	7750	871.4	403.3	7802	876.9	406.0	7854	882.4	408.7	7905	887.8	411.4	
86 0.610	7740	869.9	415.2	7792	875.4	417.9	7843	880.9	420.7	7895	886.3	423.5	
85 0.591	7730	868.4	427.5	7781	873.9	430.3	7833	879.3	433.2	7885	884.8	436.0	

TEMPERATURE-ENTROPY TABLE.

103

Temperature Degrees Fahr.	Pressure Pounds per Square Inch,	1.64			1.65			1.66			1.67		
		Quality	Heat Capa- cility	Specific Volume									
132.2	333	8418	960.5	126.6	8476	966.4	127.5	8534	972.3	128.4	8592	978.3	129.2
131.2	272	8408	959.1	129.7	8466	965.0	130.5	8524	970.9	131.4	8581	976.8	132.3
130.2	212	8398	957.6	132.8	8455	963.5	133.7	8513	969.4	134.6	8571	975.3	135.5
129.2	153	8388	956.2	136.1	8445	962.0	137.0	8503	967.9	138.0	8560	973.8	138.9
128.2	996	8377	954.7	139.4	8435	960.6	140.4	8492	966.4	141.3	8549	972.3	142.3
127.2	40	8367	953.3	142.8	8424	959.1	143.8	8482	965.0	144.8	8539	970.9	145.8
126.1	985	8357	951.8	146.4	8414	957.6	147.4	8471	963.5	148.4	8528	969.3	149.4
125.1	932	8347	950.4	150.1	8404	956.2	151.1	8460	962.1	152.1	8517	967.7	153.1
124.1	880	8336	948.8	153.8	8393	954.6	154.9	8450	960.5	155.9	8507	966.3	156.9
123.1	829	8326	947.4	157.6	8384	953.2	158.7	8439	959.1	159.8	8496	964.9	160.8
122.1	779	8316	945.9	161.6	8372	951.7	162.7	8429	957.5	163.8	8485	963.3	164.9
121.1	730	8307	944.4	165.7	8363	950.2	166.8	8419	956.0	168.0	8476	961.8	169.1
120.1	683	8296	942.9	169.9	8353	948.7	171.1	8409	954.5	172.2	8465	960.3	173.4
119.1	636	8286	941.5	174.3	8342	947.3	175.4	8398	951.0	176.6	8454	958.8	177.8
118.1	591	8276	940.0	178.8	8332	945.8	180.0	8388	951.5	181.2	8444	957.3	182.4
117.1	547	8266	938.5	183.3	8321	944.3	184.6	8377	950.0	185.8	8433	955.8	187.0
116.1	504	8255	937.0	188.0	8311	942.8	189.3	8366	948.5	190.6	8422	954.2	191.9
115.1	462	8245	935.5	192.9	8301	941.3	194.2	8356	947.0	195.5	8412	952.8	196.8
114.1	421	8235	934.0	198.0	8290	939.8	199.3	8346	945.5	200.6	8401	951.3	202.0
113.1	381	8224	932.6	203.1	8280	938.3	204.5	8335	944.0	205.9	8390	949.5	207.2
112.1	342	8214	931.1	208.5	8269	936.8	209.9	8325	942.5	211.3	8380	945.2	212.7
111.1	304	8204	929.6	214.0	8259	935.3	215.5	8314	941.0	216.9	8369	946.7	218.3
110.1	266	8194	928.1	219.7	8249	933.8	221.1	8303	939.5	222.6	8358	945.2	224.1
109.1	230	8183	926.6	225.5	8238	932.3	227.0	8293	938.0	228.5	8347	943.7	230.1
108.1	195	8173	925.1	231.5	8228	930.8	233.1	8282	936.4	234.6	8337	942.1	236.2
107.1	160	8162	923.6	237.7	8217	929.3	239.3	8271	934.9	240.9	8326	940.6	242.4
106.1	127	8152	922.1	244.1	8207	927.7	245.7	8261	933.4	247.3	8315	939.0	249.0
105.1	994	8142	920.6	250.8	8196	926.2	252.4	8251	931.9	254.1	8304	937.5	255.8
104.1	662	8131	919.1	257.6	8186	924.7	259.3	8240	930.3	261.0	8294	936.0	262.7
103.1	031	8121	917.6	264.7	8175	923.2	266.4	8229	928.8	268.2	8283	934.5	269.9
102.1	000	8111	916.1	271.9	8165	921.7	273.7	8219	927.3	275.5	8273	932.9	277.3
101.1	971	8102	914.5	279.3	8155	920.2	281.2	8209	925.8	283.0	8263	931.4	284.9
100.0	942	8091	913.0	287.0	8144	918.6	288.9	8198	924.2	290.8	8252	929.8	292.7
99.0	914	8081	911.5	295.1	8134	917.1	297.1	8188	922.7	299.0	8241	928.3	301.0
98.0	887	8070	910.0	303.4	8124	915.6	305.4	8177	921.2	307.4	8230	926.7	309.4
97.0	860	8060	908.5	311.8	8113	914.1	313.9	8166	919.7	316.0	8220	925.2	318.0
96.0	834	8051	907.1	320.7	8104	912.6	322.8	8157	918.2	325.0	8210	923.7	327.1
95.0	809	8040	905.5	329.8	8093	911.1	332.0	8146	916.7	334.2	8199	922.2	336.3
94.0	784	8030	904.0	339.2	8083	909.6	341.4	8135	915.1	343.6	8188	920.6	345.9
93.0	761	8019	902.5	348.8	8072	908.1	351.1	8125	913.6	353.4	8177	919.1	355.7
92.0	737	8009	901.0	358.9	8062	906.5	361.2	8114	912.0	363.6	8167	917.5	365.9
91.0	715	7999	899.4	369.3	8051	905.0	371.7	8103	910.5	374.1	8156	916.0	376.6
90.0	693	7988	897.9	379.9	8040	903.4	382.4	8093	908.9	384.9	8145	914.4	387.4
89.0	671	7978	896.4	390.9	8030	901.9	393.5	8082	907.4	396.0	8134	912.9	398.6
88.0	650	7967	894.8	402.2	8019	900.3	404.8	8071	905.8	407.4	8123	911.2	410.1
87.0	630	7957	893.3	414.1	8009	898.8	416.8	8061	904.3	419.5	8113	909.7	422.2
86.0	610	7947	891.8	426.3	7999	897.2	429.0	8050	902.7	431.8	8102	908.1	434.6
85.0	591	7936	890.2	438.9	7988	895.7	441.7	8039	901.1	444.6	8091	906.5	447.4

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	1.68			1.69			1.70			1.71		
		Quality.	Heat Con- tents.	Specific Volume.									
420	308.6												
419	305.2	300	1375	2.290									
418	301.9	298	1373	2.310									
417	298.7	296	1371	2.330									
416	295.4	294	1370	2.349									
415	292.2	292	1369	2.368									
414	289.0	291	1368	2.387									
413	285.9	289	1367	2.406									
412	282.7	287	1365	2.425									
411	279.6	285	1364	2.445									
410	276.5	283	1362	2.464									
409	273.5	281	1361	2.484									
408	270.5	279	1359	2.505									
407	267.5	278	1358	2.526	300	1369	2.586						
406	264.5	276	1357	2.547	298	1368	2.608						
405	261.6	274	1356	2.568	296	1367	2.629						
404	258.6	272	1354	2.589	294	1365	2.650						
403	255.7	270	1353	2.610	292	1364	2.672						
402	252.9	268	1351	2.631	290	1362	2.696						
401	250.0	266	1350	2.653	288	1361	2.719						
400	247.2	264	1349	2.676	286	1360	2.740						
399	244.4	263	1348	2.698	284	1358	2.764						
398	241.7	261	1347	2.723	282	1357	2.788						
397	238.9	259	1345	2.746	280	1355	2.810						
396	236.2	257	1344	2.770	278	1354	2.835						
395	233.5	255	1342	2.793	276	1353	2.860						
394	230.8	253	1341	2.818	274	1351	2.885	299	1364	2.960			
393	228.2	251	1339	2.843	272	1350	2.910	297	1363	2.985			
392	225.6	249	1338	2.869	270	1349	2.936	295	1361	3.010			
391	223.0	247	1337	2.894	269	1348	2.961	293	1360	3.035			
390	220.4	246	1336	2.920	267	1346	2.988	291	1358	3.060			
389	217.8	244	1335	2.946	265	1345	3.015	289	1357	3.186			
388	215.3	242	1333	2.972	263	1344	3.041	286	1355	3.112			
387	212.8	240	1332	3.000	261	1342	3.07	284	1353	3.140			
386	210.3	238	1330	3.027	259	1341	3.096	282	1352	3.167			
385	207.9	236	1329	3.054	257	1339	3.125	280	1351	3.296			
384	205.4	234	1327	3.082	255	1338	3.152	278	1349	3.223			
383	203.0	232	1326	3.110	253	1336	3.180	276	1348	3.251	300	1360	3.330
382	200.6	230	1325	3.139	251	1335	3.200	274	1347	3.280	298	1358	3.360
381	198.3	229	1324	3.170	249	1333	3.239	272	1345	3.310	296	1357	3.390
380	195.9	227	1322	3.198	247	1332	3.266	270	1344	3.340	294	1355	3.420
379	193.6	225	1321	3.227	245	1331	3.296	268	1342	3.370	292	1354	3.450
378	191.3	223	1319	3.257	243	1329	3.325	266	1341	3.400	290	1353	3.481
377	189.0	221	1318	3.287	241	1328	3.355	264	1339	3.431	287	1351	3.514
376	186.7	219	1317	3.317	239	1327	3.385	262	1338	3.464	285	1349	3.544
375	184.5	217	1315	3.346	238	1326	3.418	260	1337	3.497	283	1348	3.577
374	182.3	215	1314	3.376	236	1324	3.448	258	1335	3.529	281	1347	3.609
373	180.1	213	1312	3.407	234	1323	3.480	256	1334	3.560	279	1345	3.640

N. B. This page is left blank so that the tables on pages 106 and 107 may face each other.

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	1.68			1.69			1.70			1.71		
		Quality.	Heat Con- tents	Specific Volume.	Quality.	Heat Con- tents.	Specific Volume.	Quality.	Heat Con- tents.	Specific Volume.	Quality.	Heat Con- tents.	Specific Volume.
372	177.9	212	1311	3.438	232	1322	3.510	254	1333	3.594	276	1343	3.673
371	175.7	210	1310	3.469	230	1320	3.541	252	1331	3.628	274	1342	3.708
370	173.6	208	1309	3.500	228	1319	3.578	250	1330	3.660	272	1340	3.740
369	171.5	206	1307	3.534	226	1317	3.610	248	1328	3.694	270	1339	3.775
368	169.4	204	1306	3.567	224	1316	3.643	246	1327	3.728	268	1338	3.810
367	167.3	202	1305	3.600	222	1315	3.679	244	1326	3.763	266	1336	3.845
366	165.3	200	1303	3.634	220	1313	3.711	242	1324	3.798	263	1334	3.882
365	163.2	198	1302	3.669	218	1312	3.748	240	1323	3.831	261	1333	3.918
364	161.2	197	1301	3.702	216	1310	3.781	238	1321	3.868	259	1332	3.955
363	159.2	195	1300	3.738	214	1309	3.818	236	1320	3.905	257	1330	3.990
362	157.2	193	1298	3.773	212	1308	3.853	234	1319	3.940	255	1329	4.028
361	155.3	191	1297	3.809	210	1306	3.890	232	1317	3.979	253	1328	4.065
360	153.3	189	1295	3.845	208	1305	3.928	230	1316	4.015	251	1326	4.104
359	151.4	187	1294	3.880	206	1303	3.961	227	1314	4.054	248	1324	4.141
358	149.5	185	1292	3.918	204	1302	4.000	225	1312	4.092	246	1323	4.182
357	147.6	183	1291	3.954	203	1301	4.040	223	1311	4.131	244	1321	4.221
356	145.8	182	1290	3.991	201	1300	4.079	221	1310	4.171	242	1320	4.263
355	143.9	180	1289	4.029	199	1299	4.119	219	1308	4.210	240	1319	4.305
354	142.1	178	1288	4.069	197	1297	4.159	217	1307	4.251	238	1317	4.347
353	140.3	176	1286	4.109	195	1296	4.199	215	1306	4.293	235	1315	4.390
352	138.5	174	1285	4.149	193	1294	4.240	213	1304	4.337	233	1314	4.433
351	136.7	172	1283	4.189	191	1293	4.282	211	1303	4.379	231	1313	4.477
350	135.0	170	1282	4.230	189	1292	4.325	209	1302	4.420	229	1311	4.520
349	133.2	168	1280	4.272	187	1290	4.370	207	1300	4.466	227	1310	4.568
348	131.5	166	1279	4.315	185	1289	4.413	205	1299	4.512	224	1308	4.615
347	129.8	165	1278	4.360	183	1287	4.460	203	1297	4.560	222	1307	4.662
346	128.1	163	1277	4.405	181	1286	4.505	201	1296	4.608	220	1305	4.709
345	126.4	161	1275	4.451	179	1285	4.550	199	1295	4.655	218	1304	4.760
344	124.8	159	1274	4.495	177	1283	4.597	197	1293	4.704	216	1303	4.809
343	123.2	157	1273	4.542	175	1282	4.645	195	1292	4.752	214	1301	4.859
342	121.5	155	1271	4.590	173	1280	4.690	193	1290	4.800	212	1300	4.909
341	119.9	153	1270	4.638	171	1279	4.740	191	1289	4.850	210	1299	4.960
340	118.4	152	1269	4.685	170	1278	4.788	189	1288	4.900	208	1297	5.010
339	116.8	150	1268	4.733	168	1277	4.838	187	1286	4.950	205	1295	5.061
338	115.2	148	1266	4.783	166	1275	4.887	185	1285	5.000	203	1294	5.115
337	113.7	146	1265	4.832	164	1274	4.939	183	1284	5.055	201	1292	5.170
336	112.2	144	1263	4.880	162	1273	4.990	181	1282	5.105	199	1291	5.224
335	110.7	142	1262	4.930	160	1271	5.040	179	1281	5.160	197	1290	5.279
334	109.2	140	1261	4.980	158	1270	5.092	177	1280	5.212	195	1288	5.334
333	107.7	138	1259	5.032	156	1268	5.147	174	1278	5.272	193	1287	5.389
332	106.3	137	1258	5.086	154	1267	5.200	172	1276	5.322	191	1286	5.444
331	104.8	135	1257	5.140	152	1266	5.256	170	1275	5.380	189	1284	5.500
330	103.4	133	1256	5.195	150	1264	5.312	168	1274	5.435	186	1282	5.555
329	102.0	131	1254	5.250	148	1263	5.370	166	1272	5.493	184	1281	5.612
328	100.6	129	1253	5.309	146	1261	5.430	164	1271	5.550	182	1280	5.670
327	99.2	127	1252	5.365	144	1260	5.487	162	1269	5.610	180	1278	5.730
326	97.8	125	1250	5.420	142	1259	5.547	160	1268	5.670	178	1277	5.790
325	96.5	123	1249	5.480	140	1258	5.607	158	1266	5.730	176	1276	5.850

TEMPERATURE ENTROPY TABLE

107

Temperature, Degrees Fahr.	Pressure, Pounds per Square inch	1. 64				1. 65				1. 66				1. 67			
		Quality	Heat Con- tent	Speci- fic Volume													
372	177.9	299	1354	3.765	+1	120	+10	+11	121	+11	+11	122	+12	+11	123	+13	+11
371	175.7	297	1353	3.798	+1	120	+10	+10	121	+11	+11	122	+12	+10	123	+13	+10
370	173.6	295	1351	3.833	+1	120	+10	+10	121	+11	+11	122	+12	+10	123	+13	+10
369	171.5	292	1349	3.869	+1	120	+10	+10	121	+11	+11	122	+12	+10	123	+13	+10
368	169.4	290	1348	3.904	+1	120	+10	+10	121	+11	+11	122	+12	+10	123	+13	+10
367	167.3	288	1347	3.940	+1	120	+10	+10	121	+11	+11	122	+12	+10	123	+13	+10
366	165.3	286	1345	3.976	+1	120	+10	+10	121	+11	+11	122	+12	+10	123	+13	+10
365	163.2	284	1344	4.011	+1	120	+10	+10	121	+11	+11	122	+12	+10	123	+13	+10
364	161.2	282	1343	4.049	+1	120	+10	+10	121	+11	+11	122	+12	+10	123	+13	+10
363	159.2	280	1341	4.086	+1	120	+10	+10	121	+11	+11	122	+12	+10	123	+13	+10
362	157.2	277	1339	4.123	+1	120	+10	+10	121	+11	+11	122	+12	+10	123	+13	+10
361	155.3	275	1338	4.160	299	1349	4.260	+1	120	+10	+10	121	+11	+10	122	+12	+10
360	153.3	273	1337	4.200	297	1348	4.302	+1	120	+10	+10	121	+11	+10	122	+12	+10
359	151.4	271	1335	4.239	295	1346	4.343	+1	120	+10	+10	121	+11	+10	122	+12	+10
358	149.5	269	1334	4.279	293	1345	4.385	+1	120	+10	+10	121	+11	+10	122	+12	+10
357	147.6	267	1333	4.319	290	1343	4.428	+1	120	+10	+10	121	+11	+10	122	+12	+10
356	145.8	264	1331	4.360	288	1342	4.470	+1	120	+10	+10	121	+11	+10	122	+12	+10
355	143.9	262	1329	4.400	286	1340	4.513	+1	120	+10	+10	121	+11	+10	122	+12	+10
354	142.1	260	1328	4.444	283	1338	4.557	+1	120	+10	+10	121	+11	+10	122	+12	+10
353	140.3	258	1327	4.488	281	1337	4.602	+1	120	+10	+10	121	+11	+10	122	+12	+10
352	138.5	256	1326	4.532	279	1336	4.647	+1	120	+10	+10	121	+11	+10	122	+12	+10
351	136.7	254	1324	4.577	277	1335	4.695	+1	120	+10	+10	121	+11	+10	122	+12	+10
350	135.0	252	1323	4.622	274	1333	4.743	299	1344	4.850	+1	120	+10	+10	121	+12	+10
349	133.2	249	1321	4.669	272	1331	4.790	296	1342	4.900	+1	120	+10	+10	121	+12	+10
348	131.5	247	1319	4.717	270	1330	4.839	294	1341	4.950	+1	120	+10	+10	121	+12	+10
347	129.8	245	1318	4.766	267	1328	4.889	292	1339	5.000	+1	120	+10	+10	121	+12	+10
346	128.1	243	1317	4.815	265	1327	4.935	290	1338	5.050	+1	120	+10	+10	121	+12	+10
345	126.4	241	1315	4.868	263	1325	4.985	287	1336	5.105	+1	120	+10	+10	121	+12	+10
344	124.5	239	1314	4.919	261	1324	5.037	285	1335	5.155	+1	120	+10	+10	121	+12	+10
343	123.2	236	1312	4.970	258	1322	5.090	283	1334	5.208	+1	120	+10	+10	121	+12	+10
342	121.5	234	1311	5.020	256	1321	5.140	280	1332	5.260	+1	120	+10	+10	121	+12	+10
341	119.9	232	1309	5.075	254	1319	5.193	278	1330	5.315	300	1339	5.433	+1	120	+10	+10
340	118.4	230	1308	5.124	252	1318	5.247	276	1329	5.367	298	1338	5.483	+1	120	+10	+10
339	116.8	228	1307	5.179	249	1316	5.300	273	1327	5.420	296	1337	5.545	+1	120	+10	+10
338	115.2	226	1305	5.230	247	1315	5.355	271	1326	5.475	293	1335	5.600	+1	120	+10	+10
337	113.7	224	1304	5.286	245	1314	5.410	269	1325	5.530	291	1334	5.660	+1	120	+10	+10
336	112.2	221	1302	5.340	242	1312	5.463	266	1323	5.585	289	1333	5.717	+1	120	+10	+10
335	110.7	219	1300	5.395	240	1310	5.520	264	1321	5.640	286	1332	5.775	+1	120	+10	+10
334	109.2	217	1299	5.450	238	1309	5.580	262	1320	5.700	284	1330	5.836	+1	120	+10	+10
333	107.7	215	1298	5.502	236	1308	5.638	259	1318	5.760	281	1328	5.898	+1	120	+10	+10
332	106.3	213	1297	5.560	233	1306	5.695	257	1317	5.820	279	1327	5.960	+1	120	+10	+10
331	104.8	211	1295	5.620	231	1305	5.750	255	1316	5.882	277	1326	6.023	+1	120	+10	+10
330	103.4	208	1293	5.675	229	1303	5.810	252	1314	5.940	274	1324	6.088	+1	120	+10	+10
329	102.0	206	1292	5.735	226	1301	5.868	250	1313	6.007	272	1323	6.154	+1	120	+10	+10
328	100.6	204	1290	5.795	224	1300	5.928	247	1311	6.070	269	1321	6.220	+1	120	+10	+10
327	99.2	202	1289	5.850	222	1299	5.990	245	1309	6.130	267	1320	6.285	+1	120	+10	+10
326	97.8	200	1288	5.910	220	1297	6.052	243	1308	6.195	264	1318	6.355	+1	120	+10	+10
325	96.5	198	1286	5.970	217	1295	6.115	240	1306	6.260	262	1316	6.435	+1	120	+10	+10

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	1.68			1.69			1.70			1.71		
		Quality.	Heat Con- tents.	Specific Volume.									
324 95.1	121	1247	5.535	139	1257	5.670	156	1265	5.790	174	1274	5.910	
323 93.8	120	1246	5.595	137	1255	5.730	154	1264	5.850	172	1273	5.975	
322 92.5	118	1245	5.655	135	1254	5.790	152	1262	5.910	170	1272	6.040	
321 91.2	116	1244	5.715	133	1252	5.850	150	1261	5.975	168	1270	6.105	
320 90.0	114	1242	5.775	131	1251	5.910	148	1260	6.040	165	1268	6.170	
319 88.7	112	1241	5.835	129	1250	5.970	146	1258	6.105	163	1267	6.240	
318 87.4	110	1239	5.900	127	1248	6.030	144	1257	6.175	161	1266	6.310	
317 86.2	108	1238	5.965	125	1247	6.09	142	1256	6.240	159	1264	6.375	
316 85.0	106	1237	6.030	123	1245	6.16	140	1254	6.310	157	1263	6.45	
315 83.8	105	1236	6.09	121	1244	6.23	138	1253	6.380	155	1261	6.52	
314 82.6	103	1234	6.16	119	1243	6.30	136	1251	6.450	153	1260	6.59	
313 81.4	101	1233	6.23	117	1241	6.37	134	1250	6.525	151	1259	6.66	
312 80.2	99	1232	6.30	116	1240	6.44	132	1249	6.60	149	1257	6.74	
311 79.1	97	1230	6.37	114	1239	6.51	130	1247	6.67	147	1256	6.82	
310 77.9	95	1229	6.44	112	1238	6.59	128	1246	6.74	144	1254	6.89	
309 76.8	93	1227	6.51	110	1236	6.66	126	1244	6.82	142	1253	6.97	
308 75.7	91	1226	6.59	108	1235	6.74	124	1243	6.89	140	1251	7.05	
307 74.6	89	1225	6.67	106	1234	6.81	122	1242	6.97	138	1250	7.13	
306 73.5	88	1224	6.74	104	1232	6.89	120	1240	7.05	136	1249	7.21	
305 72.4	86	1222	6.82	102	1231	6.97	118	1239	7.14	134	1247	7.29	
304 71.4	84	1221	6.90	100	1229	7.05	116	1238	7.22	132	1246	7.38	
303 70.3	82	1220	6.98	98	1228	7.14	114	1236	7.30	130	1245	7.46	
302 69.3	80	1218	7.06	96	1227	7.22	112	1235	7.38	128	1243	7.54	
301 68.2	78	1217	7.14	94	1225	7.30	110	1233	7.47	126	1242	7.63	
300 67.2	76	1215	7.23	92	1224	7.39	108	1232	7.55	124	1240	7.73	
299 66.2	74	1214	7.31	90	1222	7.48	106	1231	7.64	122	1239	7.82	
298 65.2	72	1213	7.39	88	1221	7.57	104	1229	7.73	119	1237	7.90	
297 64.3	71	1212	7.48	86	1220	7.65	102	1228	7.82	117	1236	7.99	
296 63.3	69	1210	7.57	85	1219	7.74	100	1227	7.91	115	1235	8.09	
295 62.3	67	1209	7.66	83	1218	7.83	98	1225	8.00	113	1233	8.19	
294 61.4	65	1208	7.75	81	1216	7.92	96	1224	8.09	111	1232	8.28	
293 60.5	63	1206	7.84	79	1215	8.01	94	1223	8.18	109	1230	8.38	
292 59.5	61	1205	7.93	77	1213	8.10	92	1221	8.28	107	1229	8.47	
291 58.6	59	1204	8.03	75	1212	8.20	90	1220	8.38	105	1228	8.57	
290 57.7	58	1203	8.13	73	1210	8.30	88	1218	8.48	103	1226	8.67	
289 56.8	56	1201	8.22	71	1209	8.40	86	1217	8.58	101	1225	8.77	
288 56.0	54	1200	8.32	69	1208	8.50	84	1216	8.68	99	1223	8.87	
287 55.1	52	1198	8.42	67	1206	8.60	82	1214	8.79	97	1222	8.98	
286 54.2	50	1197	8.51	65	1205	8.70	80	1213	8.89	95	1221	9.10	
285 53.4	48	1196	8.61	63	1204	8.81	78	1212	9.00	93	1219	9.21	
284 52.6	46	1194	8.72	61	1202	8.91	76	1210	9.10	91	1218	9.32	
283 51.7	45	1193	8.83	60	1201	9.02	74	1209	9.22	89	1216	9.43	
282 50.9	43	1192	8.94	58	1200	9.14	72	1207	9.33	87	1215	9.54	
281 50.1	41	1191	9.05	56	1199	9.25	70	1206	9.44	85	1214	9.65	
280 49.33	39	1189	9.16	54	1197	9.36	68	1205	9.55	83	1212	9.77	
279 48.55	37	1188	9.27	52	1196	9.47	66	1203	9.67	81	1211	9.89	
278 47.77	35	1186	9.38	50	1194	9.59	64	1202	9.78	79	1210	10.02	
277 47.01	33	1185	9.50	48	1193	9.70	62	1200	9.90	76	1208	10.14	

TEMPERATURE-ENTROPY TABLE

109

Temperature, Degrees Fahr.	Pressure, Pounds per Square inch.	1-72				1-73				1-74				1-75			
		Quality	Heat Con- tent	Specific Volume													
324 95.1	195	1284	6.05	215	1294	6.19	238	1305	6.33	260	1315	6.46					
323 93.8	193	1283	6.11	213	1293	6.26	236	1304	6.40	257	1313	6.53					
322 92.5	191	1282	6.18	210	1291	6.33	233	1302	6.46	255	1312	6.60					
321 91.2	189	1280	6.25	208	1290	6.40	231	1300	6.53	252	1311	6.67					
320 90.0	187	1279	6.32	206	1288	6.46	229	1299	6.60	250	1309	6.75					
319 88.7	185	1278	6.39	204	1287	6.53	226	1297	6.67	248	1308	6.82					
318 87.4	182	1276	6.45	201	1285	6.60	224	1296	6.75	245	1306	6.89					
317 86.2	180	1274	6.53	199	1284	6.67	222	1295	6.83	243	1304	6.97					
316 85.0	178	1273	6.60	197	1283	6.75	219	1293	6.90	240	1303	7.05					
315 83.8	176	1272	6.67	194	1281	6.82	217	1291	6.98	238	1301	7.13					
314 82.6	174	1270	6.75	192	1279	6.90	215	1280	7.06	235	1299	7.20					
313 81.4	172	1269	6.82	190	1278	6.97	212	1288	7.14	233	1298	7.29					
312 80.2	170	1268	6.90	188	1277	7.05	210	1287	7.22	231	1297	7.37					
311 79.1	168	1267	6.97	185	1275	7.13	208	1286	7.30	228	1295	7.45					
310 77.9	166	1265	7.05	183	1274	7.20	205	1284	7.38	226	1294	7.54					
309 76.8	163	1263	7.13	181	1272	7.29	203	1283	7.46	224	1293	7.62					
308 75.7	161	1262	7.20	179	1271	7.37	201	1281	7.54	221	1291	7.71					
307 74.6	159	1261	7.29	176	1269	7.45	198	1279	7.63	219	1289	7.80					
306 73.5	157	1259	7.37	174	1267	7.53	196	1278	7.72	216	1287	7.89					
305 72.4	154	1257	7.46	172	1266	7.62	194	1277	7.80	214	1286	7.98					
304 71.4	152	1256	7.54	170	1265	7.70	191	1275	7.89	211	1284	8.07					
303 70.3	150	1255	7.63	167	1263	7.79	189	1273	7.98	209	1283	8.16					
302 69.3	148	1253	7.71	165	1262	7.88	186	1271	8.07	207	1282	8.25					
301 68.2	146	1252	7.80	163	1260	7.97	184	1270	8.16	204	1280	8.35					
300 67.2	144	1250	7.89	161	1259	8.06	182	1269	8.25	202	1279	8.44					
299 66.2	141	1248	7.99	158	1257	8.16	180	1258	8.35	199	1277	8.54					
298 65.2	139	1247	8.08	156	1255	8.25	177	1266	8.44	197	1275	8.64					
297 64.3	137	1246	8.17	154	1254	8.34	175	1264	8.54	195	1274	8.74					
296 63.3	135	1244	8.26	151	1252	8.43	173	1263	8.64	192	1272	8.84					
295 62.3	133	1243	8.36	149	1251	8.53	170	1261	8.74	190	1271	8.94					
294 61.4	131	1242	8.46	147	1249	8.63	168	1260	8.85	187	1269	9.05					
293 60.5	128	1240	8.56	145	1248	8.74	165	1258	8.95	185	1268	9.15					
292 59.5	126	1238	8.66	143	1247	8.84	163	1257	9.05	183	1266	9.27					
291 58.6	124	1237	8.76	140	1245	8.95	161	1255	9.16	180	1264	9.38					
290 57.7	122	1236	8.86	138	1244	9.05	158	1253	9.27	178	1263	9.49					
289 56.8	120	1234	8.96	136	1242	9.16	156	1252	9.38	175	1261	9.60					
288 56.0	118	1233	9.06	134	1241	9.27	154	1251	9.50	173	1260	9.71					
287 55.1	116	1232	9.18	132	1240	9.38	151	1249	9.61	170	1258	9.82					
286 54.2	113	1230	9.29	129	1238	9.50	149	1247	9.72	168	1257	9.93					
285 53.4	111	1228	9.40	127	1236	9.61	147	1246	9.84	166	1255	10.05					
284 52.6	109	1227	9.51	125	1235	9.72	144	1244	9.95	163	1253	10.18					
283 51.7	107	1226	9.63	123	1234	9.84	142	1243	10.07	161	1252	10.30					
282 50.9	105	1224	9.74	120	1232	9.96	140	1242	10.20	158	1250	10.43					
281 50.1	103	1223	9.86	118	1230	10.09	137	1240	10.33	156	1249	10.55					
280 49.3	101	1222	9.98	116	1229	10.21	135	1238	10.46	153	1247	10.67					
279 48.5	98	1220	10.10	114	1228	10.33	133	1237	10.58	151	1246	10.80					
278 47.7	96	1218	10.23	112	1226	10.46	130	1235	10.71	149	1245	10.95					
277 47.0	94	1217	10.36	109	1224	10.59	128	1234	10.84	146	1243	11.06					

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr. Pressure, Pounds per Square Inch.	1.68			1.69			1.70			1.71		
	Quality.	Heat Con- tents.	Specific Volume.									
276 46.26	32	1184	9.62	46	1192	9.83	60	1199	10.04	74	1206	10.26
275 45.52	30	1183	9.74	44	1190	9.95	58	1198	10.15	72	1205	10.49
274 44.78	28	1181	9.86	42	1189	10.07	56	1196	10.28	70	1203	10.51
273 44.06	26	1180	9.98	41	1188	10.20	54	1195	10.40	68	1202	10.64
272 43.35	24	1178	10.10	39	1187	10.33	52	1193	10.54	66	1201	10.77
271 42.64	22	1177	10.23	37	1185	10.47	50	1192	10.67	64	1199	10.91
270 41.95	21	1176	10.36	35	1184	10.60	49	1191	10.80	62	1198	11.05
269 41.26	19	1175	10.50	33	1182	10.73	47	1190	10.94	60	1197	11.19
268 40.58	17	1173	10.64	31	1181	10.87	45	1188	11.08	58	1195	11.33
267 39.91	15	1172	10.76	29	1179	11.00	43	1187	11.22	56	1194	11.47
266 39.26	13	1170	10.90	27	1178	11.15	41	1186	11.37	54	1192	11.62
265 38.60	11	1169	11.05	25	1177	11.30	39	1184	11.52	52	1191	11.77
264 37.96	10	1168	11.19	23	1175	11.45	37	1183	11.67	50	1190	11.92
263 37.33	8	1167	11.33	21	1174	11.59	35	1181	11.81	49	1189	12.08
262 36.71	6	1165	11.48	20	1173	11.74	33	1180	11.96	47	1188	12.23
261 36.09	4	1164	11.63	18	1172	11.89	31	1178	12.12	45	1186	12.39
260 35.48	2	1162	11.78	16	1170	12.04	29	1177	12.27	43	1185	12.56
259 34.88	0	1161	11.93	14	1169	12.20	27	1176	12.45	41	1183	12.72
258 34.29	9992	1159.9	11.99	12	1167	12.36	25	1174	12.60	39	1182	12.89
257 33.71	9982	1158.6	12.17	10	1166	12.52	23	1173	12.78	37	1181	13.06
256 33.14	9972	1157.3	12.35	8	1164	12.69	21	1172	12.96	35	1179	13.24
255 32.57	9960	1156.0	12.55	6	1163	12.85	20	1171	13.14	33	1178	13.42
254 32.01	9949	1154.6	12.74	4	1161	13.02	18	1169	13.30	31	1177	13.60
253 31.46	9938	1153.4	12.94	2	1160	13.20	16	1168	13.49	29	1176	13.79
252 30.92	9928	1152.1	13.15	0	1159	13.37	14	1167	13.66	27	1174	13.96
251 30.38	9918	1150.8	13.35	9993	1157.8	13.45	12	1165	13.85	25	1172	14.16
250 29.86	9907	1149.5	13.55	9982	1156.5	13.66	10	1164	14.05	23	1171	14.35
249 29.34	9896	1148.2	13.77	9971	1155.2	13.87	8	1162	14.25	21	1170	14.55
248 28.82	9885	1146.8	13.98	9960	1153.9	14.08	6	1161	14.45	19	1168	14.75
247 28.32	9875	1145.5	14.19	9950	1152.6	14.30	4	1160	14.64	17	1167	14.94
246 27.82	9864	1144.2	14.41	9939	1151.3	14.52	2	1158	14.84	15	1165	15.15
245 27.33	9853	1142.9	14.63	9928	1150.0	14.74	0	1157	15.04	13	1164	15.35
244 26.85	9843	1141.6	14.87	9918	1148.6	14.99	9992	1155.7	15.10	12	1163	15.57
243 26.37	9832	1140.3	15.11	9907	1147.3	15.23	9981	1154.4	15.34	10	1162	15.79
242 25.90	9822	1139.0	15.35	9896	1146.0	15.47	9971	1153.0	15.58	8	1160	16.00
241 25.44	9811	1137.7	15.60	9885	1144.7	15.72	9959	1151.7	15.84	6	1159	16.23
240 24.98	9801	1136.3	15.85	9875	1143.3	15.97	9949	1150.3	16.09	4	1157	16.45
239 24.53	9790	1135.0	16.10	9864	1142.0	16.23	9938	1149.0	16.35	2	1156	16.69
238 24.09	9780	1133.6	16.37	9854	1140.6	16.49	9927	1147.6	16.62	0	1155	16.91
237 23.66	9769	1132.3	16.64	9842	1139.3	16.76	9916	1146.3	16.89	9989	1153.3	17.01
236 23.23	9759	1131.0	16.91	9832	1138.0	17.04	9905	1144.9	17.17	9979	1151.9	17.29
235 22.80	9748	1129.7	17.19	9821	1136.6	17.31	9894	1143.5	17.44	9967	1150.5	17.57
234 22.39	9737	1128.3	17.47	9810	1135.2	17.60	9882	1142.1	17.73	9955	1149.1	17.86
233 21.98	9726	1127.0	17.76	9799	1133.9	17.89	9872	1140.8	18.03	9945	1147.7	18.16
232 21.57	9715	1125.6	18.05	9788	1132.5	18.19	9861	1139.4	18.32	9933	1146.3	18.46
231 21.18	9705	1124.3	18.35	9777	1131.2	18.49	9850	1138.1	18.63	9922	1145.0	18.76
230 20.78	9695	1123.0	18.65	9767	1129.9	18.79	9839	1136.8	18.93	9912	1143.7	19.07
229 20.40	9684	1121.6	18.96	9756	1128.5	19.10	9828	1135.4	19.24	9900	1142.3	19.38

TEMPERATURE-ENTROPY TABLE.

111

Temperature Degrees Fahr.	Pressure, Pounds per Square inch	1.72			1.73			1.74			1.75		
		Quality	Heat Capa- city	Specific Volume									
276.46 26 92	1216	10.48	107	1223	10.72	126	1233	10.97	144	1241	11.20		
276.45 52 90	1214	10.60	105	1222	10.86	123	1231	11.10	141	1239	11.34		
276.44 78 88	1213	10.74	103	1220	11.08	121	1229	11.24	139	1238	11.49		
273.44 66 86	1212	10.87	101	1219	11.12	119	1228	11.39	137	1237	11.63		
272.43 55 83	1210	11.00	99	1218	11.26	116	1226	11.51	134	1235	11.77		
271.42 64 81	1208	11.15	96	1216	11.40	114	1225	11.66	132	1234	11.91		
270.41 95 79	1207	11.29	94	1214	11.54	112	1224	11.80	129	1232	12.06		
269.41 26 77	1206	11.43	92	1213	11.69	109	1222	11.94	127	1231	12.20		
268.40 58 75	1204	11.57	90	1212	11.84	107	1220	12.10	124	1229	12.36		
267.49 91 73	1203	11.72	88	1210	11.99	105	1219	12.25	122	1227	12.52		
266.49 26 71	1202	11.87	86	1209	12.14	102	1217	12.40	120	1226	12.68		
265.48 60 69	1200	12.03	83	1207	12.30	100	1216	12.56	117	1224	12.84		
264.47 96 67	1199	12.19	81	1206	12.45	98	1214	12.71	115	1223	13.00		
263.47 33 65	1197	12.34	79	1204	12.60	95	1212	12.88	113	1222	13.15		
262.46 71 62	1195	12.50	77	1203	12.77	93	1211	13.04	110	1220	13.32		
261.46 09 60	1194	12.67	75	1202	12.94	91	1210	13.20	108	1218	13.49		
260.45 48 58	1193	12.84	73	1200	13.10	88	1208	13.38	105	1217	13.66		
259.44 88 56	1191	13.00	70	1198	13.28	86	1207	13.55	103	1215	13.84		
258.44 29 54	1190	13.18	68	1197	13.45	84	1205	13.73	101	1214	14.01		
257.43 71 52	1189	13.35	66	1196	13.62	81	1203	13.90	98	1212	14.20		
256.43 14 50	1187	13.54	64	1194	13.80	79	1202	14.09	96	1211	14.38		
255.42 57 48	1186	13.70	62	1193	13.99	77	1201	14.28	93	1209	14.56		
254.42 01 46	1184	13.90	60	1192	14.17	74	1199	14.46	91	1208	14.57		
253.41 46 44	1183	14.09	58	1190	14.35	72	1197	14.65	89	1206	14.94		
252.40 92 42	1182	14.28	55	1188	14.54	70	1196	14.83	86	1204	15.12		
251.40 38 40	1180	14.46	53	1187	14.73	68	1195	15.03	84	1203	15.33		
250.40 86 37	1178	14.66	51	1186	14.93	65	1193	15.24	81	1201	15.54		
249.40 34 35	1177	14.86	49	1184	15.12	63	1191	15.45	79	1200	15.75		
248.40 82 33	1176	15.05	47	1183	15.33	61	1190	15.65	77	1199	15.95		
247.40 32 31	1174	15.27	45	1182	15.54	59	1189	15.86	74	1197	16.18		
246.40 82 29	1173	15.48	43	1180	15.75	57	1188	16.08	72	1195	16.30		
245.40 33 27	1172	15.69	41	1179	15.95	54	1186	16.30	70	1194	16.56		
244.40 85 25	1170	15.90	39	1177	16.18	52	1184	16.51	67	1192	16.84		
243.40 37 23	1169	16.11	36	1175	16.40	50	1183	16.75	65	1191	17.07		
242.40 90 21	1167	16.33	34	1174	16.62	48	1181	16.98	62	1189	17.39		
241.40 44 19	1166	16.55	32	1173	16.85	46	1180	17.21	60	1188	17.54		
240.40 98 17	1165	16.78	30	1171	17.08	44	1179	17.45	58	1186	17.80		
239.40 53 15	1163	17.00	28	1170	17.32	42	1177	17.70	56	1185	18.04		
238.40 09 13	1162	17.24	26	1169	17.57	39	1175	17.95	53	1183	18.30		
237.40 66 11	1160	17.48	24	1167	17.81	37	1174	18.20	51	1182	18.55		
236.40 23 9	1159	17.71	22	1166	18.06	35	1173	18.46	49	1180	18.80		
235.40 80 7	1158	17.97	20	1165	18.32	33	1172	18.72	46	1178	19.08		
234.40 39 5	1156	18.21	18	1163	18.59	31	1170	18.99	44	1177	19.35		
233.40 98 3	1155	18.49	16	1162	18.85	29	1169	19.24	42	1176	19.62		
232.40 57 1	1153	18.75	14	1160	19.12	27	1148	19.50	40	1174	19.90		
231.40 18 0.9995	1151.9	18.90	12	1159	19.40	25	1166	19.77	37	1172	20.18		
230.40 78 0.9984	1150.6	19.21	10	1158	19.66	23	1163	20.05	35	1171	20.47		
229.40 40 0.9972	1149.1	19.53	8	1156	19.95	21	1163	20.34	33	1170	20.75		

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr. 1.68	Pressure, Pounds per Square Inch.	1.68			1.69			1.70			1.71		
		Quality.	Heat Con- tents.	Specific Volume.	Quality.	Heat Con- tents.	Specific Volume.	Quality.	Heat Con- tents.	Specific Volume.	Quality.	Heat Con- tents.	Specific Volume.
228 20.02	9673	1120.2 19.28	9744	1127.1 19.42	9816	1134.0 19.56	9888	1140.8 19.71					
227 19.64	9662	1118.9 19.60	9734	1125.8 19.75	9805	1132.7 19.90	9877	1139.5 20.04					
226 19.28	9651	1117.6 19.95	9723	1124.4 20.10	9795	1131.3 20.25	9866	1138.1 20.39					
225 18.91	9640	1116.3 20.28	9712	1123.1 20.43	9783	1129.9 20.58	9855	1136.8 20.73					
224 18.56	9630	1114.9 20.63	9701	1121.7 20.78	9773	1128.5 20.93	9844	1135.4 21.09					
223 18.21	9620	1113.6 20.98	9691	1120.4 21.14	9762	1127.2 21.29	9833	1134.0 21.45					
222 17.86	9609	1112.2 21.33	9680	1119.0 21.49	9751	1125.8 21.65	9822	1132.6 21.81					
221 17.52	9600	1110.9 21.70	9670	1117.7 21.86	9741	1124.5 22.03	9812	1131.3 22.19					
220 17.19	9589	1109.5 22.08	9660	1116.3 22.25	9731	1123.1 22.41	9801	1129.9 22.57					
219 16.86	9578	1108.1 22.47	9648	1114.9 22.64	9719	1121.7 22.80	9790	1128.5 22.97					
218 16.53	9566	1106.7 22.86	9637	1113.5 23.03	9707	1120.3 23.20	9778	1127.0 23.37					
217 16.21	9556	1105.4 23.26	9626	1112.1 23.43	9696	1118.9 23.60	9767	1125.6 23.77					
216 15.90	9545	1104.0 23.66	9615	1110.7 23.84	9686	1117.5 24.01	9756	1124.3 24.18					
215 15.59	9535	1102.7 24.08	9605	1109.4 24.25	9675	1116.2 24.43	9745	1122.9 24.61					
214 15.29	9524	1101.3 24.51	9594	1108.0 24.69	9664	1114.8 24.86	9734	1121.5 25.04					
213 14.99	9514	1100.0 24.94	9583	1106.7 25.12	9653	1113.4 25.30	9723	1120.1 25.48					
212 14.70	9503	1098.6 25.33	9573	1105.3 25.52	9642	1112.0 25.71	9711	1118.7 25.89					
211 14.41	9492	1097.3 25.73	9562	1103.9 25.92	9631	1110.6 26.11	9700	1117.3 26.30					
210 14.12	9482	1095.9 26.20	9551	1102.5 26.39	9620	1109.2 26.58	9689	1115.9 26.77					
209 13.84	9471	1094.4 26.67	9540	1101.1 26.86	9609	1107.8 27.06	9678	1114.5 27.25					
208 13.57	9460	1093.1 27.15	9529	1099.8 27.35	9598	1106.4 27.55	9667	1113.1 27.74					
207 13.29	9449	1091.7 27.65	9518	1098.4 27.85	9587	1105.0 28.05	9656	1111.7 28.25					
206 13.03	9439	1090.3 28.16	9507	1097.0 28.36	9576	1103.6 28.56	9644	1110.3 28.77					
205 12.77	9428	1088.9 28.66	9496	1095.6 28.87	9565	1102.2 29.08	9633	1108.9 29.29					
204 12.51	9417	1087.6 29.18	9486	1094.2 29.40	9554	1100.8 29.61	9622	1107.5 29.82					
203 12.25	9407	1086.2 29.72	9475	1092.8 29.93	9543	1099.4 30.15	9611	1106.1 30.36					
202 12.01	9397	1084.9 30.26	9464	1091.5 30.48	9532	1098.1 30.69	9600	1104.7 30.91					
201 11.76	9387	1083.5 30.83	9455	1090.1 31.05	9522	1096.7 31.27	9590	1103.3 31.49					
200 11.52	9376	1082.1 31.39	9444	1088.7 31.62	9511	1095.3 31.84	9579	1101.9 32.07					
199 11.28	9365	1080.7 31.97	9433	1087.3 32.20	9500	1093.8 32.43	9568	1100.4 32.66					
198 11.05	9355	1079.3 32.56	9422	1085.9 32.80	9490	1092.5 33.03	9557	1099.1 33.27					
197 10.82	9343	1077.8 33.17	9410	1084.4 33.41	9478	1091.0 33.65	9545	1097.5 33.88					
196 10.60	9332	1076.4 33.79	9399	1083.0 34.04	9466	1089.5 34.28	9533	1096.1 34.52					
195 10.38	9322	1075.1 34.44	9389	1081.6 34.68	9456	1088.2 34.93	9523	1094.7 35.18					
194 10.16	9311	1073.7 35.08	9378	1080.2 35.34	9445	1086.7 35.59	9511	1093.3 35.84					
193 9.95	9301	1072.3 35.75	9368	1078.8 36.01	9434	1085.4 36.26	9501	1091.9 36.52					
192 9.74	9290	1070.9 36.44	9357	1077.4 36.70	9423	1083.9 36.96	9489	1090.4 37.22					
191 9.53	9279	1069.5 37.13	9345	1076.0 37.39	9412	1082.5 37.66	9478	1089.0 37.92					
190 9.33	9269	1068.1 37.84	9335	1074.6 38.11	9401	1081.1 38.38	9467	1087.6 38.65					
189 9.13	9259	1066.8 38.57	9325	1073.2 38.85	9391	1079.7 39.12	9457	1086.2 39.40					
188 8.94	9248	1065.3 39.31	9313	1071.8 39.59	9379	1078.3 39.87	9445	1084.7 40.15					
187 8.75	9237	1063.9 40.07	9303	1070.4 40.36	9369	1076.9 40.64	9434	1083.3 40.93					
186 8.56	9226	1062.5 40.85	9292	1069.0 41.14	9357	1075.4 41.43	9423	1081.9 41.72					
185 8.37	9216	1061.1 41.66	9281	1067.6 41.95	9347	1074.0 42.25	9412	1080.5 42.54					
184 8.19	9205	1059.7 42.48	9270	1066.1 42.78	9335	1072.6 43.08	9401	1079.0 43.38					
183 8.01	9194	1058.3 43.31	9259	1064.7 43.62	9325	1071.2 43.93	9390	1077.6 44.23					
182 7.84	9184	1056.9 44.17	9249	1063.3 44.48	9314	1069.8 44.79	9379	1076.2 45.10					
181 7.67	9174	1055.4 45.04	9238	1061.8 45.36	9303	1068.2 45.68	9368	1074.7 46.00					

TEMPERATURE-ENTROPY TABLE

113

Temperature, Degrees Fahr.	Pressure, Pounds per Square inch	1.72			1.73			1.74			1.75		
		Quality	Heat Con- tent	Specific Volume	Quality	Heat Con- tent	Specific Volume	Quality	Heat Con- tent	Specific Volume	Quality	Heat Con- tent	Specific Volume
228 20.02	9960	1147.7 19.85	6	1155.20.21	18	1161.20.62	31	1168.21.05					
227 19.64	9949	1146.4 20.19	4	1153.20.52	16	1160.20.91	29	1167.21.35					
226 19.28	9938	1145.0 20.54	1	1151.20.82	14	1158.21.21	27	1166.21.66					
225 18.91	9926	1143.6 20.89	9988	1150.4 21.04	12	1157.21.52	25	1164.21.99					
224 18.56	9915	1142.2 21.24	9987	1149.0 21.39	10	1155.21.84	23	1163.22.37					
223 18.21	9904	1140.9 21.60	9975	1147.7 21.76	8	1154.22.16	20	1161.22.65					
222 17.86	9893	1139.5 21.96	9964	1146.3 22.12	6	1153.22.48	18	1159.22.98					
221 17.52	9883	1138.1 22.35	9954	1144.9 22.51	4	1151.22.81	16	1158.23.37					
220 17.19	9872	1136.7 22.74	9943	1143.5 22.90	2	1150.23.16	14	1157.23.66					
219 16.86	9860	1135.3 23.13	9931	1142.1 23.30	0	1149.23.50	12	1155.24.03					
218 16.53	9848	1133.8 23.54	9919	1140.6 23.71	9989	1147.3 23.87	10	1154.24.41					
217 16.21	9837	1132.4 23.94	9907	1139.2 24.11	9977	1145.9 24.29	8	1153.24.78					
216 15.90	9826	1131.0 24.36	9896	1137.8 24.53	9966	1144.5 24.71	6	1151.25.15					
215 15.59	9815	1129.6 24.78	9885	1136.4 24.96	9955	1143.1 25.14	4	1150.25.55					
214 15.29	9803	1128.2 25.22	9873	1135.0 25.40	9943	1141.7 25.58	2	1148.25.94					
213 14.99	9792	1126.8 25.67	9862	1133.6 25.85	9931	1140.3 26.03	0	1147.26.35					
212 14.70	9781	1125.4 26.08	9850	1132.2 26.26	9920	1138.9 26.45	9959	1145.6 26.63					
211 14.41	9770	1124.0 26.49	9839	1130.8 26.67	9908	1137.5 26.86	9975	1144.2 27.05					
210 14.12	9759	1122.6 26.96	9828	1129.3 27.15	9897	1136.0 27.35	9966	1142.7 27.54					
209 13.84	9747	1121.2 27.45	9816	1127.9 27.64	9885	1134.6 27.84	9954	1141.2 28.03					
208 13.57	9736	1119.8 27.94	9805	1126.5 28.14	9873	1133.1 28.34	9942	1139.8 28.53					
207 13.29	9724	1118.4 28.45	9793	1125.0 28.65	9862	1131.7 28.86	9930	1138.4 29.06					
206 13.03	9713	1116.9 28.97	9782	1123.6 29.18	9850	1130.3 29.38	9919	1136.9 29.59					
205 12.77	9702	1115.5 29.49	9770	1122.2 29.70	9839	1128.8 29.91	9907	1135.5 30.12					
204 12.51	9690	1114.1 30.03	9759	1120.7 30.24	9827	1127.4 30.45	9895	1134.0 30.67					
203 12.25	9679	1112.7 30.58	9747	1119.3 30.79	9815	1125.9 31.01	9883	1132.6 31.22					
202 12.01	9668	1111.3 31.13	9736	1117.9 31.35	9804	1124.5 31.57	9872	1131.2 31.79					
201 11.76	9658	1109.9 31.72	9726	1116.5 31.94	9794	1123.1 32.16	9861	1129.7 32.38					
200 11.52	9647	1108.4 32.30	9714	1115.0 32.52	9782	1121.8 32.75	9850	1128.2 32.98					
199 11.28	9635	1107.0 32.89	9703	1113.6 33.12	9770	1120.2 33.36	9838	1126.8 33.59					
198 11.05	9624	1105.6 33.50	9692	1112.2 33.74	9759	1118.8 33.97	9826	1125.4 34.21					
197 10.82	9612	1104.1 34.12	9679	1110.7 34.36	9746	1117.2 34.60	9814	1123.8 34.84					
196 10.60	9601	1102.6 34.76	9668	1109.2 35.01	9735	1115.8 35.25	9802	1122.3 35.49					
195 10.38	9590	1101.3 35.42	9657	1107.6 35.67	9724	1114.3 35.92	9790	1120.9 36.17					
194 10.16	9578	1099.8 36.09	9645	1106.3 36.34	9712	1112.9 36.59	9778	1119.4 36.85					
193 9.95	9567	1098.4 36.78	9634	1104.9 37.03	9701	1111.5 37.29	9767	1118.0 37.54					
192 9.74	9556	1097.0 37.48	9622	1103.5 37.74	9689	1110.0 38.00	9755	1116.5 38.26					
191 9.53	9544	1095.5 38.19	9611	1102.0 38.45	9677	1108.5 38.72	9743	1115.0 38.98					
190 9.33	9533	1094.1 38.92	9600	1100.6 39.19	9666	1107.1 39.46	9732	1113.6 39.73					
189 9.13	9523	1092.7 39.67	9589	1099.2 39.95	9655	1105.7 40.22	9721	1112.1 40.50					
188 8.94	9511	1091.2 40.43	9577	1097.7 40.71	9643	1104.2 40.99	9709	1110.6 41.27					
187 8.75	9500	1089.8 41.21	9566	1096.3 41.50	9631	1102.7 41.78	9697	1109.2 42.07					
186 8.56	9488	1088.3 42.01	9554	1094.8 42.31	9620	1101.2 42.60	9685	1107.7 42.89					
185 8.37	9477	1086.9 42.84	9543	1093.4 43.13	9608	1099.5 43.43	9674	1106.3 43.73					
184 8.19	9466	1085.4 43.68	9531	1091.9 43.99	9596	1098.3 44.29	9662	1104.7 44.59					
183 8.01	9455	1084.0 44.54	9520	1090.4 44.85	9585	1096.9 45.16	9650	1103.3 45.46					
182 7.84	9444	1082.6 45.42	9509	1089.0 45.73	9574	1095.4 46.04	9639	1101.8 46.35					
181 7.67	9433	1081.1 46.32	9498	1087.5 46.63	9562	1093.9 46.95	9627	1100.3 47.27					

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	1.68				1.69				1.70				1.71			
		Quality.	Heat Con- tents.	Specific Volume.													
180 7.50	9162	1054.0	45.94	9227	1060.4	46.26	9292	1066.8	46.59	9356	1073.2	46.91					
179 7.34	9152	1052.6	46.85	9216	1059.0	47.18	9281	1065.4	47.51	9346	1071.7	47.84					
178 7.17	9141	1051.2	47.78	9206	1057.6	48.12	9270	1063.9	48.46	9335	1070.3	48.79					
177 7.01	9131	1049.8	48.75	9195	1056.1	49.09	9259	1062.5	49.44	9324	1068.9	49.78					
176 6.86	9120	1048.3	49.74	9184	1054.7	50.09	9248	1061.0	50.44	9312	1067.4	50.79					
175 6.70	9109	1046.9	50.74	9173	1053.3	51.09	9237	1059.6	51.45	9301	1065.9	51.81					
174 6.55	9099	1045.5	51.77	9162	1051.8	52.13	9226	1058.2	52.50	9290	1064.5	52.86					
173 6.41	9088	1044.1	52.83	9152	1050.4	53.20	9215	1056.7	53.57	9279	1063.1	53.94					
172 6.26	9077	1042.7	53.91	9141	1049.0	54.29	9205	1055.3	54.67	9268	1061.6	55.04					
171 6.12	9066	1041.2	55.00	9130	1047.5	55.39	9193	1053.8	55.77	9256	1060.1	56.16					
170 5.98	9056	1039.8	56.14	9119	1046.1	56.54	9182	1052.3	56.93	9245	1058.6	57.32					
169 5.84	9045	1038.3	57.32	9108	1044.6	57.72	9171	1050.9	58.12	9234	1057.2	58.52					
168 5.71	9034	1036.9	58.52	9097	1043.2	58.92	9160	1049.5	59.33	9223	1055.7	59.74					
167 5.58	9024	1035.5	59.75	9086	1041.7	60.16	9149	1048.0	60.58	9212	1054.3	60.99					
166 5.45	9013	1034.0	60.99	9076	1040.3	61.41	9138	1046.5	61.84	9201	1052.8	62.26					
165 5.32	9002	1032.6	62.27	9065	1038.8	62.70	9127	1045.1	63.13	9190	1051.3	63.57					
164 5.20	8991	1031.1	63.59	9054	1037.4	64.03	9116	1043.6	64.47	9179	1049.9	64.91					
163 5.08	8981	1029.7	64.93	9043	1035.9	65.38	9105	1042.2	65.83	9167	1048.4	66.28					
162 4.960	8970	1028.3	66.32	9032	1034.5	66.77	9094	1040.7	67.23	9156	1046.9	67.69					
161 4.844	8961	1026.9	67.74	9023	1033.1	68.21	9085	1039.3	68.68	9146	1045.5	69.15					
160 4.729	8950	1025.4	69.19	9012	1031.6	69.67	9073	1037.8	70.15	9135	1040.0	70.62					
159 4.617	8939	1023.9	70.68	9001	1030.1	71.17	9062	1036.3	71.66	9124	1042.5	72.14					
158 4.508	8928	1022.5	72.21	8990	1028.7	72.71	9051	1034.8	73.21	9113	1041.0	73.70					
157 4.400	8918	1021.1	73.79	8979	1027.2	74.30	9041	1033.4	74.80	9102	1039.6	75.31					
156 4.295	8907	1019.6	75.41	8968	1025.8	75.93	9030	1031.9	76.44	9091	1038.1	76.96					
155 4.191	8896	1018.1	77.05	8957	1024.3	77.58	9018	1030.4	78.11	9079	1036.6	78.64					
154 4.090	8885	1016.7	78.74	8946	1022.8	79.28	9007	1028.9	79.82	9068	1035.1	80.36					
153 3.991	8875	1015.2	80.48	8936	1021.4	81.03	8997	1027.5	81.58	9057	1033.6	82.13					
152 3.894	8864	1013.8	82.27	8925	1019.9	82.83	8985	1026.0	83.39	9046	1032.1	83.96					
151 3.799	8853	1012.3	84.10	8914	1018.4	84.67	8974	1024.5	85.25	9035	1030.6	85.82					
150 3.706	8843	1010.8	85.99	8903	1017.0	86.57	8964	1023.0	87.16	9024	1029.1	87.75					
149 3.615	8832	1009.4	87.91	8892	1015.4	88.51	8952	1021.5	89.11	9012	1027.6	89.71					
148 3.526	8821	1007.9	89.89	8881	1014.0	90.50	8942	1020.1	91.11	9002	1026.2	91.73					
147 3.439	8810	1006.4	91.89	8870	1012.5	92.52	8930	1018.6	93.14	8990	1024.6	93.77					
146 3.353	8800	1005.0	93.98	8860	1011.0	94.62	8920	1017.1	95.26	8979	1023.2	95.90					
145 3.270	8789	1003.5	96.15	8849	1009.5	96.81	8908	1015.6	97.46	8968	1021.6	98.11					
144 3.188	8778	1002.0	98.32	8838	1008.1	98.99	8897	1014.1	99.65	8957	1020.1	100.3					
143 3.108	8767	1000.5	100.6	8827	1006.6	101.2	8886	1012.6	101.9	8945	1018.6	102.6					
142 3.029	8757	999.1	102.9	8816	1005.1	103.6	8875	1011.1	104.3	8935	1017.1	105.0					
141 2.953	8747	997.6	105.3	8806	1003.6	106.0	8865	1009.6	106.7	8924	1015.6	107.5					
140 2.877	8736	996.1	107.8	8795	1002.1	108.5	8854	1008.1	109.3	8913	1014.1	110.0					
139 2.804	8725	994.6	110.4	8784	1000.6	111.1	8843	1006.6	111.9	8902	1012.6	112.6					
138 2.732	8715	993.2	112.9	8774	999.1	113.7	8832	1005.1	114.5	8891	1011.1	115.2					
137 2.662	8704	991.6	115.6	8762	997.6	116.4	8821	1003.6	117.1	8879	1009.5	117.9					
136 2.593	8693	990.2	118.3	8751	996.1	119.1	8810	1002.1	119.9	8868	1008.0	120.7					
135 2.526	8682	988.7	121.1	8741	994.6	121.9	8799	1000.6	122.7	8857	1006.5	123.6					
134 2.460	8671	987.1	124.1	8729	993.1	124.9	8787	999.0	125.7	8846	1005.0	126.6					
133 2.396	8660	985.7	127.0	8718	991.6	127.9	8776	997.5	128.7	8834	1003.4	129.6					

TEMPERATURE-ENTROPY TABLE

115

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	1.72		1.73		1.74		1.75				
		Quality	Heat Con- tents	Specific Volume	Quality	Heat Con- tents	Specific Volume	Quality	Heat Con- tents	Specific Volume		
180 7.50	9421	1079.6	47.24	9486	1086.0	47.56	9550	1092.4	47.89	9615	1098.7	48.21
179 7.34	9410	1078.1	48.17	9475	1084.5	48.50	9539	1090.9	48.81	9604	1097.3	49.16
178 7.17	9399	1076.7	49.13	9463	1083.1	49.46	9528	1089.4	49.80	9592	1095.8	50.14
177 7.01	9388	1075.2	50.12	9452	1081.6	50.46	9516	1088.0	50.81	9581	1094.3	51.15
176 6.86	9376	1073.7	51.14	9440	1080.1	51.49	9504	1086.4	51.84	9568	1092.8	52.19
175 6.70	9365	1072.3	52.16	9429	1078.6	52.52	9493	1085.0	52.88	9557	1091.3	53.23
174 6.55	9354	1070.8	53.22	9418	1077.2	53.59	9481	1083.5	53.95	9545	1089.8	54.31
173 6.41	9343	1069.4	54.31	9406	1075.7	54.65	9470	1082.0	55.05	9534	1088.4	55.42
172 6.26	9332	1067.9	55.42	9395	1074.2	55.80	9459	1080.6	56.17	9522	1086.9	56.55
171 6.12	9320	1066.4	56.54	9383	1072.7	56.93	9446	1079.0	57.31	9510	1085.3	57.70
170 5.98	9308	1064.9	57.71	9372	1071.2	58.10	9425	1077.5	58.50	9495	1083.8	58.89
169 5.84	9297	1063.5	58.92	9360	1069.8	59.32	9423	1076.0	59.72	9486	1082.3	60.12
168 5.71	9286	1062.0	60.15	9349	1068.3	60.55	9412	1074.6	60.96	9475	1060.8	61.37
167 5.58	9275	1060.5	61.41	9339	1066.8	61.82	9390	1073.1	62.24	9463	1079.3	62.66
166 5.45	9263	1059.1	62.69	9326	1065.3	63.11	9389	1071.6	63.53	9451	1077.8	63.96
165 5.32	9252	1057.6	64.00	9315	1063.8	64.43	9377	1070.1	64.86	9440	1076.3	65.29
164 5.20	9241	1056.1	65.35	9303	1062.3	65.79	9366	1068.6	66.23	9428	1074.8	66.67
163 5.08	9230	1054.6	66.73	9292	1060.8	67.18	9354	1067.1	67.63	9416	1073.3	68.08
162 4.960	9218	1053.1	68.15	9280	1059.3	68.61	9342	1065.5	69.07	9404	1071.8	69.53
161 4.844	9208	1051.7	69.62	9270	1057.9	70.08	9332	1064.1	70.55	9394	1070.3	71.02
160 4.729	9197	1050.2	71.10	9259	1056.4	71.58	9321	1062.6	72.06	9382	1068.8	72.54
159 4.617	9185	1048.7	72.63	9247	1054.9	73.12	9309	1061.1	73.61	9371	1067.2	74.00
158 4.508	9174	1047.2	74.20	9236	1053.4	74.70	9297	1059.5	75.20	9359	1065.7	75.49
157 4.400	9163	1045.7	75.82	9224	1051.9	76.33	9286	1058.1	76.83	9345	1064.2	77.34
156 4.295	9152	1044.2	77.48	9213	1050.4	78.00	9274	1056.5	78.52	9336	1062.7	79.04
155 4.191	9141	1042.7	79.17	9202	1048.9	79.79	9263	1055.0	80.22	9324	1061.2	80.55
154 4.090	9129	1041.2	80.90	9190	1047.3	81.44	9251	1053.5	81.98	9312	1059.6	82.52
153 3.991	9118	1039.7	82.68	9179	1045.9	83.24	9240	1052.0	83.79	9301	1058.1	84.34
152 3.894	9107	1038.2	84.52	9167	1041.3	85.08	9228	1050.5	85.64	9289	1056.6	86.21
151 3.799	9095	1036.7	86.40	9156	1042.8	86.97	9216	1048.9	87.54	9277	1055.0	88.12
150 3.706	9084	1035.2	88.34	9145	1041.3	88.92	9205	1047.4	89.51	9265	1053.5	90.19
149 3.615	9073	1033.7	90.31	9133	1039.8	90.91	9193	1045.9	91.51	9253	1052.0	92.11
148 3.526	9062	1032.2	92.34	9122	1038.3	92.95	9182	1044.4	93.56	9242	1050.5	94.18
147 3.439	9050	1030.7	94.39	9110	1036.8	95.02	9170	1042.8	95.64	9230	1048.9	96.27
146 3.353	9039	1029.2	96.54	9099	1035.3	97.15	9189	1041.3	97.82	9219	1047.4	98.45
145 3.270	9028	1027.7	98.76	9087	1033.7	99.42	9147	1039.8	100.1	9207	1045.8	100.7
144 3.188	9016	1026.2	101.0	9076	1032.2	101.7	9136	1038.3	102.3	9195	1044.3	103.0
143 3.108	9005	1024.6	103.3	9064	1030.7	104.0	9134	1036.7	104.6	9183	1042.7	105.3
142 3.029	8994	1023.1	105.7	9053	1029.2	106.4	9112	1035.2	107.1	9171	1041.2	107.8
141 2.953	8984	1021.6	108.2	9043	1027.6	108.9	9102	1033.6	109.6	9161	1039.7	110.3
140 2.877	8972	1020.1	110.7	9031	1026.1	111.4	9090	1032.1	112.2	9149	1038.1	112.9
139 2.804	8961	1018.6	113.4	9020	1024.6	114.1	9075	1030.5	114.8	9137	1036.5	115.6
138 2.732	8950	1017.1	116.0	9008	1023.0	116.7	9067	1029.0	117.5	9126	1035.0	118.3
137 2.662	8938	1015.5	118.7	8996	1021.5	119.5	9055	1027.4	120.2	9114	1033.4	121.0
136 2.593	8927	1014.0	121.5	8985	1019.9	122.3	9043	1025.9	123.1	9102	1031.8	123.9
135 2.526	8915	1012.5	124.4	8974	1018.4	125.2	9032	1024.4	126.0	9090	1030.3	126.8
134 2.460	8904	1010.9	127.4	8962	1016.8	128.2	9030	1022.8	129.1	9075	1028.7	129.9
133 2.396	8892	1009.4	130.5	8950	1015.3	131.3	9008	1021.2	132.2	9066	1027.1	133.0

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr. Pressure, Pounds per Square Inch.	1.68				1.69				1.70				1.71			
	Quality.	Heat Con- tent.	Specific Volume.		Quality.	Heat Con- tent.	Specific Volume.		Quality.	Heat Con- tent.	Specific Volume.		Quality.	Heat Con- tent.	Specific Volume.	
132 2.333	8650	984.2	130.1	8708	990.1	131.0	8765	996.0	131.8	8823	1001.9	132.7				
131 2.272	8639	982.7	133.2	8697	988.6	134.1	8754	994.5	135.0	8812	1000.4	135.9				
130 2.212	8628	981.2	136.4	8686	987.1	137.3	8743	993.0	138.2	8801	998.9	139.1				
129 2.153	8618	979.7	139.8	8675	985.6	140.8	8732	991.5	141.7	8790	997.3	142.7				
128 2.096	8607	978.2	143.2	8664	984.1	144.2	8721	989.9	145.1	8779	995.8	146.1				
127 2.040	8596	976.7	146.7	8653	982.6	147.7	8710	988.4	148.7	8767	994.3	149.7				
126 1.985	8585	975.2	150.4	8642	981.0	151.4	8699	986.9	152.4	8756	992.7	153.4				
125 1.932	8574	973.5	154.2	8631	979.5	155.2	8688	985.4	156.2	8745	991.2	157.2				
124 1.880	8563	972.2	158.0	8620	978.0	159.0	8677	983.8	160.1	8734	989.7	161.1				
123 1.829	8553	970.7	161.9	8609	976.5	163.0	8666	982.3	164.0	8722	988.2	165.1				
122 1.779	8542	969.1	166.0	8598	974.9	167.1	8655	980.7	168.2	8711	986.6	169.3				
121 1.730	8532	967.6	170.2	8589	973.4	171.3	8645	979.2	172.5	8701	985.1	173.6				
120 1.683	8521	966.1	174.5	8577	971.9	175.7	8634	977.7	176.8	8690	983.5	178.0				
119 1.636	8510	964.6	179.0	8566	970.4	180.2	8623	976.2	181.3	8679	982.0	182.5				
118 1.591	8500	963.1	183.6	8556	968.9	184.8	8612	974.7	186.0	8668	980.4	187.2				
117 1.547	8489	961.6	188.3	8545	967.4	189.5	8601	973.1	190.8	8656	978.9	192.0				
116 1.504	8478	960.0	193.1	8533	965.8	194.4	8589	971.5	195.7	8645	977.3	196.9				
115 1.462	8467	958.5	198.1	8523	964.3	199.4	8579	970.0	200.7	8634	975.8	202.0				
114 1.421	8456	957.0	203.3	8512	962.7	204.6	8567	968.5	206.0	8623	974.2	207.3				
113 1.381	8445	955.5	208.6	8501	961.2	210.0	8556	967.0	211.3	8611	972.7	212.7				
112 1.342	8435	953.9	214.1	8490	959.7	215.5	8545	965.4	216.9	8600	971.1	218.3				
111 1.304	8424	952.4	219.8	8479	958.2	221.2	8534	963.9	222.6	8589	969.6	224.1				
110 1.266	8413	950.9	225.6	8468	956.6	227.0	8523	962.3	228.5	8578	968.8	230.0				
109 1.230	8402	949.4	231.6	8457	955.1	233.1	8512	960.7	234.6	8566	966.4	236.1				
108 1.195	8392	947.8	237.7	8446	953.5	239.3	8501	959.1	240.8	8555	964.8	242.4				
107 1.160	8380	946.3	244.0	8435	952.0	245.6	8489	957.6	247.2	8544	967.3	248.8				
106 1.127	8370	944.7	250.6	8424	950.4	252.2	8478	956.0	253.8	8533	961.7	255.5				
105 1.094	8359	943.2	257.5	8413	948.8	259.1	8467	954.5	260.8	8522	960.1	262.5				
104 1.062	8348	941.6	264.5	8402	947.2	266.2	8456	952.9	267.9	8510	958.5	269.6				
103 1.031	8337	940.1	271.7	8391	945.7	273.5	8445	951.4	275.2	8499	957.0	277.0				
102 1.000	8326	938.5	279.1	8380	944.1	280.9	8434	949.8	282.7	8488	955.4	284.5				
101 0.971	8316	937.0	286.8	8370	942.6	288.6	8424	948.2	290.5	8478	953.8	292.3				
100 0.942	8305	935.4	294.6	8359	941.0	296.5	8412	946.6	298.4	8466	952.2	300.3				
99 0.914	8294	933.9	302.9	8348	939.5	304.9	8401	945.0	306.8	8455	950.6	308.8				
98 0.887	8284	932.3	311.4	8337	937.9	313.4	8390	943.4	315.4	8444	949.0	317.4				
97 0.860	8273	930.8	320.1	8326	936.4	322.3	8379	941.9	324.2	8432	947.5	326.2				
96 0.834	8263	929.3	329.2	8316	934.8	331.3	8369	940.4	333.4	8422	946.0	335.5				
95 0.809	8252	927.8	338.5	8305	933.3	340.7	8358	938.8	342.8	8411	944.6	345.0				
94 0.784	8241	926.2	348.1	8294	931.7	350.3	8347	937.2	352.6	8399	942.8	354.8				
93 0.761	8230	924.6	358.0	8283	930.1	360.3	8335	935.7	362.6	8388	941.3	364.9				
92 0.737	8219	923.0	365.3	8272	928.5	370.7	8324	934.1	373.0	8377	939.6	375.4				
91 0.715	8208	921.5	379.0	8261	927.0	381.4	8313	932.5	383.8	8365	938.0	386.2				
90 0.693	8197	919.9	389.9	8250	925.4	392.3	8302	930.9	394.8	8354	936.4	397.3				
89 0.671	8186	918.3	401.1	8238	923.8	403.7	8291	929.3	406.2	8343	934.8	408.8				
88 0.650	8175	916.7	412.7	8227	922.2	415.3	8279	927.7	417.9	8331	933.1	420.6				
87 0.630	8165	915.2	424.9	8217	920.6	427.6	8269	926.1	430.3	8320	931.6	433.0				
86 0.610	8154	913.6	437.4	8206	919.0	440.1	8257	924.5	442.9	8309	930.0	445.7				
85 0.591	8143	912.0	450.3	8194	917.4	453.1	8246	922.9	456.0	8298	928.3	458.9				

TEMPERATURE-ENTROPY TABLE

117

Temperature Degrees Fahr.	Pressure, Pounds per Square Inch	1.72			1.73			1.74			1.75		
		Quality	Heat Con- tent	Specific Volume									
132 2 333	8881	1007.8	133.6	8939	1013.7	134.4	8997	1019.6	135.3	9055	1025.6	136.2	
131 2 272	8870	1006.3	136.8	8928	1012.2	137.7	8985	1018.1	138.6	9043	1024.0	139.4	
130 2 212	8859	1004.8	140.1	8916	1010.7	141.0	8974	1016.6	141.9	9031	1022.5	142.8	
129 2 153	8847	1003.2	143.6	8805	1009.1	144.5	8862	1015.0	145.5	9020	1020.9	146.4	
128 2 096	8836	1001.7	147.0	8803	1007.6	148.0	8851	1013.4	148.9	9008	1019.3	149.9	
127 2 040	8825	1000.2	150.6	8882	1006.1	151.6	8939	1011.9	152.6	8996	1017.8	153.6	
126 1 985	8813	998.6	154.4	8870	1004.5	155.4	8927	1010.3	156.4	8984	1016.2	157.4	
126 1 932	8802	997.1	158.3	8859	1003.0	159.3	8916	1008.8	160.3	8973	1014.7	161.3	
124 1 880	8791	995.5	162.2	8847	1001.3	163.2	8904	1007.2	164.2	8961	1013.0	165.3	
123 1 825	8779	994.0	166.2	8836	999.8	167.3	8892	1005.6	168.3	8949	1010.5	169.4	
122 1 771	8768	992.4	170.4	8824	998.2	171.5	8881	1004.0	172.6	8937	1009.8	173.6	
121 1 730	8758	990.9	174.7	8814	996.7	175.8	8870	1002.5	177.0	8927	1008.3	178.1	
120 1 682	8746	989.3	179.1	8802	995.1	180.3	8859	1000.9	181.4	8915	1006.7	182.6	
119 1 636	8735	987.8	183.7	8791	993.6	184.9	8847	999.4	186.1	8903	1005.1	187.2	
118 1 591	8724	986.2	188.4	8780	992.0	189.6	8836	997.8	190.9	8892	1003.5	192.1	
117 1 547	8712	984.6	193.2	8768	990.4	194.5	8824	996.2	195.7	8880	1001.9	197.0	
116 1 504	8700	983.0	198.2	8756	988.8	199.5	8812	994.6	200.7	8858	1000.3	202.0	
115 1 462	8690	981.5	203.3	8745	987.3	204.6	8801	993.0	205.9	8856	998.7	207.2	
114 1 421	8678	979.9	208.6	8734	985.7	210.0	8789	991.4	211.3	8844	997.1	212.6	
113 1 381	8667	978.4	214.1	8722	984.1	215.4	8777	989.8	216.8	8832	995.5	218.2	
112 1 342	8656	976.8	219.7	8711	982.5	221.1	8766	988.2	222.5	8821	993.8	223.9	
111 1 304	8644	975.3	225.5	8690	980.9	227.0	8754	986.6	228.4	8809	992.3	229.8	
110 1 266	8633	973.7	231.4	8688	979.3	232.9	8743	985.0	234.4	8797	990.7	235.9	
109 1 230	8621	972.1	237.6	8676	977.8	239.1	8731	983.4	240.6	8785	989.1	242.1	
108 1 195	8610	970.5	243.9	8665	976.2	245.5	8719	981.8	247.0	8774	987.5	248.6	
107 1 160	8598	968.9	250.4	8653	974.6	252.0	8707	980.2	253.6	8762	985.0	255.1	
106 1 127	8587	967.3	257.1	8641	973.0	258.7	8696	978.6	260.4	8750	984.3	262.0	
105 1 094	8576	965.7	264.1	8630	971.4	265.8	8684	977.0	267.5	8739	982.7	269.1	
104 1 062	8564	964.1	271.3	8618	969.8	273.0	8672	975.4	274.7	8726	981.0	276.5	
103 1 031	8553	962.6	278.7	8607	968.2	280.5	8661	973.8	282.3	8715	979.4	284.0	
102 1 000	8542	961.0	286.3	8596	966.6	288.1	8649	972.2	289.9	8703	977.8	291.7	
101 0 971	8531	959.4	294.2	8585	965.0	296.0	8639	970.6	297.9	8692	976.2	299.7	
100 0 942	8519	957.8	302.2	8573	963.4	304.1	8627	969.0	306.0	8680	974.6	307.9	
99 0 914	8508	956.2	310.7	8562	961.8	312.7	8615	967.4	314.6	8668	973.0	316.6	
98 0 887	8497	954.6	319.4	8550	960.2	321.4	8603	965.8	323.4	8657	971.3	325.4	
97 0 860	8486	953.1	328.3	8539	958.5	330.4	8592	964.2	332.4	8645	969.8	334.5	
96 0 834	8475	951.5	337.6	8528	957.0	339.8	8581	962.6	341.9	8634	968.2	344.0	
95 0 809	8464	949.9	347.2	8516	955.4	349.3	8569	961.0	351.5	8622	966.5	353.7	
94 0 784	8452	948.3	357.0	8505	953.8	359.2	8558	959.4	361.5	8611	964.9	363.7	
93 0 761	8441	946.7	367.2	8493	952.2	369.5	8546	957.8	371.8	8599	963.3	374.0	
92 0 737	8429	945.1	377.7	8482	950.6	380.1	8534	956.1	382.4	8587	961.6	384.8	
91 0 715	8418	943.5	388.7	8470	949.0	391.1	8523	954.5	393.5	8575	960.0	395.9	
90 0 693	8406	941.9	399.8	8459	947.4	402.3	8511	952.9	404.8	8563	958.3	407.3	
89 0 671	8395	940.3	411.3	8447	945.8	413.9	8499	951.3	416.5	8511	956.7	419.0	
88 0 650	8383	938.6	423.2	8435	944.1	425.8	8487	949.6	428.4	8539	955.0	431.1	
87 0 630	8372	937.0	435.7	8424	942.5	438.4	8476	948.0	441.1	8528	953.4	443.8	
86 0 610	8361	935.4	448.5	8413	940.9	451.2	8464	946.3	454.0	8516	951.8	456.8	
85 0 591	8349	933.8	461.7	8401	939.2	464.6	8452	944.7	467.4	8504	950.1	470.3	

TEMPERATURE-ENTROPY TABLE

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	1.76			1.77			1.78			1.79		
		Quality.	Heat Con- tent.	Specific Volume.									
324 95.1	282	1324	6.64
323 93.8	280	1323	6.70
322 92.5	277	1321	6.76	300	1330	6.93
321 91.2	275	1320	6.84	297	1328	7.00
320 90.0	272	1318	6.91	295	1327	7.07
319 88.7	270	1317	6.99	292	1325	7.14
318 87.4	267	1315	7.07	289	1323	7.22
317 86.2	265	1314	7.15	287	1322	7.30
316 85.0	262	1312	7.23	284	1321	7.38
315 83.8	260	1310	7.30	282	1319	7.47
314 82.6	257	1309	7.38	279	1318	7.55
313 81.4	255	1307	7.47	276	1316	7.64
312 80.2	252	1305	7.55	274	1315	7.72	298	1325	7.91
311 79.1	250	1304	7.64	271	1313	7.80	296	1324	8.00
310 77.9	247	1302	7.72	268	1311	7.89	293	1322	8.09
309 76.8	245	1301	7.81	266	1310	7.98	290	1321	8.18
308 75.7	242	1299	7.90	263	1308	8.07	288	1319	8.27
307 74.6	240	1298	7.99	261	1307	8.16	285	1318	8.36
306 73.5	237	1296	8.08	258	1305	8.25	282	1316	8.45
305 72.4	235	1295	8.17	255	1304	8.34	279	1314	8.55
304 71.4	232	1293	8.26	253	1302	8.44	277	1313	8.64
303 70.3	230	1292	8.35	250	1301	8.54	274	1311	8.74	298	1321	8.96	...
302 69.3	227	1290	8.45	247	1299	8.64	271	1309	8.84	295	1320	9.06	...
301 68.2	225	1289	8.55	245	1298	8.74	269	1308	8.95	292	1318	9.17	...
300 67.2	222	1287	8.64	242	1296	8.84	266	1307	9.05	290	1317	9.27	...
299 66.2	220	1286	8.74	240	1295	8.94	263	1305	9.16	287	1315	9.37	...
298 65.2	217	1284	8.85	237	1293	9.04	260	1303	9.27	284	1313	9.48	...
297 64.3	214	1282	8.95	235	1292	9.14	258	1302	9.38	281	1312	9.59	...
296 63.3	212	1281	9.05	232	1290	9.25	255	1300	9.49	278	1310	9.70	...
295 62.3	209	1279	9.15	229	1288	9.35	252	1298	9.59	275	1308	9.80	...
294 61.4	207	1278	9.26	227	1287	9.46	250	1297	9.70	272	1306	9.92	...
293 60.5	204	1276	9.37	224	1285	9.57	247	1295	9.80	270	1305	10.03	...
292 59.5	202	1275	9.49	222	1284	9.68	244	1293	9.91	267	1303	10.15	...
291 58.6	199	1273	9.60	219	1282	9.80	242	1292	10.02	264	1302	10.27	...
290 57.7	197	1272	9.70	216	1280	9.91	239	1290	10.14	261	1300	10.40	...
289 56.8	194	1270	9.81	214	1279	10.02	236	1289	10.26	258	1298	10.52	...
288 56.0	192	1269	9.93	211	1277	10.14	234	1288	10.39	255	1297	10.64	...
287 55.1	189	1267	10.05	209	1276	10.26	231	1286	10.50	252	1295	10.77	...
286 54.2	187	1266	10.17	206	1274	10.40	228	1284	10.63	250	1294	10.90	...
285 53.4	184	1264	10.29	203	1272	10.52	225	1282	10.75	247	1292	11.03	...
284 52.6	182	1262	10.41	201	1271	10.64	223	1281	10.88	244	1290	11.16	...
283 51.7	179	1260	10.53	198	1269	10.77	220	1279	11.00	241	1288	11.30	...
282 50.9	177	1259	10.66	196	1268	10.90	217	1278	11.13	238	1287	11.44	...
281 50.1	174	1257	10.79	193	1266	11.03	215	1276	11.27	235	1285	11.57	...
280 49.33	172	1256	10.92	191	1265	11.16	212	1275	11.40	232	1283	11.70	...
279 48.55	169	1254	11.05	188	1263	11.30	209	1273	11.54	229	1282	11.84	...
278 47.77	167	1253	11.19	185	1261	11.43	207	1272	11.68	226	1280	11.99	...
277 47.01	164	1251	11.32	183	1260	11.57	204	1270	11.82	224	1279	12.13	...

TEMPERATURE-ENTROPY TABLE.

119

Temperature, Degrees Fahr. Pressure, Pounds per Square Inch.	1.80			1.81			1.82			1.83		
	Quality.	Heat Con- tent.	Specific Volume.									
324 95. 1
323 93. 8
322 92. 5
321 91. 2
320 90. 0
319 88. 7
318 87. 4
317 86. 2
316 85. 0
315 83. 8
314 82. 6
313 81. 4
312 80. 2
311 79. 1
310 77. 9
309 76. 8
308 75. 7
307 74. 6
306 73. 5
305 72. 4
304 71. 4
303 70. 3
302 69. 3
301 68. 2
300 67. 2
299 66. 2
298 65. 2
297 64. 3
296 63. 3
295 62. 3
294 61. 4	298	1318	10.19
293 60. 5	295	1316	10.30
292 59. 5	292	1314	10.41
291 58. 6	289	1312	10.53
290 57. 7	286	1311	10.65
289 56. 8	283	1309	10.77
288 56. 0	280	1307	10.90
287 55. 1	277	1306	11.03
286 54. 2	274	1304	11.15	298	1314	11.43
285 53. 4	271	1302	11.28	295	1313	11.56
284 52. 6	269	1301	11.41	292	1311	11.69
283 51. 7	266	1299	11.55	289	1309	11.82
282 50. 9	263	1298	11.68	286	1307	11.95
281 50. 1	260	1296	11.81	283	1306	12.09
280 49. 33	257	1294	11.95	280	1304	12.23
279 48. 55	254	1292	12.10	277	1302	12.38
278 47. 77	251	1291	12.25	274	1301	12.52	299	1311	12.80
277 47. 01	248	1289	12.39	270	1298	12.67	296	1310	12.96

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr. Pressure, Pounds per Square Inch.	1.76			1.77			1.78			1.79		
	Quality.	Heat Con- tent.	Specific Volume.									
276 46.26	162	1250	11.46	180	1258	11.70	201	1268	11.96	221	1277	12.27
275 45.52	159	1248	11.60	178	1257	11.85	198	1266	12.11	218	1275	12.41
274 44.78	157	1247	11.74	175	1255	12.00	196	1265	12.26	215	1273	12.57
273 44.06	154	1245	11.88	173	1254	12.16	193	1263	12.40	212	1272	12.71
272 43.35	152	1244	12.02	170	1252	12.30	190	1261	12.57	210	1270	12.88
271 42.64	149	1242	12.17	167	1250	12.45	188	1260	12.73	207	1269	13.03
270 41.95	147	1241	12.33	165	1249	12.60	185	1258	12.88	204	1267	13.19
269 41.26	144	1239	12.49	162	1247	12.76	182	1257	13.04	201	1265	13.34
268 40.58	141	1237	12.63	160	1246	12.92	180	1255	13.20	198	1264	13.50
267 39.91	139	1235	12.80	157	1244	13.09	177	1253	13.37	195	1262	13.67
266 39.26	137	1234	12.95	155	1243	13.25	174	1252	13.54	193	1261	13.84
265 38.60	134	1232	13.11	152	1241	13.42	172	1251	13.71	190	1259	14.00
264 37.96	132	1231	13.27	150	1240	13.59	169	1249	13.89	187	1257	14.19
263 37.33	129	1229	13.44	147	1238	13.76	166	1247	14.06	184	1255	14.37
262 36.71	127	1228	13.61	145	1237	13.93	163	1245	14.24	181	1253	14.55
261 36.09	124	1226	13.78	142	1235	14.10	161	1244	14.41	178	1252	14.72
260 35.48	122	1225	13.95	139	1233	14.28	158	1242	14.60	176	1250	14.91
259 34.88	119	1223	14.15	137	1232	14.47	155	1240	14.79	173	1249	15.10
258 34.29	117	1222	14.33	134	1230	14.66	153	1239	14.99	170	1247	15.30
257 33.71	114	1220	14.51	132	1229	14.83	150	1237	15.17	167	1245	15.51
256 33.14	112	1219	14.70	129	1227	15.03	147	1236	15.38	165	1244	15.71
255 32.57	109	1217	14.89	127	1226	15.22	144	1234	15.58	162	1242	15.91
254 32.01	107	1216	15.09	124	1224	15.42	142	1232	15.78	159	1240	16.13
253 31.46	104	1214	15.29	122	1222	15.62	139	1231	15.99	156	1239	16.34
252 30.92	102	1212	15.49	119	1220	15.82	136	1229	16.19	154	1237	16.56
251 30.38	99	1210	15.68	117	1219	16.01	134	1228	16.40	151	1235	16.77
250 29.86	97	1209	15.89	114	1217	16.23	131	1226	16.61	148	1234	16.99
249 29.34	95	1208	16.10	112	1216	16.45	128	1224	16.83	145	1232	17.21
248 28.82	92	1206	16.31	109	1214	16.67	126	1223	17.05	143	1231	17.45
247 28.32	90	1205	16.52	107	1213	16.90	123	1221	19.27	140	1229	17.68
246 27.82	87	1203	16.75	104	1211	17.12	120	1219	17.50	137	1227	17.91
245 27.33	85	1202	16.98	102	1210	17.36	118	1218	17.74	134	1225	18.15
244 26.85	82	1200	17.20	99	1208	17.59	115	1216	17.97	132	1224	18.40
243 26.37	80	1198	17.44	96	1206	17.83	112	1214	18.21	129	1222	18.64
242 25.90	77	1196	17.69	94	1205	18.07	110	1213	18.46	126	1220	18.99
241 25.44	75	1195	17.91	91	1203	18.31	107	1211	18.71	124	1219	19.15
240 24.98	73	1194	18.16	89	1202	18.57	105	1210	18.96	121	1217	19.40
239 24.53	70	1192	18.40	86	1200	18.83	102	1208	19.23	119	1216	19.68
238 24.09	68	1191	18.66	84	1199	19.10	99	1206	19.50	116	1214	19.94
237 23.66	66	1189	18.93	81	1197	19.35	97	1205	19.77	113	1212	20.20
236 23.23	63	1187	19.20	79	1195	19.62	94	1203	20.04	111	1211	20.50
235 22.80	61	1186	19.46	76	1193	19.90	92	1202	20.32	108	1209	20.78
234 22.39	59	1185	19.73	74	1192	20.19	89	1200	20.60	106	1208	21.06
233 21.98	56	1183	20.00	72	1191	20.48	87	1199	20.90	103	1206	21.35
232 21.57	54	1182	20.29	69	1189	20.75	84	1197	21.20	100	1204	21.65
231 21.18	52	1180	20.59	67	1188	21.03	82	1195	21.50	98	1203	21.95
230 20.78	50	1179	20.88	64	1186	21.34	79	1193	21.80	95	1201	22.27
229 20.40	47	1177	21.19	62	1185	21.65	77	1192	22.12	93	1200	22.58

TEMPERATURE-ENTROPY TABLE

121

Temperature Degrees Fahr.	Pressure Pounds per Square Inch	1.80				1.81				1.82				1.83			
		Quality,	Heat Con- tent,	Specific Volume	Quality	Heat Con- tent,	Specific Volume										
276.46	26	245	1287	12.54	267	1297	12.81	293	1308	13.11	—	1308	13.11	—	1308	13.11	
275.45	25	242	1286	12.69	264	1295	12.98	289	1306	13.27	—	1306	13.27	—	1306	13.27	
274.44	24	239	1284	12.84	261	1293	13.13	286	1304	13.44	—	1304	13.44	—	1304	13.44	
273.44	23	236	1282	13.00	258	1292	13.29	283	1302	13.60	—	1302	13.60	—	1302	13.60	
272.43	22	233	1280	13.15	255	1290	13.45	280	1301	13.77	—	1301	13.77	—	1301	13.77	
271.42	21	230	1279	13.30	252	1288	13.61	277	1299	13.93	299	13.08	14.08	13.08	14.08	14.25	
270.41	20	227	1277	13.48	249	1287	13.78	273	1297	14.10	296	1306	14.43	—	1306	14.43	
269.41	19	224	1275	13.64	246	1285	13.94	270	1295	14.28	293	1305	14.60	—	1305	14.60	
268.40	18	221	1274	13.81	243	1283	14.11	267	1293	14.46	289	1302	14.78	—	1302	14.78	
267.39	17	218	1272	13.99	239	1281	14.30	263	1291	14.62	286	1301	14.96	—	1301	14.96	
266.39	16	215	1270	14.16	236	1279	14.49	260	1290	14.81	282	1300	15.15	—	1300	15.15	
265.38	15	212	1268	14.34	233	1277	14.65	257	1288	15.00	279	1297	15.34	—	1297	15.34	
264.37	14	209	1267	14.51	230	1276	14.82	254	1286	15.20	276	1295	15.54	—	1295	15.54	
263.37	13	206	1265	14.70	227	1274	15.01	250	1284	15.39	272	1293	15.73	—	1293	15.73	
262.36	12	203	1263	14.89	224	1272	15.20	247	1282	15.59	269	1291	15.92	—	1291	15.92	
261.36	11	200	1262	15.08	221	1271	15.40	244	1281	15.79	266	1290	16.13	—	1290	16.13	
260.35	10	197	1260	15.27	217	1269	15.61	241	1279	15.98	262	1288	16.33	—	1288	16.33	
259.34	9	194	1258	15.47	214	1267	15.80	237	1277	16.19	259	1286	16.54	—	1286	16.54	
258.34	8	192	1257	15.67	211	1265	16.00	234	1275	16.40	255	1284	16.75	—	1284	16.75	
257.33	7	189	1255	15.87	208	1263	16.23	231	1273	16.60	252	1282	16.96	—	1282	16.96	
256.33	6	186	1253	16.08	205	1262	16.45	228	1272	16.81	249	1280	17.19	—	1280	17.19	
255.32	5	183	1252	16.30	202	1260	16.67	225	1270	17.03	245	1278	17.49	—	1278	17.49	
254.32	4	180	1250	16.50	199	1258	16.89	221	1268	17.26	242	1277	17.64	—	1277	17.64	
253.31	3	177	1248	16.71	196	1256	17.10	218	1266	17.49	239	1275	17.87	—	1275	17.87	
252.30	2	174	1246	16.94	193	1255	17.32	215	1264	17.71	235	1273	18.10	—	1273	18.10	
251.30	1	171	1245	17.16	190	1253	17.55	212	1263	17.95	232	1271	18.35	—	1271	18.35	
250.29	0	168	1243	17.38	187	1251	17.78	209	1261	18.19	229	1269	18.60	—	1269	18.60	
249.29	34	165	1241	17.60	184	1250	18.02	205	1259	18.42	226	1268	18.84	—	1268	18.84	
248.28	32	162	1239	17.83	181	1248	18.25	202	1257	18.65	222	1266	19.09	—	1266	19.09	
247.28	32	159	1238	18.09	178	1246	18.50	199	1255	18.92	219	1264	19.34	—	1264	19.34	
246.27	32	156	1236	18.32	175	1244	18.75	196	1254	19.19	216	1262	19.60	—	1262	19.60	
245.27	33	153	1234	18.56	172	1243	19.09	193	1252	19.44	212	1260	19.85	—	1260	19.85	
244.26	35	151	1233	18.81	169	1241	19.25	190	1250	19.70	209	1259	20.11	—	1259	20.11	
243.26	37	148	1231	19.08	166	1240	19.50	187	1249	19.95	206	1257	20.39	—	1257	20.39	
242.25	39	145	1230	19.31	163	1238	19.77	184	1247	20.21	202	1255	20.65	—	1255	20.65	
241.25	44	142	1228	19.59	160	1236	20.02	181	1245	20.50	199	1253	20.93	—	1253	20.93	
240.24	48	139	1226	19.85	158	1235	20.30	177	1243	20.77	196	1251	21.20	—	1251	21.20	
239.24	53	136	1224	20.11	155	1233	20.58	174	1241	21.05	192	1249	21.50	—	1249	21.50	
238.24	59	133	1223	20.40	152	1231	20.85	171	1240	21.34	189	1247	21.80	—	1247	21.80	
237.23	66	131	1221	20.66	149	1230	21.15	168	1238	21.63	186	1246	22.10	—	1246	22.10	
236.23	73	128	1220	20.94	146	1228	21.42	165	1236	21.95	183	1244	22.39	—	1244	22.39	
235.22	80	125	1218	21.22	143	1226	21.72	162	1234	22.22	180	1242	22.70	—	1242	22.70	
234.22	39	122	1216	21.51	140	1224	22.02	159	1233	22.53	177	1241	23.00	—	1241	23.00	
233.21	98	120	1215	21.81	137	1223	22.32	156	1231	22.84	173	1239	23.34	—	1239	23.34	
232.21	57	117	1213	22.12	134	1221	22.65	153	1229	23.15	170	1237	23.66	—	1237	23.66	
231.21	18	114	1211	22.43	132	1220	22.96	150	1228	23.47	167	1235	24.00	—	1235	24.00	
230.20	78	112	1210	22.75	129	1218	23.29	147	1226	23.80	164	1234	24.32	—	1234	24.32	
229.20	40	109	1208	23.08	126	1216	23.60	144	1224	24.12	161	1232	24.66	—	1232	24.66	

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr. 1.76	Pressure, Pounds per Square Inch.	Quality.	Heat Con- tents.	Specific Volume.	1.77	Heat Con- tents.	Specific Volume.	1.78	Heat Con- tents.	Specific Volume.	1.79	Heat Con- tents.	Specific Volume.
228	20.02	45	1176	21.50	59	1183	21.95	74	1190	22.44	90	1198	22.90
227	19.64	43	1174	21.80	57	1181	22.29	72	1189	22.76	87	1196	23.24
226	19.28	41	1173	22.13	55	1180	22.60	69	1187	23.09	85	1195	23.58
225	18.91	38	1171	22.47	52	1178	22.93	67	1186	23.41	82	1193	23.90
224	18.56	36	1170	22.80	50	1177	23.27	65	1185	23.75	80	1192	24.25
223	18.21	34	1168	23.14	48	1176	23.60	62	1183	24.10	77	1190	24.60
222	17.86	32	1167	23.50	45	1174	23.95	60	1182	24.45	75	1189	24.95
221	17.52	30	1166	23.84	43	1172	24.31	57	1180	24.80	72	1187	25.31
220	17.19	27	1164	24.20	41	1171	24.67	55	1178	25.18	69	1185	25.69
219	16.86	25	1163	24.55	39	1170	25.05	52	1176	25.55	67	1184	26.05
218	16.53	23	1161	24.93	36	1168	25.41	50	1175	25.92	64	1182	26.44
217	16.21	21	1160	25.30	34	1166	25.80	48	1174	26.30	62	1181	26.84
216	15.90	19	1158	25.68	32	1165	26.20	45	1172	26.70	59	1179	27.25
215	15.59	17	1157	26.05	30	1164	26.60	43	1171	27.10	57	1178	27.67
214	15.29	15	1156	26.45	28	1163	27.00	41	1169	27.50	54	1176	28.10
213	14.99	12	1154	26.85	25	1160	27.40	38	1167	27.90	52	1174	28.52
212	14.70	10	1152	27.29	23	1159	27.85	36	1166	28.35	50	1173	28.95
211	14.41	8	1151	27.70	21	1158	28.30	34	1165	28.79	47	1171	29.40
210	14.12	6	1150	28.14	19	1156	28.71	32	1163	29.23	45	1170	29.85
209	13.84	4	1149	28.60	17	1155	29.17	29	1161	29.70	42	1168	30.30
208	13.57	2	1147	29.05	15	1154	29.63	27	1160	30.20	40	1167	30.78
207	13.29	9999	1145.1	29.26	12	1152	30.10	25	1159	30.70	38	1166	31.25
206	13.03	9987	1143.6	29.79	10	1150	30.55	22	1157	31.05	35	1164	31.72
205	12.77	9975	1142.1	30.33	8	1149	31.05	20	1155	31.60	33	1162	32.20
204	12.51	9963	1140.6	30.88	6	1147	31.50	18	1154	32.10	31	1161	32.70
203	12.25	9951	1139.2	31.44	4	1146	32.00	16	1153	32.60	28	1159	33.20
202	12.01	9940	1137.8	32.01	2	1145	32.55	14	1151	33.15	26	1158	33.75
201	11.76	9929	1136.3	32.61	9997	1142.9	32.83	11	1149	33.70	24	1156	34.30
200	11.52	9917	1134.8	33.20	9985	1141.4	33.43	9	1148	34.20	22	1155	34.85
199	11.28	9905	1133.4	33.82	9973	1139.9	34.05	7	1146	34.75	19	1153	35.40
198	11.05	9894	1131.9	34.44	9961	1138.5	34.67	5	1145	35.30	17	1152	36.00
197	10.82	9881	1130.4	35.08	9948	1136.9	35.32	3	1144	35.90	15	1150	36.60
196	10.60	9869	1128.9	35.73	9936	1135.4	35.98	0	1142	36.50	13	1148	37.20
195	10.38	9857	1127.4	36.41	9924	1134.0	36.66	9991	1140.5	36.91	10	1147	37.80
194	10.16	9845	1125.9	37.10	9912	1132.5	37.35	9979	1139.0	37.60	8	1145	38.40
193	9.95	9834	1124.5	37.80	9900	1131.0	38.06	9967	1137.6	38.31	6	1144	39.05
192	9.74	9822	1123.0	38.52	9888	1129.5	38.78	9955	1136.0	39.04	4	1143	39.70
191	9.53	9810	1121.5	39.25	9876	1128.0	39.51	9942	1134.5	39.78	1	1141	40.30
190	9.33	9798	1120.1	40.00	9864	1126.6	40.27	9930	1133.1	40.55	9997	1139.6	40.82
189	9.13	9787	1118.6	40.77	9853	1125.1	41.05	9919	1131.6	41.32	9985	1138.1	41.60
188	8.94	9774	1117.1	41.55	9840	1123.6	41.83	9906	1130.1	42.11	9972	1136.5	42.39
187	8.75	9763	1115.7	42.35	9829	1122.1	42.64	9894	1128.6	42.92	9960	1135.1	43.21
186	8.56	9751	1114.2	43.18	9816	1120.6	43.47	9882	1127.1	43.76	9947	1133.5	44.05
185	8.37	9739	1112.7	44.02	9805	1119.1	44.32	9870	1125.6	44.61	9935	1132.0	44.91
184	8.19	9727	1111.2	44.89	9792	1117.6	45.19	9857	1124.0	45.49	9923	1130.5	45.79
183	8.01	9715	1109.7	45.77	9780	1116.1	46.08	9846	1122.6	46.38	9911	1129.0	46.69
182	7.84	9704	1108.2	46.67	9769	1114.7	46.98	9833	1121.1	47.29	9899	1127.5	47.60
181	7.67	9692	1106.7	47.59	9757	1113.1	47.91	9822	1119.5	48.22	9887	1125.9	48.54

TEMPERATURE-ENTROPY TABLE.

123

Temperature Degrees Fahr.	Pressure Pounds per Square Inch.	1.80			1.81			1.82			1.83		
		Quality	Heat Content	Specific Volume									
228	20.02	106	1206	23.40	123	1214	23.94	141	1222	24.48	158	1230	25.00
227	19.64	104	1205	23.74	120	1212	24.37	138	1221	24.80	155	1228	25.38
226	19.28	101	1203	24.09	118	1211	24.61	135	1219	25.15	152	1227	25.74
225	18.91	98	1201	24.43	115	1209	24.97	132	1217	25.50	149	1225	26.10
224	18.56	96	1200	24.80	112	1208	25.34	129	1216	25.88	146	1223	26.49
223	18.21	93	1198	25.15	109	1206	25.72	127	1214	26.25	143	1222	26.85
222	17.86	90	1196	25.51	107	1205	26.10	124	1213	26.64	140	1220	27.25
221	17.52	88	1195	25.88	104	1203	26.47	121	1211	27.04	137	1218	27.66
220	17.19	85	1193	26.26	101	1200	26.86	118	1209	27.44	134	1216	28.05
219	16.86	83	1192	26.65	98	1199	27.25	115	1207	27.85	131	1215	28.45
218	16.53	80	1190	27.05	96	1198	27.67	112	1205	28.27	128	1213	28.88
217	16.21	78	1189	27.45	93	1196	28.09	110	1204	28.69	126	1212	29.30
216	15.90	75	1187	27.85	90	1194	28.50	107	1202	29.10	123	1210	29.74
215	15.59	72	1185	28.29	88	1193	28.91	104	1201	29.53	120	1208	30.19
214	15.29	70	1184	28.70	85	1191	29.35	101	1199	29.97	117	1206	30.64
213	14.99	67	1182	29.14	82	1189	29.80	98	1197	30.44	114	1205	31.10
212	14.70	65	1181	29.58	80	1188	30.24	96	1196	30.90	111	1203	31.55
211	14.41	62	1179	30.02	77	1186	30.70	93	1194	31.35	109	1202	32.05
210	14.12	60	1178	30.48	74	1184	31.15	90	1192	31.85	106	1200	32.55
209	13.84	57	1176	30.95	72	1183	31.65	87	1190	32.35	103	1198	33.05
208	13.57	55	1175	31.40	69	1181	32.10	85	1189	32.85	100	1197	33.55
207	13.29	52	1173	31.90	66	1179	32.60	82	1187	33.35	97	1195	34.05
206	13.03	50	1171	32.40	64	1178	33.10	79	1186	33.90	94	1193	34.60
205	12.77	47	1169	32.90	61	1176	33.60	77	1184	34.40	91	1191	35.10
204	12.51	45	1168	33.40	59	1175	34.10	74	1182	34.90	89	1190	35.60
203	12.25	43	1167	33.95	56	1173	34.65	71	1181	35.45	86	1188	36.15
202	12.01	40	1166	34.50	54	1172	35.20	69	1179	36.00	83	1187	36.70
201	11.76	38	1165	35.05	51	1170	35.75	66	1178	36.55	80	1185	37.30
200	11.52	35	1162	35.60	49	1169	36.32	64	1176	37.10	78	1183	37.85
199	11.28	33	1160	36.15	46	1167	36.90	61	1174	37.65	75	1182	38.45
198	11.05	30	1158	36.75	44	1166	37.49	58	1173	38.25	72	1180	39.05
197	10.82	28	1157	37.35	41	1164	38.05	56	1171	38.90	69	1178	39.65
196	10.60	26	1156	37.95	39	1162	38.64	53	1169	39.50	67	1177	40.30
195	10.38	23	1154	38.57	36	1160	39.25	50	1168	40.14	64	1175	40.90
194	10.16	21	1153	39.20	34	1159	39.90	48	1166	40.77	61	1173	41.60
193	9.95	19	1151	39.85	31	1157	40.55	45	1164	41.47	59	1172	42.20
192	9.74	16	1149	40.50	29	1156	41.23	43	1163	42.08	56	1170	43.00
191	9.53	14	1148	41.15	26	1154	41.90	40	1161	42.80	54	1169	43.70
190	9.33	12	1147	41.82	24	1153	42.62	38	1160	43.54	51	1167	44.40
189	9.13	9	1145	42.48	22	1151	43.35	35	1158	44.25	48	1166	45.20
188	8.94	7	1143	43.20	19	1149	44.05	33	1157	45.00	46	1164	45.95
187	8.75	5	1142	43.90	17	1148	44.80	30	1155	45.75	43	1162	46.70
186	8.56	2	1140	44.65	14	1146	45.50	28	1154	46.50	41	1161	47.50
185	8.37	0	1138	45.35	12	1145	46.25	25	1152	47.25	38	1159	48.30
184	8.19	9988	1136	9.46.09	10	1143	47.05	23	1150	48.05	36	1157	49.10
183	8.01	9976	1135	47.00	7	1141	47.85	20	1148	48.90	33	1155	49.90
182	7.84	9964	1133	9.47.92	5	1140	48.65	17	1146	49.70	30	1153	50.70
181	7.67	9951	1132	3.48.86	3	1139	49.45	15	1145	50.50	28	1152	51.55

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr. 1.76	Pressure, Pounds per Square Inch.	1.76				1.77				1.78				1.79			
		Quality.	Heat Con- tents.	Specific Volume													
180 7.50	9680	1105.1	48.53	9744	1111.5	48.86	9809	1117.9	49.18	9874	1124.3	49.51					
179 7.34	9668	1103.7	49.49	9733	1110.0	49.82	9797	1116.4	50.15	9862	1122.8	50.48					
178 7.17	9656	1102.2	50.47	9721	1108.6	50.81	9785	1114.9	51.15	9850	1121.3	51.48					
177 7.01	9645	1100.7	51.49	9709	1107.1	51.84	9773	1113.4	52.18	9838	1119.8	52.52					
176 6.86	9632	1099.2	52.54	9697	1105.5	52.89	9761	1111.9	53.23	9825	1118.2	53.58					
175 6.70	9621	1097.7	53.59	9685	1104.0	53.94	9749	1110.4	54.30	9813	1116.7	54.66					
174 6.55	9609	1096.2	54.68	9673	1102.5	55.04	9737	1108.8	55.40	9800	1115.2	55.76					
173 6.41	9597	1094.7	55.79	9661	1101.0	56.16	9725	1107.3	56.53	9788	1113.7	56.90					
172 6.26	9586	1093.2	56.93	9649	1099.5	57.31	9713	1105.8	57.68	9776	1112.1	58.06					
171 6.12	9573	1091.6	58.08	9636	1097.9	58.46	9700	1104.2	58.85	9763	1110.5	59.23					
170 5.98	9561	1090.1	59.28	9625	1096.4	59.67	9688	1102.7	60.06	9751	1109.0	60.46					
169 5.84	9550	1088.6	60.52	9613	1094.9	60.91	9676	1101.2	61.31	9739	1107.5	61.71					
168 5.71	9538	1087.1	61.78	9601	1093.4	62.18	9664	1099.7	62.59	9727	1105.9	63.00					
167 5.58	9426	1085.6	63.07	9589	1091.9	63.49	9652	1098.1	63.90	9715	1104.4	64.32					
166 5.45	9514	1084.1	64.38	9577	1090.3	64.81	9640	1096.6	65.23	9702	1102.8	65.65					
165 5.32	9502	1082.6	65.73	9565	1088.8	66.16	9627	1095.0	66.59	9690	1101.3	67.02					
164 5.20	9490	1081.0	67.12	9553	1087.3	67.56	9615	1093.5	68.00	9677	1099.7	68.44					
163 5.08	9478	1079.5	68.53	9541	1085.7	68.98	9603	1092.0	69.43	9665	1098.2	69.88					
162 4.960	9466	1078.0	69.99	9529	1084.2	70.44	9591	1090.4	70.90	9653	1096.6	71.36					
161 4.844	9456	1076.5	71.49	9518	1082.7	71.96	9580	1088.9	72.42	9642	1095.1	72.89					
160 4.729	9444	1075.0	73.01	9506	1081.2	73.49	9568	1087.4	73.97	9630	1093.6	74.45					
159 4.617	9432	1073.4	74.58	9494	1079.6	75.07	9555	1085.8	75.56	9617	1092.0	76.04					
158 4.508	9420	1071.9	76.19	9482	1078.1	76.69	9543	1084.2	77.19	9605	1090.4	77.68					
157 4.400	9409	1070.4	77.85	9470	1076.6	78.36	9532	1082.7	78.86	9593	1088.9	79.37					
156 4.295	9397	1068.9	79.55	9458	1075.0	80.07	9519	1081.2	80.59	9580	1087.3	81.11					
155 4.191	9385	1067.3	81.28	9446	1073.4	81.81	9507	1079.6	82.34	9568	1085.7	82.87					
154 4.090	9373	1065.7	83.06	9434	1071.9	83.60	9495	1078.0	84.14	9556	1084.2	84.68					
153 3.991	9361	1064.2	84.89	9422	1070.4	85.44	9483	1076.5	85.99	9544	1082.6	86.54					
152 3.894	9349	1062.7	86.77	9410	1068.8	87.33	9471	1074.9	87.90	9531	1081.0	88.46					
151 3.799	9337	1061.1	88.69	9398	1067.2	89.27	9458	1073.3	89.84	9519	1079.4	90.42					
150 3.706	9326	1059.6	90.68	9386	1065.7	91.27	9446	1071.8	91.86	9507	1077.9	92.44					
149 3.615	9314	1058.0	92.71	9374	1064.1	93.31	9434	1070.2	93.91	9494	1076.3	94.51					
148 3.526	9302	1056.5	94.79	9362	1062.6	95.40	9422	1068.7	96.01	9482	1074.8	96.62					
147 3.439	9290	1055.0	96.89	9350	1061.0	97.52	9410	1067.1	98.14	9470	1073.1	98.77					
146 3.353	9278	1053.4	99.09	9338	1059.5	99.73	9398	1065.5	100.4	9458	1071.6	101.0					
145 3.270	9266	1051.8	101.4	9326	1057.9	102.0	9385	1063.9	102.7	9445	1070.0	103.3					
144 3.188	9255	1050.3	103.7	9314	1056.4	104.3	9374	1062.4	105.0	9433	1068.4	105.7					
143 3.108	9242	1048.7	106.0	9302	1054.8	106.7	9361	1060.8	107.4	9421	1066.8	108.1					
142 3.029	9231	1047.2	108.5	9290	1053.2	109.2	9349	1059.2	109.9	9408	1065.2	110.5					
141 2.953	9220	1045.7	111.0	9279	1051.7	111.7	9338	1057.7	112.4	9397	1063.7	113.1					
140 2.877	9208	1044.1	113.6	9267	1050.1	114.4	9326	1056.0	115.1	9385	1062.0	115.8					
139 2.804	9196	1042.5	116.3	9255	1048.5	117.1	9314	1054.5	117.8	9373	1060.5	118.6					
138 2.732	9184	1041.0	119.0	9243	1047.0	119.8	9302	1053.0	120.6	9360	1058.9	121.3					
137 2.662	9172	1039.4	121.8	9231	1045.3	122.6	9289	1051.3	123.4	9348	1057.3	124.1					
136 2.593	9160	1037.8	124.7	9219	1043.8	125.5	9277	1049.7	126.3	9336	1055.7	127.1					
135 2.526	9149	1036.2	127.7	9207	1042.2	128.4	9265	1048.1	129.2	9323	1054.1	130.1					
134 2.460	9136	1034.6	130.7	9194	1040.6	131.5	9253	1046.5	132.4	9311	1052.4	133.2					
133 2.396	9124	1033.1	133.9	9182	1039.0	134.7	9240	1044.9	135.6	9298	1050.8	136.4					

TEMPERATURE-ENTROPY TABLE

125

Temperature Degrees Fahr.	Pressure Pounds per Square Inch	1.80				1.81				1.82				1.83			
		Quality	Heat Cap. Btu's	Specific Volume													
180 7.50	9939	1130.7	49.83	0	1137.5	50.34	13	1144.2	51.35	25	1150.0	52.40					
179 7.34	9926	1129.2	50.81	0.991	1136.6	51.14	10	1142.5	52.20	23	1149.5	53.30					
178 7.17	9914	1127.7	51.82	0.978	1134.1	52.16	8	1140.5	53.20	20	1147.5	54.30					
177 7.01	9892	1126.2	52.87	0.966	1132.5	53.21	5	1139.5	54.20	18	1146.5	55.20					
176 6.86	9889	1124.6	53.93	0.953	1130.9	54.28	3	1137.5	55.19	15	1144.5	56.19					
175 6.70	9877	1123.0	55.01	0.940	1129.4	55.37	0	1136.5	56.10	13	1142.5	57.10					
174 6.55	9864	1121.5	56.13	0.928	1127.9	56.49	9992	1134.2	56.85	10	1140.5	58.10					
173 6.41	9852	1120.0	57.27	0.916	1126.3	57.64	9979	1132.5	58.01	8	1139.5	59.20					
172 6.26	9840	1118.4	58.44	0.903	1124.8	58.81	9967	1131.5	59.19	6	1138.5	60.20					
171 6.12	9827	1116.8	59.62	0.890	1123.1	60.00	9953	1129.5	60.29	3	1135.5	61.30					
170 5.98	9814	1115.3	60.85	0.877	1121.6	61.24	9941	1127.9	61.63	1	1134.5	62.40					
169 5.84	9802	1113.8	62.11	0.865	1120.0	62.51	9928	1126.3	62.91	9991	1132.5	63.31					
168 5.71	9789	1112.2	63.41	0.852	1118.5	63.81	9915	1124.8	64.22	9978	1131.0	64.61					
167 5.58	9777	1110.6	64.73	0.840	1116.9	65.15	9902	1123.2	65.56	9966	1129.4	65.98					
166 5.45	9765	1109.1	66.08	0.827	1115.3	66.50	9890	1121.6	66.92	9953	1127.9	67.35					
165 5.32	9752	1107.5	67.46	0.815	1113.8	67.89	9877	1120.0	68.32	9940	1126.3	68.75					
164 5.20	9740	1106.0	68.88	0.802	1112.2	69.32	9864	1118.4	69.76	9927	1124.7	70.20					
163 5.08	9727	1104.4	70.33	0.789	1110.6	70.78	9852	1116.9	71.23	9914	1123.1	71.58					
162 4.960	9715	1102.8	71.82	0.777	1109.0	72.28	9839	1115.3	72.74	9901	1121.5	73.20					
161 4.844	9704	1101.3	73.30	0.766	1107.5	73.83	9828	1113.7	74.30	9889	1119.7	74.77					
160 4.729	9691	1099.7	74.92	0.753	1105.9	75.40	9815	1112.1	75.88	9877	1118.7	75.36					
159 4.617	9679	1098.2	76.53	0.740	1104.4	77.02	9802	1110.5	77.50	9864	1116.7	77.99					
158 4.508	9666	1096.6	78.18	0.728	1102.8	78.68	9789	1108.9	79.18	9841	1115.1	79.47					
157 4.400	9654	1095.1	79.88	0.716	1101.2	80.39	9777	1107.4	80.83	9838	1113.6	81.40					
156 4.295	9642	1093.5	81.63	0.703	1099.6	82.14	9764	1105.8	82.66	9825	1111.9	82.18					
155 4.191	9629	1091.9	83.40	0.690	1098.0	83.93	9751	1104.2	84.46	9812	1110.3	84.28					
154 4.080	9617	1090.3	85.22	0.677	1096.4	85.76	9738	1102.6	85.30	9799	1108.7	85.84					
153 3.991	9605	1088.7	87.09	0.665	1094.9	87.64	9726	1101.0	88.20	9787	1107.1	88.73					
152 3.894	9592	1087.1	89.02	0.653	1093.3	89.58	9713	1099.4	90.15	9774	1105.5	90.71					
151 3.799	9579	1085.5	90.99	0.640	1091.6	91.57	9700	1097.8	92.14	9761	1103.9	92.72					
150 3.706	9567	1084.0	93.03	0.628	1090.1	93.62	9688	1096.2	94.20	9748	1102.3	94.79					
149 3.615	9554	1082.4	95.11	0.615	1088.5	95.70	9675	1094.6	96.30	9735	1100.6	96.90					
148 3.526	9542	1080.8	97.24	0.602	1085.9	97.85	9663	1093.0	98.46	9723	1099.1	99.07					
147 3.439	9530	1079.2	99.39	0.590	1085.3	100.0	9650	1091.3	100.6	9710	1097.4	101.3					
146 3.353	9518	1077.7	101.6	0.577	1083.7	102.3	9637	1089.8	102.9	9697	1095.8	103.6					
145 3.270	9505	1076.0	104.0	0.564	1082.1	104.6	9624	1085.1	105.3	9684	1094.2	105.9					
144 3.188	9493	1074.5	106.3	0.552	1080.5	107.0	9612	1086.5	107.7	9671	1092.6	108.3					
143 3.108	9480	1072.8	108.7	0.539	1078.9	109.4	9599	1084.9	110.1	9658	1090.9	110.8					
142 3.029	9468	1071.3	111.2	0.527	1077.3	111.9	9586	1083.3	112.6	9645	1089.3	113.3					
141 2.953	9456	1069.7	113.9	0.516	1075.7	114.6	9575	1081.7	115.3	9634	1087.7	116.0					
140 2.877	9444	1068.0	116.5	0.503	1074.0	117.3	9562	1080.0	118.0	9621	1086.0	118.7					
139 2.804	9431	1066.5	119.3	0.490	1072.4	120.1	9549	1078.4	120.8	9608	1084.4	121.5					
138 2.732	9419	1064.9	122.1	0.478	1070.8	122.8	9537	1076.8	123.6	9595	1082.8	124.4					
137 2.662	9406	1063.2	124.9	0.465	1069.2	125.7	9523	1075.1	126.5	9582	1081.1	127.2					
136 2.593	9394	1061.6	127.9	0.452	1067.6	128.6	9511	1073.5	129.4	9569	1079.5	130.2					
135 2.526	9382	1060.0	130.9	0.440	1066.0	131.7	9498	1071.9	132.5	9557	1077.9	133.3					
134 2.460	9369	1058.4	134.0	0.427	1064.3	134.9	9485	1070.2	135.7	9543	1076.2	135.5					
133 2.396	9356	1056.8	137.3	0.414	1062.7	138.1	9472	1068.6	139.0	9530	1074.5	139.8					

TEMPERATURE-ENTROPY TABLE.

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch.	1.76			1.77			1.78			1.79		
		Quality.	Heat Con- tents.	Specific Volume.									
132	2.333	9113	1031.5	137.1	9170	1037.4	137.9	9228	1043.3	138.8	9286	1049.2	139.7
131	2.272	9101	1029.9	140.3	9159	1035.8	141.2	9216	1041.7	142.1	9274	1047.6	143.0
130	2.212	9089	1028.3	143.7	9147	1034.2	144.6	9204	1040.1	145.5	9262	1046.0	146.4
129	2.153	9077	1026.8	147.3	9135	1032.7	148.3	9192	1038.5	149.2	9250	1044.4	150.1
128	2.096	9065	1025.2	150.8	9123	1031.1	151.8	9180	1036.9	152.8	9237	1042.8	153.7
127	2.040	9053	1023.6	154.5	9111	1029.5	155.5	9168	1035.3	156.5	9225	1041.2	157.5
126	1.985	9041	1022.0	158.4	9099	1027.9	159.4	9156	1033.7	160.4	9213	1039.6	161.4
125	1.932	9030	1020.5	162.4	9086	1026.3	163.4	9143	1032.2	164.4	9200	1038.0	165.4
124	1.880	9018	1018.8	166.4	9074	1024.7	167.4	9131	1030.5	168.5	9188	1036.3	169.5
123	1.829	9006	1017.3	170.5	9062	1023.1	171.5	9119	1029.0	172.6	9176	1034.8	173.7
122	1.779	8994	1015.6	174.7	9050	1021.4	175.8	9107	1027.3	176.9	9163	1033.1	178.0
121	1.730	8983	1014.0	179.2	9040	1019.9	180.3	9096	1025.7	181.5	9152	1031.5	182.6
120	1.683	8971	1012.5	183.7	9027	1018.3	184.9	9084	1024.1	186.0	9140	1029.9	187.2
119	1.636	8959	1010.9	188.4	9015	1016.7	189.6	9071	1022.5	190.8	9127	1028.3	191.9
118	1.591	8948	1009.3	193.3	9004	1015.1	194.5	9060	1020.9	195.7	9116	1026.6	196.9
117	1.547	8936	1007.7	198.2	8991	1013.5	199.4	9047	1019.2	200.7	9103	1025.0	201.9
116	1.504	8923	1006.1	203.3	8979	1011.8	204.5	9035	1017.5	205.8	9090	1023.3	207.1
115	1.462	8912	1004.5	208.5	8968	1010.2	209.8	9023	1015.9	211.1	9079	1021.7	212.4
114	1.421	8900	1002.9	214.0	8955	1008.6	215.3	9011	1014.3	216.6	9066	1020.1	218.0
113	1.381	8888	1001.3	219.5	8943	1007.0	220.9	8998	1012.7	222.3	9054	1018.4	223.6
112	1.342	8876	999.7	225.3	8931	1005.4	226.7	8986	1011.1	228.1	9042	1016.8	229.5
111	1.304	8864	998.1	231.3	8919	1003.8	232.7	8970	1009.5	234.1	9029	1015.2	235.9
110	1.266	8852	996.4	237.3	8907	1002.1	238.8	8962	1007.8	240.3	9017	1013.5	241.7
109	1.230	8840	994.8	243.6	8895	1000.5	245.1	8950	1006.2	246.7	9004	1011.9	248.2
108	1.195	8829	993.2	250.1	8883	998.9	251.7	8938	1004.5	253.2	8992	1010.2	254.8
107	1.160	8816	991.6	256.7	8871	997.3	258.3	8925	1002.9	259.9	8980	1008.6	261.5
106	1.127	8805	989.9	263.6	8859	995.6	265.2	8913	1001.2	266.9	8968	1006.9	268.5
105	1.094	8793	988.3	270.8	8847	993.0	272.5	8901	999.6	274.2	8956	1005.3	275.8
104	1.062	8781	986.7	278.2	8835	992.3	279.9	8889	997.9	281.6	8943	1003.6	283.3
103	1.031	8769	985.1	285.8	8823	990.7	287.5	8877	996.3	289.3	8931	1002.0	291.1
102	1.000	8757	983.4	293.5	8811	989.1	295.3	8865	994.7	297.1	8919	1000.3	298.9
101	0.971	8746	981.8	301.6	8800	987.4	303.4	8854	993.0	305.3	8907	998.6	307.1
100	0.942	8734	980.2	309.8	8787	985.7	311.7	8841	991.3	313.6	8894	996.9	315.5
99	0.914	8722	978.6	318.5	8775	984.1	320.5	8829	989.7	322.4	8882	995.3	324.4
98	0.887	8710	976.9	327.4	8763	982.5	329.4	8817	988.0	331.4	8870	993.6	333.4
97	0.860	8698	975.3	336.5	8751	980.9	338.6	8805	986.4	340.6	8858	992.0	342.7
96	0.834	8687	973.7	346.1	8740	979.3	348.2	8793	984.8	350.3	8846	990.4	352.4
95	0.809	8675	972.1	355.9	8728	977.7	358.0	8781	983.2	360.2	8834	988.8	362.4
94	0.784	8663	970.4	365.9	8716	976.0	368.2	8769	981.5	370.4	8822	987.1	372.6
93	0.761	8651	968.8	376.3	8704	974.4	378.6	8757	979.9	380.9	8809	985.4	383.2
92	0.737	8639	967.2	387.1	8692	972.7	389.5	8744	978.2	391.8	8797	983.7	394.2
91	0.715	8627	965.5	398.3	8680	971.0	400.7	8732	976.5	403.2	8785	982.0	405.6
90	0.693	8615	963.8	409.7	8668	969.3	412.2	8720	974.8	414.7	8772	980.3	417.2
89	0.671	8603	962.2	421.6	8656	967.7	424.1	8708	973.2	426.7	8760	978.6	429.2
88	0.650	8591	960.5	433.7	8643	966.0	436.3	8695	971.5	438.9	8747	976.9	441.6
87	0.630	8580	958.9	446.5	8632	964.4	449.2	8684	969.8	451.9	8736	975.3	454.6
86	0.610	8568	957.2	459.6	8620	962.7	462.4	8671	968.1	465.1	8723	973.6	467.9
85	0.591	8556	955.6	473.1	8607	961.0	476.0	8659	966.4	478.8	8711	971.9	481.7

TEMPERATURE-ENTROPY TABLE

127

Temperature, Degrees Fahr.	Pressure, Pounds per Square Inch	1.80			1.81			1.82			1.83		
		Quality	Heat Con- tents	Specific Volume									
132 2.333	9344	1055.2	140.5	9402	1061.1	141.4	9460	1067.0	142.3	9518	1072.9	143.1	
131 2.272	9322	1053.5	143.9	9389	1059.4	144.8	9447	1045.4	145.7	9505	1071.5	146.6	
130 2.212	9319	1051.9	147.3	9377	1057.5	148.2	9435	1063.7	149.2	9492	1089.6	150.1	
129 2.153	9307	1050.3	151.1	9364	1056.2	152.0	9422	1062.1	152.9	9479	1068.0	153.8	
128 2.096	9295	1048.7	154.7	9352	1054.6	155.6	9409	1060.4	156.6	9466	1086.3	157.5	
127 2.040	9282	1047.1	158.4	9339	1053.0	159.4	9396	1058.8	160.4	9454	1084.7	161.4	
126 1.985	9270	1045.4	162.4	9327	1051.3	163.4	9384	1057.1	164.4	9441	1063.0	165.4	
125 1.932	9257	1043.8	166.4	9314	1049.7	167.5	9371	1055.5	168.5	9428	1081.4	169.5	
124 1.880	9245	1042.2	170.6	9301	1048.0	171.6	9358	1053.8	172.7	9415	1089.7	173.7	
123 1.829	9232	1040.6	174.8	9289	1046.4	175.8	9345	1052.2	176.9	9402	1058.1	178.0	
122 1.779	9220	1038.9	179.1	9276	1044.7	180.2	9333	1050.5	181.3	9389	1056.3	182.4	
121 1.730	9209	1037.3	183.7	9265	1043.1	184.8	9321	1048.9	186.0	9378	1054.7	187.1	
120 1.683	9196	1035.7	188.3	9252	1041.5	189.5	9309	1047.2	190.6	9365	1053.0	191.8	
119 1.636	9184	1034.1	193.1	9240	1039.9	194.3	9266	1045.6	195.5	9352	1051.4	196.7	
118 1.591	9171	1032.4	198.1	9227	1038.2	199.3	9283	1044.0	200.5	9339	1049.7	201.7	
117 1.547	9159	1030.8	203.1	9215	1036.5	204.4	9271	1042.3	205.6	9326	1048.0	206.9	
116 1.504	9146	1029.1	208.3	9202	1034.8	209.6	9257	1040.6	210.9	9313	1046.3	212.3	
115 1.462	9134	1027.5	213.7	9190	1033.2	215.0	9245	1039.0	216.3	9301	1044.7	217.6	
114 1.421	9122	1025.8	219.3	9177	1031.5	220.6	9232	1037.3	221.9	9288	1043.0	223.3	
113 1.381	9109	1024.2	225.0	9164	1029.9	226.4	9219	1035.6	227.7	9275	1040.4	229.1	
112 1.342	9097	1022.5	230.9	9152	1028.2	232.2	9207	1033.9	233.7	9262	1039.7	235.1	
111 1.304	9084	1020.9	237.0	9139	1026.6	238.4	9194	1032.3	239.9	9249	1038.0	241.3	
110 1.266	9072	1019.2	243.2	9127	1024.9	244.7	9182	1030.6	246.2	9237	1036.3	247.6	
109 1.230	9059	1017.6	249.7	9114	1023.3	251.2	9169	1028.9	252.7	9223	1034.7	254.2	
108 1.195	9047	1015.9	256.3	9102	1021.6	257.8	9156	1027.2	259.4	9211	1032.9	260.9	
107 1.160	9034	1014.3	263.1	9089	1019.9	264.7	9143	1025.6	266.3	9198	1031.2	267.8	
106 1.127	9022	1012.6	270.1	9076	1018.2	271.7	9131	1023.9	273.4	9185	1029.5	275.0	
105 1.094	9010	1010.9	277.5	9064	1016.5	279.2	9118	1022.2	280.8	9172	1027.8	282.5	
104 1.062	8997	1009.2	285.0	9051	1014.8	286.7	9105	1020.5	288.5	9159	1036.1	289.2	
103 1.031	8985	1007.6	292.8	9039	1013.2	294.6	9093	1018.8	296.3	9147	1024.5	298.1	
102 1.000	8972	1005.9	300.8	9026	1011.5	302.6	9080	1017.1	304.4	9134	1022.8	306.2	
101 0.971	8961	1004.2	309.0	9015	1009.8	310.8	9068	1015.4	312.7	9122	1021.1	314.5	
100 0.942	8948	1002.5	317.4	9002	1008.1	319.3	9055	1013.7	321.2	9109	1019.3	323.1	
99.0 0.914	8936	1001.9	326.3	8959	1006.5	328.3	9043	1012.0	330.2	9096	1017.6	332.2	
98.0 0.887	8923	999.2	335.4	8977	1004.8	337.4	9030	1010.3	339.4	9083	1015.9	341.4	
97.0 0.860	8911	997.6	344.8	8964	1003.2	346.8	9017	1008.7	348.9	9070	1013.3	350.9	
96.0 0.834	8899	996.0	354.5	8952	1001.5	356.7	9005	1007.1	358.8	9059	1012.6	360.9	
95.0 0.809	8887	994.3	364.5	8940	999.8	366.7	8993	1005.4	368.9	9046	1010.9	371.1	
94.0 0.784	8874	992.6	374.9	8927	998.1	377.1	8980	1003.7	389.3	9033	1009.2	381.5	
93.0 0.761	8862	990.9	385.5	8915	996.4	387.8	8967	1001.9	390.1	9020	1007.5	392.4	
92.0 0.737	8850	989.2	396.5	8902	994.7	398.9	8955	1000.2	401.3	9007	1005.8	403.6	
91.0 0.715	8837	987.5	408.0	8889	993.0	410.4	8942	998.5	412.8	8994	1004.1	415.3	
90.0 0.693	8825	985.8	419.7	8877	991.3	422.2	8929	996.8	424.7	8981	1002.3	427.2	
89.0 0.671	8812	984.1	431.8	8864	989.6	434.3	8916	995.1	436.9	8988	1000.6	438.5	
88.0 0.650	8799	982.4	444.2	8851	987.9	446.8	8903	993.4	449.4	8955	998.5	452.1	
87.0 0.630	8787	980.7	457.3	8839	986.2	460.0	8891	991.7	462.7	8943	997.1	465.4	
86.0 0.610	8775	979.0	470.7	8827	984.5	473.5	8878	990.0	476.2	8930	995.4	479.0	
85.0 0.591	8762	977.3	484.5	8814	982.8	487.4	8865	988.2	490.3	8917	993.7	493.1	

NAPERIAN LOGARITHMS.

 $e = 2.7182818$ $\log e = 0.4342945 - M$

	0	1	2	3	4	5	6	7	8	9
1.0	0.0000	0.00995	0.01980	0.02956	0.03922	0.04879	0.05827	0.06766	0.07696	0.08618
1.1	0.09531	0.1044	0.1133	0.1222	0.1310	0.1398	0.1484	0.1570	0.1655	0.1739
1.2	0.1823	0.1906	0.1988	0.2070	0.2151	0.2231	0.2311	0.2390	0.2469	0.2546
1.3	0.2624	0.2700	0.2776	0.2852	0.2927	0.3001	0.3075	0.3148	0.3221	0.3293
1.4	0.3365	0.3436	0.3507	0.3577	0.3646	0.3716	0.3784	0.3853	0.3920	0.3988
1.5	0.4055	0.4121	0.4187	0.4253	0.4318	0.4382	0.4447	0.4511	0.4574	0.4637
1.6	0.4700	0.4762	0.4824	0.4886	0.4947	0.5008	0.5068	0.5128	0.5188	0.5247
1.7	0.5306	0.5365	0.5423	0.5481	0.5539	0.5596	0.5653	0.5710	0.5766	0.5822
1.8	0.5878	0.5933	0.5988	0.6043	0.6098	0.6152	0.6206	0.6259	0.6313	0.6366
1.9	0.6418	0.6471	0.6523	0.6575	0.6627	0.6678	0.6729	0.6780	0.6831	0.6881
2.0	0.6931	0.6981	0.7031	0.7080	0.7129	0.7178	0.7227	0.7275	0.7324	0.7372
2.1	0.7419	0.7467	0.7514	0.7561	0.7608	0.7655	0.7701	0.7747	0.7793	0.7839
2.2	0.7884	0.7930	0.7975	0.8020	0.8065	0.8109	0.8154	0.8198	0.8242	0.8286
2.3	0.8329	0.8372	0.8416	0.8459	0.8502	0.8544	0.8587	0.8629	0.8671	0.8713
2.4	0.8755	0.8796	0.8838	0.8879	0.8920	0.8961	0.9002	0.9042	0.9083	0.9123
2.5	0.9163	0.9203	0.9243	0.9282	0.9322	0.9361	0.9400	0.9439	0.9478	0.9517
2.6	0.9555	0.9594	0.9632	0.9670	0.9708	0.9746	0.9783	0.9821	0.9858	0.9895
2.7	0.9933	0.9969	1.0006	1.0043	1.0080	1.0116	1.0152	1.0188	1.0225	1.0260
2.8	1.0296	1.0332	1.0367	1.0403	1.0438	1.0473	1.0508	1.0543	1.0578	1.0613
2.9	1.0647	1.0682	1.0716	1.0750	1.0784	1.0818	1.0852	1.0886	1.0919	1.0953
3.0	1.0986	1.1019	1.1053	1.1086	1.1119	1.1151	1.1184	1.1217	1.1249	1.1282
3.1	1.1314	1.1346	1.1378	1.1410	1.1442	1.1474	1.1506	1.1537	1.1569	1.1600
3.2	1.1632	1.1663	1.1694	1.1725	1.1756	1.1787	1.1817	1.1848	1.1878	1.1909
3.3	1.1939	1.1969	1.2000	1.2030	1.2060	1.2090	1.2119	1.2149	1.2179	1.2208
3.4	1.2238	1.2267	1.2296	1.2326	1.2355	1.2384	1.2413	1.2442	1.2470	1.2499
3.5	1.2528	1.2556	1.2585	1.2613	1.2641	1.2669	1.2698	1.2726	1.2754	1.2782
3.6	1.2809	1.2837	1.2865	1.2892	1.2920	1.2947	1.2975	1.3002	1.3029	1.3056
3.7	1.3083	1.3110	1.3137	1.3164	1.3191	1.3218	1.3244	1.3271	1.3297	1.3324
3.8	1.3350	1.3376	1.3403	1.3429	1.3455	1.3481	1.3507	1.3533	1.3558	1.3584
3.9	1.3610	1.3635	1.3661	1.3686	1.3712	1.3737	1.3762	1.3788	1.3813	1.3838
4.0	1.3863	1.3888	1.3913	1.3938	1.3962	1.3987	1.4012	1.4036	1.4061	1.4085
4.1	1.4110	1.4134	1.4159	1.4183	1.4207	1.4231	1.4255	1.4279	1.4303	1.4327
4.2	1.4351	1.4375	1.4398	1.4422	1.4446	1.4469	1.4493	1.4516	1.4540	1.4563
4.3	1.4586	1.4609	1.4633	1.4656	1.4679	1.4702	1.4725	1.4748	1.4770	1.4793
4.4	1.4816	1.4839	1.4861	1.4884	1.4907	1.4929	1.4951	1.4974	1.4996	1.5019
4.5	1.5041	1.5063	1.5085	1.5107	1.5129	1.5151	1.5173	1.5195	1.5217	1.5239
4.6	1.5261	1.5282	1.5304	1.5326	1.5347	1.5369	1.5390	1.5412	1.5433	1.5454
4.7	1.5476	1.5497	1.5518	1.5539	1.5560	1.5581	1.5602	1.5623	1.5644	1.5665
4.8	1.5686	1.5707	1.5728	1.5748	1.5769	1.5790	1.5810	1.5831	1.5851	1.5872
4.9	1.5892	1.5913	1.5933	1.5953	1.5974	1.5994	1.6014	1.6034	1.6054	1.6074
5.0	1.6094	1.6114	1.6134	1.6154	1.6174	1.6194	1.6214	1.6233	1.6253	1.6273
5.1	1.6292	1.6312	1.6332	1.6351	1.6371	1.6390	1.6409	1.6429	1.6448	1.6467
5.2	1.6457	1.6506	1.6525	1.6544	1.6563	1.6582	1.6601	1.6620	1.6639	1.6658
5.3	1.6677	1.6696	1.6715	1.6734	1.6752	1.6771	1.6790	1.6808	1.6827	1.6845
5.4	1.6864	1.6882	1.6901	1.6919	1.6938	1.6956	1.6974	1.6993	1.7011	1.7029
5.5	1.7047	1.7066	1.7084	1.7102	1.7120	1.7138	1.7156	1.7174	1.7192	1.7210
5.6	1.7228	1.7246	1.7263	1.7281	1.7299	1.7317	1.7334	1.7352	1.7370	1.7387

NAPERIAN LOGARITHMS.

LOGARITHMS.

Nat. Nos.	0	1	2	3	4	5	6	7	8	9	Proportional Parts.								
											1	2	3	4	5	6	7	8	9
10	0000	0043	0086	0128	0170	0212	0253	0294	0334	0374	4	8	12	17	21	25	29	33	37
11	0414	0453	0492	0531	0569	0607	0645	0682	0719	0755	4	8	11	15	19	23	26	30	34
12	0792	0828	0864	0899	0934	0969	1004	1038	1072	1106	3	7	10	14	17	21	24	28	31
13	1139	1173	1206	1239	1271	1303	1335	1367	1399	1430	3	6	10	13	16	19	23	26	29
14	1461	1492	1523	1553	1584	1614	1644	1673	1703	1732	3	6	9	12	15	18	21	24	27
15	1761	1790	1818	1847	1875	1903	1931	1959	1987	2014	3	6	8	11	14	17	20	22	25
16	2041	2068	2095	2122	2148	2175	2201	2227	2253	2279	3	5	8	11	13	16	18	21	24
17	2304	2330	2355	2380	2405	2430	2455	2480	2504	2529	2	5	7	10	12	15	17	20	22
18	2553	2577	2601	2625	2648	2672	2695	2718	2742	2765	2	5	7	9	12	14	16	19	21
19	2788	2810	2833	2856	2878	2900	2923	2945	2967	2989	2	4	7	9	11	13	16	18	20
20	3010	3032	3054	3075	3096	3118	3139	3160	3181	3201	2	4	6	8	11	13	15	17	19
21	3222	3243	3263	3284	3304	3324	3345	3365	3385	3404	2	4	6	8	10	12	14	16	18
22	3424	3444	3464	3483	3502	3522	3541	3560	3579	3598	2	4	6	8	10	12	14	15	17
23	3617	3636	3655	3674	3692	3711	3729	3747	3766	3784	2	4	6	7	9	11	13	15	17
24	3802	3820	3838	3856	3874	3892	3909	3927	3945	3962	2	4	5	7	9	11	12	14	16
25	3979	3997	4014	4031	4048	4065	4082	4099	4116	4133	2	3	5	7	9	10	12	14	15
26	4150	4166	4183	4200	4216	4232	4249	4265	4281	4298	2	3	5	7	8	10	11	13	15
27	4314	4330	4346	4362	4378	4393	4409	4425	4440	4456	2	3	5	6	8	9	11	13	14
28	4472	4487	4502	4518	4533	4548	4564	4579	4594	4609	2	3	5	6	8	9	11	12	14
29	4624	4639	4654	4669	4683	4698	4713	4728	4742	4757	1	3	4	6	7	9	10	12	13
30	4771	4786	4800	4814	4829	4843	4857	4871	4886	4900	1	3	4	6	7	9	10	11	13
31	4914	4928	4942	4955	4969	4983	4997	5011	5024	5038	1	3	4	6	7	8	10	11	12
32	5051	5065	5079	5092	5105	5119	5132	5145	5159	5172	1	3	4	5	7	8	9	11	12
33	5185	5198	5211	5224	5237	5250	5263	5276	5289	5302	1	3	4	5	6	8	9	10	12
34	5315	5328	5340	5353	5366	5378	5391	5403	5416	5428	1	3	4	5	6	8	9	10	11
35	5441	5453	5465	5478	5490	5502	5514	5527	5539	5551	1	2	4	5	6	7	9	10	11
36	5563	5575	5587	5599	5611	5623	5635	5647	5658	5670	1	2	4	5	6	7	8	10	11
37	5682	5694	5705	5717	5729	5740	5752	5763	5775	5786	1	2	3	5	6	7	8	9	10
38	5798	5809	5821	5832	5843	5855	5866	5877	5888	5899	1	2	3	5	6	7	8	9	10
39	5911	5922	5933	5944	5955	5966	5977	5988	5999	6010	1	2	3	4	5	7	8	9	10
40	6021	6031	6042	6053	6064	6075	6085	6096	6107	6117	1	2	3	4	5	6	8	9	10
41	6128	6138	6149	6160	6170	6180	6191	6201	6212	6222	1	2	3	4	5	6	7	8	9
42	6232	6243	6253	6263	6274	6284	6294	6304	6314	6325	1	2	3	4	5	6	7	8	9
43	6335	6345	6355	6365	6375	6385	6395	6405	6415	6425	1	2	3	4	5	6	7	8	9
44	6435	6444	6454	6464	6474	6484	6493	6503	6513	6522	1	2	3	4	5	6	7	8	9
45	6532	6542	6551	6561	6571	6580	6590	6599	6609	6618	1	2	3	4	5	6	7	8	9
46	6628	6637	6646	6656	6665	6675	6684	6693	6702	6712	1	2	3	4	5	6	7	7	8
47	6721	6730	6739	6749	6758	6767	6776	6785	6794	6803	1	2	3	4	5	5	6	7	8
48	6812	6821	6830	6839	6848	6857	6866	6875	6884	6893	1	2	3	4	4	5	6	7	8
49	6902	6911	6920	6928	6937	6946	6955	6964	6972	6981	1	2	3	4	4	5	6	7	8
50	6990	6998	7007	7016	7024	7033	7042	7050	7059	7067	1	2	3	3	4	5	6	7	8
51	7076	7084	7093	7101	7110	7118	7126	7135	7143	7152	1	2	3	3	4	5	6	7	8
52	7160	7168	7177	7185	7193	7202	7210	7218	7226	7235	1	2	2	3	4	5	6	7	7
53	7243	7251	7259	7267	7275	7284	7292	7300	7308	7316	1	2	2	3	4	5	6	6	7
54	7324	7332	7340	7348	7356	7364	7372	7380	7388	7396	1	2	2	3	4	5	6	6	7

LOGARITHMS.

Nat. Num.	0	1	2	3	4	5	6	7	8	9	Proportional Parts								
											1	2	3	4	5	6	7	8	9
55	7404	7412	7419	7427	7435	7443	7451	7459	7466	7474	1	2	2	3	4	5	5	6	7
56	7482	7490	7497	7505	7513	7520	7528	7536	7543	7551	1	2	2	3	4	5	5	6	7
57	7559	7566	7574	7582	7589	7597	7604	7612	7619	7627	1	2	2	3	4	5	5	6	7
58	7634	7642	7649	7657	7664	7672	7679	7686	7694	7701	1	1	2	3	4	5	5	6	7
59	7709	7716	7723	7731	7738	7745	7752	7760	7767	7774	1	1	2	3	4	5	5	6	7
60	7782	7789	7796	7803	7810	7818	7825	7832	7839	7846	1	1	2	3	4	4	5	6	6
61	7853	7860	7868	7875	7882	7889	7896	7903	7910	7917	1	1	2	3	4	4	5	6	6
62	7924	7931	7938	7945	7952	7959	7966	7973	7980	7987	1	1	2	3	3	4	5	5	6
63	7993	8000	8007	8014	8021	8028	8035	8041	8048	8055	1	1	2	3	3	4	5	5	6
64	8082	8089	8096	8082	8089	8096	8102	8109	8116	8122	1	1	2	3	3	4	5	5	6
65	8129	8136	8142	8149	8156	8162	8169	8176	8182	8189	1	1	2	3	3	4	5	5	6
66	8195	8202	8209	8215	8222	8228	8235	8241	8248	8254	1	1	2	3	3	4	5	5	6
67	8261	8267	8274	8280	8287	8293	8299	8306	8312	8319	1	1	2	3	3	4	5	5	6
68	8325	8331	8338	8344	8351	8357	8363	8370	8376	8382	1	1	2	3	3	4	4	5	6
69	8388	8395	8401	8407	8414	8420	8426	8432	8439	8445	1	1	2	2	3	4	4	5	6
70	8451	8457	8463	8470	8476	8482	8488	8494	8500	8506	1	1	2	2	3	4	4	5	6
71	8513	8519	8525	8531	8537	8543	8549	8555	8561	8567	1	1	2	2	3	4	4	5	5
72	8573	8579	8585	8591	8597	8603	8609	8615	8621	8627	1	1	2	2	3	4	4	5	5
73	8633	8639	8645	8651	8657	8663	8669	8675	8681	8686	1	1	2	2	3	4	4	5	5
74	8692	8698	8704	8710	8716	8722	8727	8733	8739	8745	1	1	2	2	3	4	4	5	5
75	8751	8756	8762	8768	8774	8779	8785	8791	8797	8802	1	1	2	2	3	3	4	5	5
76	8808	8814	8820	8825	8831	8837	8842	8848	8854	8859	1	1	2	2	3	3	4	5	5
77	8865	8871	8876	8882	8887	8893	8899	8904	8910	8915	1	1	2	2	3	3	4	4	5
78	8921	8927	8932	8938	8943	8949	8954	8960	8965	8971	1	1	2	2	3	3	4	4	5
79	8976	8982	8987	8993	8998	9004	9009	9015	9020	9025	1	1	2	2	3	3	4	4	5
80	9031	9036	9042	9047	9053	9058	9063	9069	9074	9079	1	1	2	2	3	3	4	4	5
81	9085	9090	9096	9101	9106	9112	9117	9122	9128	9133	1	1	2	2	3	3	4	4	5
82	9135	9143	9149	9154	9159	9165	9170	9175	9180	9185	1	1	2	2	3	3	4	4	5
83	9191	9196	9201	9206	9212	9217	9222	9227	9232	9238	1	1	2	2	3	3	4	4	5
84	9243	9248	9253	9258	9263	9269	9274	9279	9284	9289	1	1	2	2	3	3	4	4	5
85	9294	9299	9304	9309	9315	9320	9325	9330	9335	9340	1	1	2	2	3	3	4	4	5
86	9345	9350	9355	9360	9365	9370	9375	9380	9385	9390	1	1	2	2	3	3	4	4	5
87	9395	9400	9405	9410	9415	9420	9425	9430	9435	9440	0	1	1	2	2	3	3	4	4
88	9445	9450	9455	9460	9465	9469	9474	9479	9484	9489	0	1	1	2	2	3	3	4	4
89	9494	9499	9504	9509	9513	9518	9523	9528	9533	9538	0	1	1	2	2	3	3	4	4
90	9542	9547	9552	9557	9562	9566	9571	9576	9581	9586	0	1	1	2	2	3	3	4	4
91	9590	9595	9600	9605	9609	9614	9619	9624	9628	9633	0	1	1	2	2	3	3	4	4
92	9638	9643	9647	9652	9657	9661	9666	9671	9675	9680	0	1	1	2	2	3	3	4	4
93	9685	9689	9694	9699	9703	9708	9713	9717	9722	9727	0	1	1	2	2	3	3	4	4
94	9731	9736	9741	9745	9750	9754	9759	9763	9768	9773	0	1	1	2	2	3	3	4	4
95	9777	9782	9786	9791	9795	9800	9805	9809	9814	9818	0	1	1	2	2	3	3	4	4
96	9823	9827	9832	9836	9841	9845	9850	9854	9859	9863	0	1	1	2	2	3	3	4	4
97	9868	9872	9877	9881	9886	9890	9894	9899	9903	9908	0	1	1	2	2	3	3	4	4
98	9912	9917	9921	9926	9930	9934	9939	9943	9948	9952	0	1	1	2	2	3	3	4	4
99	9956	9961	9965	9969	9974	9978	9983	9987	9991	9996	0	1	1	2	2	3	3	4	4

SHORT-TITLE CATALOGUE
OF THE
PUBLICATIONS
OF
JOHN WILEY & SONS,
NEW YORK.
LONDON: CHAPMAN & HALL, LIMITED.
ARRANGED UNDER SUBJECTS.

Descriptive circulars sent on application. Books marked with an asterisk (*) are sold at net prices only. All books are bound in cloth unless otherwise stated.

AGRICULTURE.

Armsby's Manual of Cattle-feeding.	12mo, 2 <i>1</i> 75
Principles of Animal Nutrition.	8vo, 4 00
Budd and Hansen's American Horticultural Manual.	
Part I. Propagation, Culture, and Improvement.	12mo, 1 50
Part II. Systematic Pomology.	12mo, 1 50
Elliott's Engineering for Land Drainage.	12mo, 1 50
Practical Farm Drainage.	12mo, 1 00
Graves's Forest Mensuration.	8vo, 4 00
Green's Principles of American Forestry.	12mo, 1 50
Grotenfels's Principles of Modern Dairy Practice. (Woll.)	12mo, 2 00
Hanausek's Microscopy of Technical Products. (Winton.)	8vo, 5 00
Herrick's Denatured or Industrial Alcohol.	8vo, 4 00
Maynard's Landscape Gardening as Applied to Home Decoration.	12mo, 1 50
* McKay and Larsen's Principles and Practice of Butter-making.	8vo, 1 50
Sanderson's Insects Injurious to Staple Crops.	12mo, 1 50
* Schwarz's Longleaf Pine in Virgin Forest.	12mo, 1 25
Stockbridge's Rocks and Soils.	8vo, 2 50
Winton's Microscopy of Vegetable Foods.	8vo, 2 50
Woll's Handbook for Farmers and Dairymen.	16mo, 1 50

ARCHITECTURE.

Baldwin's Steam Heating for Buildings.	12mo, 2 50
Bashore's Sanitation of a Country House.	12mo, 1 00
Berg's Buildings and Structures of American Railroads.	12mo, 5 00
Birkmire's Planning and Construction of American Theatres.	8vo, 3 00
Architectural Iron and Steel.	8vo, 3 50
Compound Riveted Girders as Applied in Buildings.	8vo, 2 00
Planning and Construction of High Office Buildings.	8vo, 3 50
Skeleton Construction in Buildings.	8vo, 3 00
Brigg's Modern American School Buildings.	8vo, 4 00
Carpenter's Heating and Ventilating of Buildings.	8vo, 4 00

Freitag's Architectural Engineering.....	8vo.	3 50
Fireproofing of Steel Buildings.....	8vo.	2 50
French and Ives's Stereotomy.....	8vo.	2 50
Gerhard's Guide to Sanitary House-inspection.....	16mo.	1 00
Sanitation of Public Buildings.....	12mo.	1 50
Theatre Fires and Panics.....	12mo.	1 50
*Greene's Structural Mechanics.....	8vo.	2 50
Holly's Carpenters' and Joiners' Handbook.....	18mo.	.75
Johnson's Statics by Algebraic and Graphic Methods.....	8vo.	2 00
Kellaway's How to Lay Out Suburban Home Grounds.....	8vo.	2 00
Kidder's Architects' and Builders' Pocket-book. Rewritten Edition. 16mo, mor.,	5 00	
Merrill's Stones for Building and Decoration.....	8vo.	5 00
Non-metallic Minerals: Their Occurrence and Uses.....	8vo.	4 00
Monckton's Stair-building.....	4to.	4 00
Patton's Practical Treatise on Foundations.....	8vo.	5 00
Peabody's Naval Architecture.....	8vo.	7 50
Rice's Concrete-block Manufacture.....	8vo.	2 00
Richey's Handbook for Superintendents of Construction.....	16mo, mor.,	4 00
* Building Mechanics' Ready Reference Book:		
* Carpenters' and Woodworkers' Edition.....	16mo, morocco,	1 50
* Cementworkers and Plasterer's Edition. (In Press.)		
* Stone- and Brick-mason's Edition.....	12mo, mor.,	1 50
Sabin's Industrial and Artistic Technology of Paints and Varnish.....	8vo.	3 00
Siebert and Biggin's Modern Stone-cutting and Masonry.....	8vo.	1 50
Snow's Principal Species of Wood.....	8vo.	3 50
Sondericker's Graphic Statics with Applications to Trusses, Beams, and Arches.		
	8vo.	2 00
Towne's Locks and Builders' Hardware.....	18mo, morocco,	3 00
Turneaure and Maurer's Principles of Reinforced Concrete Construction.....	8vo.	3 00
Wait's Engineering and Architectural Jurisprudence.....	8vo.	6 00
	Sheep.	6 50
Law of Operations Preliminary to Construction in Engineering and Architecture.....	8vo.	5 00
	Sheep.	5 50
Law of Contracts.....	8vo.	3 00
Wilson's Air Conditioning. (In Press.)		
Wood's Rustless Coatings: Corrosion and Electrolysis of Iron and Steel. 8vo.	4 00	
Worcester and Atkinson's Small Hospitals, Establishment and Maintenance, Suggestions for Hospital Architecture, with Plans for a Small Hospital.		
	12mo.	1 25
The World's Columbian Exposition of 1893.....	Large 4to.	1 00

ARMY AND NAVY.

Bernadou's Smokeless Powder, Nitro-cellulose, and the Theory of the Cellulose Molecule.....	12mo.	2 50
Chase's Screw Propellers and Marine Propulsion.....	8vo.	3 00
Cloke's Gunner's Examiner.....	8vo.	1 50
Craig's Azimuth.....	4to.	3 50
Crehore and Squier's Polarizing Photo-chronograph.....	8vo.	3 00
* Davis's Elements of Law.....	8vo.	2 50
* Treatise on the Military Law of United States.....	8vo.	7 00
	Sheep.	7 50
De Brack's Cavalry Outposts Duties. (Carr.).	24mo, morocco,	2 00
Dietz's Soldier's First Aid Handbook.....	16mo, morocco.	1 25
* Dudley's Military Law and the Procedure of Courts-martial. Large 12mo.	2 50	
Durand's Resistance and Propulsion of Ships.....	8vo.	5 00

• Dyer's Handbook of Light Artillery	12mo, 3 00
Einsler's Modern High Explosives	8vo, 4 00
• Fiebeger's Text-book on Field Fortification	Small 8vo, 3 00
Hamilton's The Gunner's Catechism	18mo, 1 00
• Hoff's Elementary Naval Tactics	8vo, 1 50
Ingalls's Handbook of Problems in Direct Fire	8vo, 4 00
• Lienau's Ordnance and Gunnery	8vo, 6 00
• Lyons's Treatise on Electromagnetic Phenomena. Vol. I. and II. 8vo, each	6 00
• Mahan's Permanent Fortifications. (Mercur.)	8vo, half morocco, 7 50
Manual for Courts-martial	16mo, morocco, 1 50
• Mercur's Attack of Fortified Places	12mo, 3 00
• Elements of the Art of War	8vo, 4 00
Metcalf's Cost of Manufactures And the Administration of Workshops 8vo, 5 00	
• Ordnance and Gunnery. 2 vols.	12mo, 5 00
Murray's Infantry Drill Regulations	18mo, paper, 10
Nixon's Adjutants' Manual	14mo, 1 00
Peabody's Naval Architecture	8vo, 7 50
• Phelps's Practical Marine Surveying	8vo, 2 50
Powell's Army Officer's Examiner	12mo, 4 00
Sharpe's Art of Subsisting Armies in War	18mo, morocco, 1 50
• Tupes and Poole's Manual of Bayonet Exercises and Musketry Fencing	24mo, leather, 50
Weaver's Military Explosives	8vo, 3 00
Wheeler's Siege Operations and Military Mining	8vo, 2 00
Winthrop's Abridgment of Military Law	12mo, 2 50
Woodhull's Notes on Military Hygiene	16mo, 1 50
Young's Simple Elements of Navigation	16mo, morocco, 2 00

ASSAYING.

Fletcher's Practical Instructions in Quantitative Assaying with the Blowpipe	12mo, morocco, 1 50
Furman's Manual of Practical Assaying	8vo, 3 00
Lodge's Notes on Assaying and Metallurgical Laboratory Experiments	8vo, 3 00
Low's Technical Methods of Ore Analysis	8vo, 3 00
Miller's Manual of Assaying	12mo, 1 00
Cyanide Process	12mo, 1 00
Minet's Production of Aluminum and its Industrial Use. (Waldo.)	12mo, 2 50
O'Driscoll's Notes on the Treatment of Gold Ores	8vo, 2 00
Ricketts and Miller's Notes on Assaying	8vo, 3 00
Robine and Lenglen's Cyanide Industry. (Le Clerc.)	8vo, 4 00
Ulke's Modern Electrolytic Copper Refining	8vo, 3 00
Wilson's Cyanide Processes	12mo, 1 50
Chlorination Process	12mo, 1 50

ASTRONOMY.

Comstock's Field Astronomy for Engineers	8vo, 2 50
Craig's Azimuth	4to, 3 50
Crandall's Text-book on Geodesy and Least Squares	8vo, 3 00
Doolittle's Treatise on Practical Astronomy	8vo, 4 00
Gore's Elements of Geodesy	8vo, 2 50
Hayford's Text-book of Geodetic Astronomy	8vo, 3 00
Merriman's Elements of Precise Surveying and Geodesy	8vo, 2 50
• Michie and Harlow's Practical Astronomy	8vo, 3 00
• White's Elements of Theoretical and Descriptive Astronomy	12mo, 2 00

BOTANY.

Davenport's Statistical Methods, with Special Reference to Biological Variation.	16mo, morocco, 1 25
Thomé and Bennett's Structural and Physiological Botany.....	16mo, 2 25
Westermaier's Compendium of General Botany. (Schneider).	8vo, 2 00

CHEMISTRY.

* Abegg's Theory of Electrolytic Dissociation. (Von Ende.)	12mo, 1 25
Adriance's Laboratory Calculations and Specific Gravity Tables.....	12mo, 1 25
Alexeyeff's General Principles of Organic Synthesis. (Matthews.)	8vo, 3 00
Allen's Tables for Iron Analysis.....	8vo, 3 00
Arnold's Compendium of Chemistry. (Mandel.)	Small 8vo, 3 50
Austen's Notes for Chemical Students.....	12mo, 1 50
Beard's Mine Gases and Explosions. (In Press.)	
Bernadou's Smokeless Powder.—Nitro-cellulose, and Theory of the Cellulose Molecule.....	12mo, 3 50
Bolduan's Immune Seria.....	12mo, 1 50
* Browning's Introduction to the Rarer Elements.	8vo, 1 50
Brush and Penfield's Manual of Determinative Mineralogy.....	8vo, 4 00
* Claassen's Beet-sugar Manufacture. (Hall and Rolfe.)	8vo, 3 00
Claassen's Quantitative Chemical Analysis by Electrolysis. (Boltwood.)	8vo, 3 00
Cohn's Indicators and Test-papers.	12mo, 3 00
Tests and Reagents.	8vo, 3 00
Crafts's Short Course in Qualitative Chemical Analysis. (Schaeffer.)	12mo, 1 50
* Danneel's Electrochemistry. (Merriam.)	12mo, 1 25
Dolezalek's Theory of the Lead Accumulator (Storage Battery). (Von Ende.)	12mo, 2 50
Drechsel's Chemical Reactions. (Merrill.)	12mo, 1 25
Duhem's Thermodynamics and Chemistry. (Burgess.)	8vo, 4 00
Eissler's Modern High Explosives.....	8vo, 4 00
Effron's Enzymes and their Applications. (Prescott.)	8vo, 3 00
Erdmann's Introduction to Chemical Preparations. (Dunlap.)	12mo, 1 25
* Fischer's Physiology of Alimentation.....	Large 12mo, 2 00
Fletcher's Practical Instructions in Quantitative Assaying with the Blowpipe.	12mo, morocco, 1 50
Fowler's Sewage Works Analyses.....	12mo, 2 00
Fresenius's Manual of Qualitative Chemical Analysis. (Wells.)	8vo, 5 00
Manual of Qualitative Chemical Analysis. Part I. Descriptive. (Wells.)	8vo, 3 00
Quantitative Chemical Analysis. (Cohn.) 2 vols.	8vo, 12 50
Fuertes's Water and Public Health.....	12mo, 1 50
Furman's Manual of Practical Assaying.....	8vo, 3 00
* Getman's Exercises in Physical Chemistry.....	12mo, 2 00
Gill's Gas and Fuel Analysis for Engineers.....	12mo, 1 25
* Gooch and Browning's Outlines of Qualitative Chemical Analysis. Small 8vo,	1 25
Grotenhelt's Principles of Modern Dairy Practice. (Woll.)	12mo, 2 00
Groth's Introduction to Chemical Crystallography (Marshall)	12mo, 1 25
Hammarsten's Text-book of Physiological Chemistry. (Mandel.)	8vo, 4 00
Hanausek's Microscopy of Technical Products. (Winton.)	8vo, 5 00
* Haskin's and MacLeod's Organic Chemistry.....	12mo, 2 00
Heim's Principles of Mathematical Chemistry. (Morgan.)	12mo, 1 50
Hering's Ready Reference Tables (Conversion Factors).	16mo, morocco, 2 50
Herrick's Denatured or Industrial Alcohol.	8vo, 4 00
Hind's Inorganic Chemistry.....	8vo, 3 00
* Laboratory Manual for Students.....	12mo, 1 00
Holleman's Text-book of Inorganic Chemistry. (Cooper.)	8vo, 2 50
Text-book of Organic Chemistry. (Walker and Mott.)	8vo, 2 50
* Laboratory Manual of Organic Chemistry. (Walker.)	12mo, 1 00

Holley and Ladd's Analysis of Mixed Paints, Color Pigments, and Varnishes. (In Press)	
Hopkins's Oil-chemists' Handbook.	Evo., 3 00
Iddings's Rock Minerals.	Evo., 5 00
Jackson's Directions for Laboratory Work in Physiological Chemistry.	Evo., 1 25
Johannsen's Key for the Determination of Rock-forming Minerals in Thin Sec- tions. (In Press)	
Keep's Cast Iron.	Evo., 2 50
Ladd's Manual of Quantitative Chemical Analysis	12mo., 1 00
Landauer's Spectrum Analysis. (Tingle.)	Evo., 3 00
* Langworthy and Austen. The Occurrence of Aluminum in Vegetable Products, Animal Products, and Natural Waters.	Evo., 2 00
Lazar-Cohn's Application of Some General Reactions to Investigations in Organic Chemistry. (Tingle.)	12mo., 1 00
Leach's The Inspection and Analysis of Food with Special Reference to State Control.	
Leib's Electrochemistry of Organic Compounds. (Lorenz.).	Evo., 7 50
Lodge's Notes on Assaying and Metallurgical Laboratory Experiments.	Evo., 3 00
Lew's Technical Method of Ore Analysis.	Evo., 3 00
Lunge's Techno-chemical Analysis. (Cohn.).	12mo. 1 00
* McKay and Larsen's Principles and Practice of Butter-making.	Evo., 1 50
Maire's Modern Pigments and their Vehicles. (In Press.)	
Mandel's Handbook for Bio-chemical Laboratory	12mo., 1 50
* Martin's Laboratory Guide to Qualitative Analysis with the Blowpipe.	12mo., 60
Mason's Water supply. (Considered Principally from a Sanitary Standpoint.) 3d Edition, Rewritten.	
Examination of Water. (Chemical and Bacteriological.)	12mo., 1 25
Matthew's The Textile Fibres. 3d Edition, Rewritten	Evo., 4 00
Meyer's Determination of Radicles in Carbon Compounds. (Tingle.).	12mo., 1 00
Miller's Manual of Assaying. Cyanide Process	12mo., 1 00
Minet's Production of Aluminum and its Industrial Use. (Waldo.).	12mo., 2 50
Mister's Elementary Text-book of Chemistry.	12mo., 1 50
Morgan's An Outline of the Theory of Solutions and its Results Elements of Physical Chemistry.	12mo., 3 00
* Palmer's Practical Test Book of Chemistry.	12mo., 5 00
Morse's Calculations used in Cane-sugar Factories.	16mo., morocco, 1 50
* Mu'r's History of Chemical Theories and Laws.	Evo., 4 00
Mulliken's General Method for the Identification of Pure Organic Compounds. Vol. I.	Large Evo., 5 00
O'Driscoll's Notes on the Treatment of Gold Ores.	Evo., 2 00
Ostwald's Conversations on Chemistry. Part One. (Ramsey.).	12mo., 1 50
" " " " " Part Two. (Turnbull.)	12mo., 2 00
* Palmer's Practical Test Book of Chemistry.	12mo., 1 00
* Paul's Physical Chemistry in the Service of Medicine. (Fischer.).	12mo., 1 25
* Penfield's Notes on Determinative Mineralogy and Record of Mineral Tests.	
Pictet's The Alkaloids and their Chemical Constitution. (Biddle.)	Evo., 5 00
Pinner's Introduction to Organic Chemistry. (Austen.).	12mo., 1 50
Poole's Calorific Power of Fuels.	Evo., 3 00
Prescott and Winslow's Elements of Water Bacteriology, with Special Refer- ence to Sanitary Water Analysis.	12mo., 1 25
* Rainig's Guide to Piece-dyeing.	Evo., 25 00
Richards and Woodman's Air, Water, and Food from a Sanitary Standpoint.	Evo., 3 00
Ricketts and Miller's Notes on Assaying.	Evo., 3 00
Rideal's Sewage and the Bacterial Purification of Sewage..	Evo., 4 00
Disinfection and the Preservation of Food.	Evo., 4 00
Riggs's Elementary Manual for the Chemical Laboratory	Evo., 1 25
Robine and Lenglen's Cyanide Industry. (Le Clerc.)	Evo., 4 00

Ruddiman's Incompatibilities in Prescriptions.....	8vo, 2 00
* Whys in Pharmacy	12mo, 1 00
Sabin's Industrial and Artistic Technology of Paints and Varnish.....	8vo, 3 00
Salkowski's Physiological and Pathological Chemistry. (Orndorff.).....	8vo, 2 50
Schimpf's Text-book of Volumetric Analysis.....	12mo, 2 50
Essentials of Volumetric Analysis.....	12mo, 1 25
* Qualitative Chemical Analysis	8vo, 1 25
Smith's Lecture Notes on Chemistry for Dental Students.....	8vo, 2 50
Spencer's Handbook for Chemists of Beet-sugar Houses.....	16mo, morocco 3 00
Handbook for Cane Sugar Manufacturers.....	16mo, morocco, 3 00
Stockbridge's Rocks and Soils.....	8vo, 2 50
* Tillman's Elementary Lessons in Heat.....	8vo, 1 50
* Descriptive General Chemistry.....	8vo, 3 00
Treadwell's Qualitative Analysis. (Hall.).....	8vo, 3 00
Quantitative Analysis. (Hall.).....	8vo, 4 00
Turneaure and Russell's Public Water-supplies.....	8vo, 5 00
Van Deventer's Physical Chemistry for Beginners. (Boltwood.).....	12mo, 1 50
* Walké's Lectures on Explosives.....	8vo, 4 00
Ware's Beet-sugar Manufacture and Refining. Vol. I.....	Small 8vo, 4 00
" " " " " Vol. II.....	Small 8vo, 5 00
Washington's Manual of the Chemical Analysis of Rocks.....	8vo, 2 00
Weaver's Military Explosives.....	8vo, 2 00
Wehrfennig's Analysis and Softening of Boiler Feed-Water.....	8vo, 4 00
Wells's Laboratory Guide in Qualitative Chemical Analysis.....	8vo, 1 50
Short Course in Inorganic Qualitative Chemical Analysis for Engineering Students.....	12mo, 1 50
Text-book of Chemical Arithmetic.....	12mo, 1 25
Whipple's Microscopy of Drinking-water.....	8vo, 3 50
Wilson's Cyanide Processes.....	12mo, 1 50
Chlorination Process.....	12mo, 1 50
Winton's Microscopy of Vegetable Foods	8vo, 7 50
Wulling's Elementary Course in Inorganic, Pharmaceutical, and Medical Chemistry.....	12mo, 2 00

CIVIL ENGINEERING.

BRIDGES AND ROOFS. HYDRAULICS. MATERIALS OF ENGINEERING RAILWAY ENGINEERING.

Baker's Engineers' Surveying Instruments.....	12mo, 3 00
Bixby's Graphical Computing Table.....	Paper 19½ x 24½ inches. 25
Breed and Hosmer's Principles and Practice of Surveying.....	8vo, 3 00
* Burr's Ancient and Modern Engineering and the Isthmian Canal	8vo, 3 50
Comstock's Field Astronomy for Engineers.....	8vo, 2 50
* Corthell's Allowable Pressures on Deep Foundations.....	12mo, 1 25
Crandall's Text-book on Geodesy and Least Squares.....	8vo, 3 00
Davis's Elevation and Stadia Tables.....	8vo, 1 00
Elliott's Engineering for Land Drainage.....	12mo, 1 50
Practical Farm Drainage.....	12mo, 1 00
*Fiebeger's Treatise on Civil Engineering.....	8vo, 5 00
Flemer's Photopographic Methods and Instruments.....	8vo, 5 00
Folwell's Sewerage. (Designing and Maintenance).	8vo, 3 00
Freitag's Architectural Engineering. 2d Edition, Rewritten.....	8vo, 3 50
French and Ives's Stereotomy.....	8vo, 2 50
Goodhue's Municipal Improvements.....	12mo, 1 50
Gore's Elements of Geodesy.....	8vo, 2 50
* Hauch and Rice's Tables of Quantities for Preliminary Estimates.....	12mo, 1 25
Hayford's Text-book of Geodetic Astronomy.....	8vo, 3 00

Hering's Ready Reference Tables (Conversion Factors)	16mo, morocco, 1 50
Howe's Retaining Walls for Earth.	12mo, 1 25
Hoyt and Grover's River Discharge	8vo, 1 00
* Ives's Adjustments of the Engineer's Transit and Level	16mo, 1ds, .75
Ives and Hills's Problems in Surveying	16mo, morocco, 1 50
Johnson's (J. R.) Theory and Practice of Surveying	Small 8vo, 4 00
Johnson's (L. J.) Statics by Algebraic and Graphic Methods	8vo, 3 00
Laplace's Philosophical Essay on Probabilities. (Truscott and Emory)	12mo, 3 00
Mahan's Treatise on Civil Engineering. (1873.) (Wood)	8vo, 5 00
* Descriptive Geometry.	8vo, 1 50
Merriman's Elements of Precise Surveying and Geodesy	8vo, 3 50
Merriman and Brooks's Handbook for Surveyors	16mo, morocco, 3 00
Nugent's Plane Surveying.	8vo, 3 50
Ogden's Sewer Design.	12mo, 2 00
Parsons's Disposal of Municipal Refuse.	8vo, 3 00
Patton's Treatise on Civil Engineering	8vo half leather, 7 50
Reed's Topographical Drawing and Sketching	4to, 5 00
Rideal's Sewage and the Bacterial Purification of Sewage	8vo, 4 00
Riemer's Shaft-sinking under Difficult Conditions. (Corning and Peeler)	8vo, 3 00
Siebert and Biggin's Modern Stone-cutting and Masonry	8vo, 3 50
Smith's Manual of Topographical Drawing. (McMillan)	8vo, 2 50
Sondericker's Graphic Statics, with Applications to Trusses, Beams, and Arches	8vo, 2 00
Taylor and Thompson's Treatise on Concrete, Plain and Reinforced	8vo, 5 00
Tracy's Plane Surveying.	16mo, morocco, 3 00
* Trautwine's Civil Engineer's Pocket-book.	16mo, morocco, 5 00
Venable's Garbage Crematories in America	8vo, 2 00
Wait's Engineering and Architectural Jurisprudence.	8vo, 6 00
	Sheep, 6 50
Law of Operations Preliminary to Construction in Engineering and Architecture.	8vo, 5 00
	Sheep, 5 50
Law of Contracts.	8vo, 3 00
Warren's Stereotomy—Problems in Stone-cutting.	8vo, 2 50
Webb's Problems in the Use and Adjustment of Engineering Instruments.	16mo, morocco, 1 25
Wilson's Topographic Surveying.	8vo, 3 50

BRIDGES AND ROOFS.

Boller's Practical Treatise on the Construction of Iron Highway Bridges	8vo, 2 00
Burr and Falk's Influence Lines for Bridge and Roof Computations.	8vo, 3 00
Design and Construction of Metallic Bridges	8vo, 5 00
Du Bois's Mechanics of Engineering. Vol. II.	Small 4to, 10 00
Foster's Treatise on Wooden Trestle Bridges.	4to, 5 00
Fowler's Ordinary Foundations	8vo, 3 50
Greene's Roof Trusses.	8vo, 1 25
Bridge Trusses.	8vo, 2 50
Arches in Wood, Iron, and Stone.	8vo, 2 50
Grimm's Secondary Stresses in Bridge Trusses. (In Press.)	
Howe's Treatise on Arches.	8vo, 4 00
Design of Simple Roof-trusses in Wood and Steel.	8vo, 2 00
Symmetrical Masonry Arches.	8vo, 2 50
Johnson, Bryan, and Turnesure's Theory and Practice in the Designing of Modern Framed Structures.	Small 4to, 10 00
Merriman and Jacoby's Text-book on Roofs and Bridges:	
Part I. Stresses in Simple Trusses.	8vo, 2 50
Part II. Graphic Statics.	8vo, 2 50
Part III. Bridge Design.	8vo, 2 50
Part IV. Higher Structures.	8vo, 2 50

Morison's Memphis Bridge.	4to, 10	00
Waddell's De Pontibus, a Pocket-book for Bridge Engineers.	16mo, morocco,	2 00
* Specifications for Steel Bridges.	12mo,	50
Wright's Designing of Draw-spans. Two parts in one volume.	8vo, 3	50

HYDRAULICS.

Barnes's Ice Formation.	8vo,	3 00
Bazin's Experiments upon the Contraction of the Liquid Vein Issuing from an Orifice. (Trautwine).	8vo,	2 00
Bovey's Treatise on Hydraulics.	8vo,	5 00
Church's Mechanics of Engineering.	8vo,	6 00
Diagrams of Mean Velocity of Water in Open Channels.	paper,	1 50
Hydraulic Motors.	8vo,	2 00
Coffin's Graphical Solution of Hydraulic Problems.	16mo, morocco,	2 50
Flather's Dynamometers, and the Measurement of Power.	12mo,	3 00
Folwell's Water-supply Engineering.	8vo,	4 00
Frizzell's Water-power.	8vo,	5 00
Fuertes's Water and Public Health.	12mo,	1 50
Water-filtration Works.	12mo,	2 50
Ganguillet and Kutter's General Formula for the Uniform Flow of Water in Rivers and Other Channels. (Hering and Trautwine).	8vo,	4 00
Hazen's Clean Water and How to Get It.	Large 12mo,	1 50
Filtration of Public Water-supply.	8vo,	3 00
Hazlehurst's Towers and Tanks for Water-works.	8vo,	2 50
Herschel's 115 Experiments on the Carrying Capacity of Large, Riveted, Metal Conduits.	8vo,	2 00
* Hubbard and Kiersted's Water-works Management and Maintenance.	8vo,	4 00
Mason's Water-supply. (Considered Principally from a Sanitary Standpoint.)	8vo,	4 00
Merriman's Treatise on Hydraulics.	8vo,	5 00
* Michie's Elements of Analytical Mechanics.	8vo,	4 00
Schuyler's Reservoirs for Irrigation, Water-power, and Domestic Water-supply.	Large 8vo,	5 00
* Thomas and Watt's Improvement of Rivers.	4to,	6 00
Turneaure and Russell's Public Water-supplies.	8vo,	5 00
Wegmann's Design and Construction of Dams. 5th Edition, enlarged.	4to,	6 00
Water-supply of the City of New York from 1658 to 1895.	4to,	10 00
Whipple's Value of Pure Water.	Large 12mo,	1 00
Williams and Hazen's Hydraulic Tables.	8vo,	1 50
Wilson's Irrigation Engineering.	Small 8vo,	4 00
Wolff's Windmill as a Prime Mover.	8vo,	3 00
Wood's Turbines.	8vo,	2 50
Elements of Analytical Mechanics.	8vo,	3 00

MATERIALS OF ENGINEERING.

Baker's Treatise on Masonry Construction.	8vo,	5 00
Roads and Pavements.	8vo,	5 00
Black's United States Public Works.	Oblong 4to,	5 00
* Bovey's Strength of Materials and Theory of Structures.	8vo,	7 50
Burr's Elasticity and Resistance of the Materials of Engineering.	8vo,	7 50
Byrne's Highway Construction.	8vo,	5 00
Inspection of the Materials and Workmanship Employed in Construction.	16mo,	3 00
Church's Mechanics of Engineering.	8vo,	6 00
Du Bois's Mechanics of Engineering. Vol. I.	Small 4to	7 50
* Eckel's Cements, Limes, and Plasters.	8vo,	6 00

Johnson's Materials of Construction.....	Large Svo.	6 00
Fowler's Ordinary Foundations.....	Svo.	3 50
Graves's Forest Measurement.....	Svo.	4 00
* Greene's Structural Mechanics.....	Svo.	3 50
Keep's Cast Iron.....	Svo.	3 50
Laurie's Applied Mechanics.....	Svo.	7 50
Martens's Handbook on Testing Materials. (Henning : 2 vols.).....	Svo.	7 50
Maurer's Technical Mechanics.....	Svo.	4 00
Merrill's Stones for Building and Decoration.....	Svo.	5 00
Merriman's Mechanics of Materials.....	Svo.	5 00
* Strength of Materials.....	12mo.	1 00
Metcalf's Steel. A Manual for Steel-users.....	12mo.	3 00
Patton's Practical Treatise on Foundations.....	Svo.	5 00
Richardson's Modern Asphalt Pavements.....	Svo.	3 00
Richey's Handbook for Superintendents of Construction.....	16mo. mor.	4 00
* Ross's Clays: Their Occurrence, Properties, and Uses.....	Svo.	5 00
Rockwell's Roads and Pavements in France.....	12mo.	1 25
Sabin's Industrial and Artistic Technology of Paints and Varnish.....	Svo.	3 00
* Schwarz's Longleaf Pine in Virgin Forest.....	12mo.	1 25
Smith's Materials of Machines.....	12mo.	1 00
Snow's Principal Species of Wood.....	Svo.	3 50
Spalding's Hydraulic Cement.....	12mo.	2 00
Text-book on Roads and Pavements.....	12mo.	2 00
Taylor and Thompson's Treatise on Concrete, Plain and Reinforced.....	Svo.	5 00
Thurston's Materials of Engineering. 3 Parts.....	Svo.	8 00
Part I. Non-metallic Materials of Engineering and Metallurgy.....	Svo.	2 00
Part II. Iron and Steel.....	Svo.	3 50
Part III. A Treatise on Brasses, Bronzes, and Other Alloys and their Constituents.....	Svo.	2 50
Tilson's Street Pavements and Paving Materials.....	Svo.	4 00
Turneaure and Maurer's Principles of Reinforced Concrete Construction.....	svo.	3 00
Waddell's De Pantibus. A Pocket-book for Bridge Engineers.....	16mo. mor.	2 00
* Specifications for Steel Bridges.....	12mo.	.50
Wood's (De V.) Treatise on the Resistance of Materials, and an Appendix on the Preservation of Timber.....	Svo.	2 00
Wood's (De V.) Elements of Analytical Mechanics.....	Svo.	3 00
Wood's (M. P.) Rustless Coatings. Corrosion and Electrolysis of Iron and Steel.....	Svo.	4 00

RAILWAY ENGINEERING.

Andrew's Handbook for Street Railway Engineers. 315 inches, morocco.	1 25	
Berg's Buildings and Structures of American Railroads.....	.40.	5 00
Brook's Handbook of Street Railroad Location.....	16mo, morocco,	1 50
Butt's Civil Engineer's Field-book.....	16mo, morocco,	2 50
Crandall's Transition Curve.....	16mo, morocco,	1 50
Railway and Other Earthwork Tables.....	Svo.	1 50
Crockett's Methods for Earthwork Computations. (In Press)		
Dawson's "Engineering" and Electric Traction Pocket-book.....	16mo, morocco	5 00
Dredge's History of the Pennsylvania Railroad: (1879).....	Paper.	5 00
Fisher's Table of Cubic Yards.....	Cardboard.	.25
Godwin's Railroad Engineers' Field-book and Explorers' Guide.....	16mo, mor.	3 50
Hudson's Tables for Calculating the Cubic Contents of Excavations and Embankments.....	Svo.	1 00
Molitor and Beard's Manual for Resident Engineers.....	16mo.	1 00
Nagle's Field Manual for Railroad Engineers.....	16mo, morocco.	3 00
Philbrick's Field Manual for Engineers.....	16mo, morocco,	3 00
Raymond's Elements of Railroad Engineering. (In Press)		

Searles's Field Engineering.....	16mo, morocco,	3 00
Railroad Spiral.....	16mo, morocco,	1 50
Taylor's Prismoidal Formulae and Earthwork.....	8vo,	1 50
* Trautwine's Method of Calculating the Cube Contents of Excavations and Embankments by the Aid of Diagrams.....	8vo,	2 00
The Field Practice of Laying Out Circular Curves for Railroads.		
Cross-section Sheet.....	12mo, morocco,	2 50
Webb's Railroad Construction.....	Paper,	25
Economics of Railroad Construction.....	16mo, morocco,	5 00
Wellington's Economic Theory of the Location of Railways.....	Large 12mo,	3 50
	Small 8vo,	5 00

DRAWING.

Barr's Kinematics of Machinery.....	8vo,	2 50
* Bartlett's Mechanical Drawing.....	8vo,	3 00
* " " " Abridged Ed.....	8vo,	1 50
Coolidge's Manual of Drawing.....	8vo, paper,	1 00
Coolidge and Freeman's Elements of General Drafting for Mechanical Engineers.....	Oblong 4to,	3 50
Durley's Kinematics of Machines.....	8vo,	4 00
Emch's Introduction to Projective Geometry and its Applications.....	8vo,	2 50
Hill's Text-book on Shades and Shadows, and Perspective.....	8vo,	2 00
Jamison's Elements of Mechanical Drawing.....	8vo,	2 50
Advanced Mechanical Drawing.....	8vo,	2 00
Jones's Machine Design:		
Part I. Kinematics of Machinery.....	8vo,	1 50
Part II. Form, Strength, and Proportions of Parts.....	8vo,	3 00
MacCord's Elements of Descriptive Geometry:		
Kinematics; or, Practical Mechanism.....	8vo,	3 00
Mechanical Drawing.....	4to,	4 00
Velocity Diagrams.....	8vo,	1 50
MacLeod's Descriptive Geometry.....	Small 8vo,	1 50
* Mahan's Descriptive Geometry and Stone-cutting.....	8vo,	1 50
Industrial Drawing. (Thompson).	8vo,	3 50
Moyer's Descriptive Geometry.....	8vo,	2 00
Reed's Topographical Drawing and Sketching.....	4to,	5 00
Reid's Course in Mechanical Drawing.....	8vo,	2 00
Text-book of Mechanical Drawing and Elementary Machine Design	8vo,	3 00
Robinson's Principles of Mechanism.....	8vo,	3 00
Schwamb and Merrill's Elements of Mechanism.....	8vo,	3 00
Smith's (R. S.) Manual of Topographical Drawing. (McMillan).	8vo,	2 50
Smith (A. W.) and Marx's Machine Design.....	8vo,	3 00
* Titsworth's Elements of Mechanical Drawing.....	Oblong 8vo,	1 25
Warren's Elements of Plane and Solid Free-hand Geometrical Drawing	12mo,	1 00
Drafting Instruments and Operations.....	12mo,	1 25
Manual of Elementary Projection Drawing.....	12mo,	1 50
Manual of Elementary Problems in the Linear Perspective of Form and Shadow.....	12mo,	1 00
Plane Problems in Elementary Geometry.....	12mo,	1 25
Elements of Descriptive Geometry, Shadows, and Perspective.....	8vo,	3 50
General Problems of Shades and Shadows.....	8vo,	3 00
Elements of Machine Construction and Drawing.....	8vo,	7 50
Problems, Theorems, and Examples in Descriptive Geometry.....	8vo,	2 50
Weisbach's Kinematics and Power of Transmission. (Hermann and Klein).	8vo,	5 00
Whelpley's Practical Instruction in the Art of Letter Engraving.....	12mo,	2 00
Wilson's (H. M.) Topographic Surveying.....	8vo,	3 50

Wilson's (V. T.) Free-hand Perspective.	8vo, 1 50
Wilson's (V. T.) Free-hand Lettering.	8vo, 1 00
Woolf's Elementary Course in Descriptive Geometry.	Large 8vo, 3 00

ELECTRICITY AND PHYSICS.

* Abegg's Theory of Electrolytic Dissociation. (Von Ende.)	12mo, 1 25
Anthony and Brackett's Text-book of Physics. (Magie.)	Small 8vo, 3 00
Anthony's Lecture-notes on the Theory of Electrical Measurements	12mo, 1 00
Benjamin's History of Electricity.	8vo, 3 00
Voltaic Cell.	8vo, 3 00
Betts's Lead Refining and Electrolysis. (In Press.)	
Classen's Quantitative Chemical Analysis by Electrolysis. (Boltwood.)	8vo, 3 00
* Collins's Manual of Wireless Telegraphy.	12mo, 1 50
Morocco.	3 00
Crehore and Squier's Polarizing Photo-chronograph.	8vo, 3 00
* Danneel's Electrochemistry. (Merriam.)	12mo, 1 25
Dawson's "Engineering" and Electric Traction Pocket-book	16mo, morocco, 5 00
Dolezalek's Theory of the Lead Accumulator (Storage Battery). (Von Ende.)	12mo, 2 50
Duhem's Thermodynamics and Chemistry. (Burgess.)	8vo, 4 00
Flather's Dynamometers, and the Measurement of Power.	12mo, 3 00
Gilbert's De Magnete. (Mottelay.)	8vo, 2 50
Hanchett's Alternating Currents Explained.	12mo, 1 00
Hering's Ready Reference Tables (Conversion Factors)	16mo, morocco, 3 50
Hobart and Ellis's High-speed Dynamo Electric Machinery. (In Press.)	
Holman's Precision of Measurements.	8vo, 3 00
Telescopic Mirror-scale Method, Adjustments, and Tests	Large 8vo, 75
Karapetoff's Experimental Electrical Engineering. (In Press.)	
Kinzbrunner's Testing of Continuous-current Machines.	8vo, 2 00
Landauer's Spectrum Analysis. (Tingle.)	8vo, 3 00
Le Chatelier's High-temperature Measurements. (Boudouard Burgess.)	12mo, 3 00
Lob's Electrochemistry of Organic Compounds. (Lorenz.)	8vo, 3 00
* Lyons's Treatise on Electromagnetic Phenomena. Vols I. and II.	8vo, each, 6 00
* Michie's Elements of Wave Motion Relating to Sound and Light.	8vo, 4 00
Niaudet's Elementary Treatise on Electric Batteries. (Fishback.)	12mo, 2 50
Norris's Introduction to the Study of Electrical Engineering. (In Press.)	
* Parshall and Hobart's Electric Machine Design	4to, half morocco, 12 50
Reagan's Locomotives: Simple, Compound, and Electric. New Edition.	Large 12mo, 3 50
* Rosenberg's Electrical Engineering. (Haldane Gee—Kinzbrunner.)	8vo, 2 00
Ryan, Norris, and Hoxie's Electrical Machinery. Vol. I.	8vo, 2 50
Thurston's Stationary Steam-engines.	8vo, 2 50
* Tillman's Elementary Lessons in Heat.	8vo, 1 50
Tory and Pitcher's Manual of Laboratory Physics.	Small 8vo, 2 00
Ulke's Modern Electrolytic Copper Refining.	8vo, 3 00

LAW.

* Davis's Elements of Law.	8vo, 2 50
* Treatise on the Military Law of United States.	8vo, 7 00
*	Sheep, 7 50
* Dudley's Military Law and the Procedure of Courts-martial	Large 12mo, 2 50
Manual for Courts-martial.	16mo, morocco, 1 50
Wait's Engineering and Architectural Jurisprudence.	8vo, 6 00
Sheep, 6 50	
Law of Operations Preliminary to Construction in Engineering and Architecture.	8vo 5 00
Sheep, 5 50	
Law of Contracts.	8vo, 3 00
Winthrop's Abridgment of Military Law.	12mo, 2 50

MANUFACTURES.

Bernadou's Smokeless Powder—Nitro-cellulose and Theory of the Cellulose Molecule.....	12mo, 2 50
Bolland's Iron Founder.....	12mo, 2 50
The Iron Founder," Supplement.....	12mo, 2 50
Encyclopedia of Foundry and Dictionary of Foundry Terms Used in the Practice of Moulding.....	12mo, 3 00
* Classen's Beet-sugar Manufacture. (Hall and Rolfe).....	8vo, 3 00
* Eckel's Cements, Limes, and Plasters.....	8vo, 6 00
Eissler's Modern High Explosives.....	8vo, 4 00
Effront's Enzymes and their Applications. (Prescott).....	8vo, 3 00
Fitzgerald's Boston Machinist.....	12mo, 1 00
Ford's Boiler Making for Boiler Makers.....	18mo, 1 00
Herrick's Denatured or Industrial Alcohol.....	8vo, 4 00
Holley and Ladd's Analysis of Mixed Paints, Color Pigments, and Varnishes. (In Press.)	
Hopkins's Oil-chemists' Handbook.....	8vo, 3 00
Keep's Cast Iron.....	8vo, 2 50
Leach's The Inspection and Analysis of Food with Special Reference to State Control.....	Large 8vo, 7 50
* McKay and Larsen's Principles and Practice of Butter-making.....	8vo, 1 50
Maire's Modern Pigments and their Vehicles. (In Press.)	
Matthews's The Textile Fibres. 2d Edition, Rewritten.....	8vo, 4 00
Metcalf's Steel. A Manual for Steel-users.....	12mo, 2 00
Metcalf's Cost of Manufactures And the Administration of Workshops	8vo, 5 00
Meyer's Modern Locomotive Construction.....	4to, 10 00
Morse's Calculations used in Cane-sugar Factories.....	16mo, morocco, 1 50
* Reisig's Guide to Piece-dyeing.....	8vo, 25 00
Rice's Concrete-block Manufacture.....	8vo, 2 00
Sabin's Industrial and Artistic Technology of Paints and Varnish.....	8vo, 3 00
Smith's Press-working of Metals.....	8vo, 3 00
Spalding's Hydraulic Cement.....	12mo, 2 00
Spencer's Handbook for Chemists of Beet-sugar Houses.....	16mo, morocco, 3 00
Handbook for Cane Sugar Manufacturers.....	16mo, morocco, 3 00
Taylor and Thompson's Treatise on Concrete, Plain and Reinforced.....	8vo, 5 00
Thurston's Manual of Steam-boilers, their Designs, Construction and Operation.....	8vo, 5 00
Ware's Beet-sugar Manufacture and Refining. Vol. I.....	Small 8vo, 4 00
" " " " " Vol. II.....	8vo, 5 00
Weaver's Military Explosives.....	8vo, 3 00
West's American Foundry Practice.....	12mo, 2 50
Moulder's Text-book.....	12mo, 2 50
Wolff's Windmill as a Prime Mover.....	8vo, 3 00
Wood's Rustless Coatings: Corrosion and Electrolysis of Iron and Steel	8vo, 4 00

MATHEMATICS.

Baker's Elliptic Functions.....	8vo, 1 50
Briggs's Elements of Plane Analytic Geometry.....	12mo, 1 00
Buchanan's Plane and Spherical Trigonometry. (In Press.)	
Compton's Manual of Logarithmic Computations.....	12mo, 1 50
Davis's Introduction to the Logic of Algebra.....	8vo, 1 50
* Dickson's College Algebra.....	Large 12mo, 1 50
* Introduction to the Theory of Algebraic Equations.....	Large 12mo, 1 25
Emch's Introduction to Projective Geometry and its Applications.....	8vo, 2 50
Halsted's Elements of Geometry.....	8vo, 1 75
Elementary Synthetic Geometry.....	8vo, 1 50
* Rational Geometry.....	12mo, 1 50

* Johnson's (J. E.) Three-place Logarithmic Tables: Vest-pocket size paper,	15
100 copies for	5 00
Mounted on heavy cardboard, 8 x 10 inches,	25
10 copies for	2 00
Johnson's (W. W.) Elementary Treatise on Differential Calculus	Small Svo., 3 00
Elementary Treatise on the Integral Calculus	Small Svo., 1 50
Johnson's (W. W.) Curve Tracing in Cartesian Co-ordinates	12mo., 1 00
Johnson's (W. W.) Treatise on Ordinary and Partial Differential Equations	Small Svo., 3 50
Johnson's Treatise on the Integral Calculus	Small Svo., 3 00
Johnson's (W. W.) Theory of Errors and the Method of Least Squares	12mo., 1 50
* Johnson's (W. W.) Théoretical Mechanics	12mo., 1 00
Laplace's Philosophical Essay on Probabilities. (Truscott and Emory)	12mo., 2 00
* Ludlow and Basa. Elements of Trigonometry and Logarithmic and Other Tables	Svo., 3 00
Trigonometry and Tables published separately	Each, 2 00
* Ludlow's Logarithmic and Trigonometric Tables	Svo., 1 00
Manning's Irrational Numbers and their Representation by Sequences and Series	12mo., 1 25
Mathematical Monographs. Edited by Mansfield Merriman and Robert S. Woodward.	Octavo, each 1 00
No. 1. History of Modern Mathematics, by David Eugene Smith.	
No. 2. Synthetic Projective Geometry, by George Bruce Halsted.	
No. 3. Determinants, by Lemmas Gifford Weld. No. 4. Hyperbolic Functions, by James McMahon. No. 5. Harmonic Functions, by William E. Byerly. No. 6. Grassmann's Space Analysis, by Edward W. Hyde. No. 7. Probability and Theory of Errors, by Robert S. Woodward. No. 8. Vector Analysis and Quaternions, by Alexander Macfarlane. No. 9. Differential Equations, by William Woolsey Johnson. No. 10. The Solution of Equations, by Mansfield Merriman. No. 11. Functions of a Complex Variable, by Thomas S. Fiske.	
Maurer's Technical Mechanics.	Svo., 4 00
Merriman's Method of Least Squares.	Svo., 2 00
Rice and Johnson's Elementary Treatise on the Differential Calculus. Sm. Svo., 3 00	
Differential and Integral Calculus. 2 vols in one.	Small Svo., 2 50
* Veblen and Lennes's Introduction to the Real Infinitesimal Analysis of One Variable	Svo., 2 00
Wood's Elements of Co-ordinate Geometry.	Svo., 2 00
Trigonometry: Analytical, Plane, and Spherical	12mo., 1 00

MECHANICAL ENGINEERING.

MATERIALS OF ENGINEERING, STEAM-ENGINES AND BOILERS.

Bacon's Forge Practice.	12mo., 1 50
Baldwin's Steam Heating for Buildings.	12mo., 2 50
Barr's Kinematics of Machinery.	Svo., 2 50
* Bartlett's Mechanical Drawing.	Svo., 3 00
* " " " Abridged Ed.	Svo., 1 50
Benjamin's Wrinkles and Recipes.	12mo., 2 00
Carpenter's Experimental Engineering.	Svo., 6 00
Heating and Ventilating Buildings.	Svo., 4 00
Clerk's Gas and Oil Engine.	Small Svo., 4 00
Coolidge's Manual of Drawing.	Svo., paper, 1 00
Coolidge and Freeman's Elements of General Drafting for Mechanical Engineers.	Oblong 4to., 2 50
Cromwell's Treatise on Toothed Gearing.	12mo., 1 50
Treatise on Belts and Pulleys.	12mo., 1 50

Durley's Kinematics of Machines.....	.8vo, 4 00
Flather's Dynamometers and the Measurement of Power.....	12mo, 3 00
Rope Driving.....	12mo, 2 00
Gill's Gas and Fuel Analysis for Engineers.....	12mo, 1 25
Hall's Car Lubrication.....	12mo, 1 00
Hering's Ready Reference Tables (Conversion Factors).....	16mo, morocco, 2 50
Hutton's The Gas Engine.....	.8vo, 5 00
Jamison's Mechanical Drawing.....	.8vo, 2 50
Jones's Machine Design:	
Part I. Kinematics of Machinery.....	.8vo, 1 50
Part II. Form, Strength, and Proportions of Parts.....	.8vo, 3 00
Kent's Mechanical Engineers' Pocket-book.....	16mo, morocco, 5 00
Kerr's Power and Power Transmission.....	.8vo, 3 00
Leonard's Machine Shop, Tools, and Methods.....	.8vo, 4 00
* Lorenz's Modern Refrigerating Machinery. (Pope, Haven, and Dean.)	.8vo, 4 00
MacCord's Kinematics; or, Practical Mechanism.	.8vo, 5 00
Mechanical Drawing.....	4to, 4 00
Velocity Diagrams.....	.8vo, 1 50
MacFarland's Standard Reduction Factors for Gases.....	.8vo, 1 50
Mahan's Industrial Drawing. (Thompson.).....	.8vo, 3 50
Poole's Calorific Power of Fuels.....	.8vo, 3 00
Reid's Course in Mechanical Drawing.....	.8vo, 2 00
Text-book of Mechanical Drawing and Elementary Machine Design	.8vo, 3 00
Richard's Compressed Air.....	12mo, 1 50
Robinson's Principles of Mechanism.....	.8vo, 3 00
Schwamb and Merrill's Elements of Mechanism.....	.8vo, 3 00
Smith's (O.) Press-working of Metals.....	.8vo, 3 00
Smith (A. W.) and Marx's Machine Design.....	.8vo, 3 00
Thurston's Treatise on Friction and Lost Work in Machinery and Mill Work.....	.8vo, 3 00
Animal as a Machine and Prime Motor, and the Laws of Energetics	12mo, 1 00
Tillson's Complete Automobile Instructor.....	16mo, 1 50
	Morocco, 2 00
Warren's Elements of Machine Construction and Drawing.....	.8vo, 7 50
Weisbach's Kinematics and the Power of Transmission. (Herrmann—Klein.).....	.8vo, 5 00
Machinery of Transmission and Governors. (Herrmann—Klein.)	.8vo, 5 00
Wolff's Windmill as a Prime Mover.....	.8vo, 3 00
Wood's Turbines.....	.8vo, 2 50

MATERIALS OF ENGINEERING.

* Bovey's Strength of Materials and Theory of Structures.....	.8vo, 7 50
Burr's Elasticity and Resistance of the Materials of Engineering. 6th Edition.	
Reset.....	.8vo, 7 50
Church's Mechanics of Engineering.....	.8vo, 6 00
* Greene's Structural Mechanics.....	.8vo, 2 50
Johnson's Materials of Construction.....	.8vo, 6 00
Keep's Cast Iron.....	.8vo, 2 50
Lanza's Applied Mechanics.....	.8vo, 7 50
Martens's Handbook on Testing Materials. (Henning.).....	.8vo, 7 50
Maurer's Technical Mechanics.....	.8vo, 4 00
Merriman's Mechanics of Materials.....	.8vo, 5 00
* Strength of Materials.....	12mo, 1 00
Metcalf's Steel. A Manual for Steel-users.....	12mo, 2 00
Sabin's Industrial and Artistic Technology of Paints and Varnish.....	.8vo, 3 00
Smith's Materials of Machines.....	12mo, 1 00
Thurston's Materials of Engineering.....	3 vols., .8vo, 8 00
Part II. Iron and Steel.....	.8vo, 3 50
Part III. A Treatise on Brasses, Bronzes, and Other Alloys and their Constituents.	.8vo, 2 50

Wood's (De V.) Treatise on the Resistance of Materials and an Appendix on the Preservation of Timber.....	Svo., 2 00
Elements of Analytical Mechanics.....	Svo., 3 00
Wood's (M. P.) Rustless Coatings: Corrosion and Electrolysis of Iron and Steel.....	Svo., 4 00

STEAM-ENGINES AND BOILERS.

Berry's Temperature-entropy Diagram.....	12mo., 1 25
Carnot's Reflections on the Motive Power of Heat. (Thurston).....	12mo., 1 50
Cleighton's Steam-engine and other Heat-motors.....	Svo., 5 00
Dawson's "Engineering" and Electric Traction Pocket-book.....	16mo. met., 5 00
Ford's Boiler Making for Boiler Makers.....	12mo., 1 00
Goss's Locomotive Sparks.....	Svo., 2 00
Locomotive Performance	Svo., 5 00
Hemenway's Indicator Practice and Steam-engine Economy.....	12mo., 2 00
Hutton's Mechanical Engineering of Power Plants.....	Svo., 5 00
Heat and Heat-engines.....	Svo., 5 00
Kent's Steam-boiler Economy.....	Svo., 4 00
Kneass's Practice and Theory of the Injector.....	Svo., 1 50
MacCord's Slide valves.....	Svo., 2 00
Meyer's Modern Locomotive Construction.....	4to., 10 00
Peabody's Manual of the Steam-engine Indicator.....	12mo., 1 50
Tables of the Properties of Saturated Steam and Other Vapors.....	Svo., 1 00
Thermodynamics of the Steam-engine and Other Heat-engines.....	Svo., 5 00
Valve-gears for Steam-engines.....	Svo., 3 50
Peabody and Miller's Steam-boilers.....	Svo., 4 00
Pray's Twenty Years with the Indicator.....	Large Svo., 2 50
Pupin's Thermodynamics of Reversible Cycles in Gases and Saturated Vapors. (Osterberg).....	12mo., 1 25
Reagan's Locomotives: Simple, Compound, and Electric. New Edition.....	Large 12mo., 3 50
Sinclair's Locomotive Engine Running and Management.....	12mo., 2 00
Smart's Handbook of Engineering Laboratory Practice.....	12mo., 2 50
Snow's Steam-boiler Practice.....	Svo., 3 00
Spangler's Valve-gears.....	Svo., 2 50
Notes on Thermodynamics.....	12mo., 1 00
Spangler, Greene, and Marshall's Elements of Steam-engineering.....	Svo., 3 00
Thomas's Steam-turbines.....	Svo., 3 50
Thurston's Handy Tables.....	Svo., 1 50
Manual of the Steam-engine.....	2 vols. Svo., 10 00
Part I. History, Structure, and Theory.....	Svo., 6 00
Part II. Design, Construction, and Operation.....	Svo., 6 00
Handbook of Engine and Boiler Trials, and the Use of the Indicator and the Prony Brake.....	Svo., 5 00
Stationary Steam-engines.....	Svo., 2 50
Steam-boiler Explosions in Theory and in Practice.....	12mo., 1 50
Manual of Steam-boilers, their Designs, Construction, and Operation.....	Svo., 5 00
Wehrenfennig's Analysis and Softening of Boiler Feed-water (Patterson).....	Svo., 4 00
Weisbach's Heat, Steam, and Steam-engines. (Du Bois).....	Svo., 5 00
Whitham's Steam-engine Design.....	Svo., 5 00
Wood's Thermodynamics, Heat Motors, and Refrigerating Machines.....	Svo., 4 00

MECHANICS AND MACHINERY.

Barr's Kinematics of Machinery.....	Svo., 2 50
* Bovay's Strength of Materials and Theory of Structures	Svo., 7 50
Chase's The Art of Pattern-making.....	12mo., 3 50

Spangler, Greene, and Marshall's Elements of Steam-engineering	Svo.	3 00
Thurston's Treatise on Friction and Lost Work in Machinery and Mill Work	Svo.	3 00
Animal as a Machine and Prime Motor, and the Laws of Energetics	12mo.	1 00
Tillson's Complete Automobile Instructor	12mo.,	1 50
	Mosocco,	1 00
Warren's Elements of Machine Construction and Drawing	Svo.	7 50
Weisbach's Kinematics and Power of Transmission. (Herrmann—Klein.)	Svo.	5 00
Machinery of Transmission and Governors. (Herrmann—Klein.)	Svo.	5 00
Wood's Elements of Analytical Mechanics	Svo.	3 00
Principles of Elementary Mechanics	12mo.	1 25
Turbines	Svo.	1 50
The World's Columbian Exposition of 1893	4to.	1 00

MEDICAL.

* Bolduan's Immune Serum	12mo.	1 50
De Fursac's Manual of Psychiatry. (Rosanoff and Collins)	Large 12mo.	1 50
Ehrlich's Collected Studies on Immunity. (Bolduan.)	Svo.	6 00
* Fischer's Physiology of Alimentation	Large 12mo, cloth.	2 00
Hammarsten's Text book on Physiological Chemistry. (Mandel)	Svo.	4 00
Lassar-Cohn's Practical Urinary Analysis. (Lorenz.)	12mo.	1 00
* Paul's Physical Chemistry in the Service of Medicine. Fischer	12mo.	1 25
* Pazzi-Escot's The Toxins and Venoms and their Antibodies. Cohn	12mo.	1 00
Rostowski's Serum Diagnosis. (Bolduan.)	12mo.	1 00
Salkowski's Physiological and Pathological Chemistry. (Orndorff.)	Svo.	2 50
* Satterlee's Outlines of Human Embryology	12mo.	1 25
Steel's Treatise on the Diseases of the Dog	Svo.	3 50
Von Behring's Suppression of Tuberculosis. (Bolduan)	12mo.	1 00
Woodbull's Notes on Military Hygiene	16mo.	1 50
* Personal Hygiene	12mo.	1 00
Wylling's An Elementary Course in Inorganic Pharmaceutical and Medical Chemistry	12mo.	2 00

METALLURGY.

Betts's Lead Refining by Electrolysis. (In Press.)		
Egleston's Metallurgy of Silver, Gold, and Mercury:		
Vol. I. Silver.	Svo.	7 50
Vol. II. Gold and Mercury.	Svo.	7 50
Goesel's Minerals and Metals: A Reference Book	16mo, mor.	3 00
* Ilieg's Lead-smelting	12mo.	2 50
Keep's Cast Iron	Svo.	2 50
Kunhardt's Practice of Ore Dressing in Europe	Svo.	1 50
Le Chatelier's High temperature Measurements. Boudouard-Burgess	12mo.	3 00
Metcalf's Steel. A Manual for Steel-users.	12mo.	2 00
Miller's Cyanide Process	12mo.	1 00
Minet's Production of Alumicium and its Industrial Use. Waldo.	12mo.	2 50
Robine and Lenglen's Cyanide Industry. (Le Clerc.)	Svo.	4 00
Smith's Materials of Machines	12mo.	1 00
Thurston's Materials of Engineering. In Three Parts.	Svo.	8 00
Part II. Iron and Steel.	Svo.	3 50
Part III. A Treatise on Brasses, Bronzes, and Other Alloys and their Constituents.	Svo.	2 50
Ulke's Modern Electrolytic Copper Refining	Svo.	3 00

MINERALOGY.

Barringer's Description of Minerals of Commercial Value. Oblong, mosocco,	2 50
Boyd's Resources of Southwest Virginia.	Svo.

Boyd's Map of Southwest Virginia.	Pocket-book form.	2 00
* Browning's Introduction to the Rarer Elements.	8vo,	1 50
Brush's Manual of Determinative Mineralogy. (Penfield).	8vo,	4 00
Chester's Catalogue of Minerals.	8vo, paper,	1 00
	Cloth,	1 25
Dictionary of the Names of Minerals.	8vo,	3 50
Dana's System of Mineralogy.	Large 8vo, half leather,	12 50
First Appendix to Dana's New "System of Mineralogy."	Large 8vo,	1 00
Text-book of Mineralogy.	8vo,	4 00
Minerals and How to Study Them.	12mo,	1 50
Catalogue of American Localities of Minerals.	Large 8vo,	1 00
Manual of Mineralogy and Petrography.	12mo	2 00
Douglas's Untechnical Addresses on Technical Subjects.	12mo,	1 00
Eakle's Mineral Tables.	8vo,	1 25
Egleston's Catalogue of Minerals and Synonyms.	8vo,	2 50
Goessel's Minerals and Metals: A Reference Book.	16mo, mor.	3 00
Groth's Introduction to Chemical Crystallography (Marshall).	12mo,	1 25
Iddings's Rock Minerals.	8vo,	5 00
Johannsen's Key for the Determination of Rock-forming Minerals in Thin Sections. (In Press.)		
* Martin's Laboratory Guide to Qualitative Analysis with the Blowpipe.	12mo,	60
Merrill's Non-metallic Minerals. Their Occurrence and Uses.	8vo,	4 00
Stones for Building and Decoration.	8vo,	5 00
* Penfield's Notes on Determinative Mineralogy and Record of Mineral Tests.	8vo, paper,	50
Tables of Minerals.	8vo,	1 00
* Richards's Synopsis of Mineral Characters.	12mo, morocco,	1 25
* Ries's Clays. Their Occurrence. Properties, and Uses.	8vo,	5 00
Rosenbusch's Microscopical Physiography of the Rock-making Minerals. (Iddings.).	8vo,	5 00
* Tillman's Text-book of Important Minerals and Rocks.	8vo,	2 00

MINING.

Beard's Mine Gases and Explosions. (In Press.)		
Boyd's Resources of Southwest Virginia.	8vo,	3 00
Map of Southwest Virginia.	Pocket-book form,	2 00
Douglas's Untechnical Addresses on Technical Subjects.	12mo,	1 00
Eissler's Modern High Explosives.	8vo,	4 00
Goessel's Minerals and Metals: A Reference Book.	16mo, mor.	3 00
Goodyear's Coal-mines of the Western Coast of the United States.	12mo,	2 50
Thieng's Manual of Mining.	8vo,	5 00
* Iles's Lead-smelting.	12mo,	2 50
Kunhardt's Practice of Ore Dressing in Europe.	8vo,	1 50
Miller's Cyanide Process.	12mo,	1 00
O'Driscoll's Notes on the Treatment of Gold Ores.	8vo,	2 00
Robine and Lenglen's Cyanide Industry. (Le Clerc.).	8vo,	4 00
Weaver's Military Explosives.	8vo,	3 00
Wilson's Cyanide Processes.	12mo,	1 50
Chlorination Process.	12mo,	1 50
Hydraulic and Placer Mining. 2d edition, rewritten.	12mo,	2 50
Treatise on Practical and Theoretical Mine Ventilation.	12mo,	1 25

SANITARY SCIENCE.

Bashore's Sanitation of a Country House.	12mo,	1 00
* Outlines of Practical Sanitation.	12mo,	1 25
Folwell's Sewerage. (Designing, Construction, and Maintenance.).	8vo,	3 00
Water-supply Engineering.	8vo,	4 00

Fowler's Sewage Works Analyses.	12mo.,	2 00
Fuertes's Water and Public Health.	12mo.,	1 50
Water-filtration Works.	12mo.,	2 50
Gerhard's Guide to Sanitary House-Inspection	12mo.,	1 00
Sanitation of Public Buildings.	12mo.,	1 50
Hazen's Filtration of Public Water-supplies.	8vo,	3 00
Leach's The Inspection and Analysis of Food with Special Reference to State Control.	8vo,	7 50
Mason's Water-supply. (Considered principally from a Sanitary Standpoint) Examination of Water. (Chemical and Bacteriological).	8vo,	4 00
* Merriman's Elements of Sanitary Engineering.	12mo.,	1 25
Ogden's Sewer Design.	8vo,	2 00
Prescott and Winslow's Elements of Water Bacteriology, with Special Reference to Sanitary Water Analysis.	12mo.,	2 25
* Price's Handbook on Sanitation.	12mo.,	1 50
Richards's Cost of Food. A Study in Dietaries. Cost of Living as Modified by Sanitary Science.	12mo.,	1 00
Cost of Shelter.	12mo.,	1 00
Richards and Woodman's Air, Water, and Food from a Sanitary Stand-point.	8vo,	3 00
* Richards and Williams's The Dietary Computer.	8vo,	1 50
Rideal's Sewage and Bacterial Purification of Sewage. Disinfection and the Preservation of Food.	8vo,	4 00
Turneaure and Russell's Public Water-supplies.	8vo,	5 00
Von Behring's Suppression of Tuberculosis. (Bolduan.)	12mo.,	1 00
Whipple's Microscopy of Drinking-water.	8vo,	3 50
Wilson's Air Conditioning. (In Press.)		
Winton's Microscopy of Vegetable Foods.	8vo,	7 50
Woodhull's Notes on Military Hygiene.	12mo.,	1 50
* Personal Hygiene.	12mo.,	1 00

MISCELLANEOUS.

Association of State and National Food and Dairy Departments Interstate Pure Food Commission		
Tenth Annual Convention Held at Hartford, July 17-20, 1905.	8vo,	3 00
Eleventh Annual Convention, Held at Jamestown Tri-Centennial Exposition, July 16-19, 1907. (In Press.)		
Emmons's Geological Guide-book of the Rocky Mountain Excursion of the International Congress of Geologists.	Large 8vo,	1 50
Ferrel's Popular Treatise on the Winds.	8vo,	4 00
Gannett's Statistical Abstract of the World.	12mo.,	75
Gerhard's The Modern Bath and Bath-houses. (In Press.)		
Haines's American Railway Management.	12mo.,	3 50
Ricketts's History of Rensselaer Polytechnic Institute, 1824-1894. Small 8vo,	3 00	
Rotherham's Emphasized New Testament.	Large 8vo,	3 00
Standage's Decorative Treatment of Wood, Glass, Metal, etc. (In Press.)		
The World's Columbian Exposition of 1893	4to,	1 00
Winslow's Elements of Applied Microscopy	12mo.,	1 50

HEBREW AND CHALDEE TEXT-BOOKS.

Green's Elementary Hebrew Grammar.	12mo.,	1 25
Hebrew Chrestomathy.	8vo,	3 00
Gesenius's Hebrew and Chaldee Lexicon to the Old Testament Scriptures. (Tregelles.)	Small 4to, half morocco	5 00
Letteris's Hebrew Bible.	8vo,	3 25

PLEASE DO NOT REMOVE
CARDS OR SLIPS FROM THIS POCKET

UNIVERSITY OF TORONTO LIBRARY

S&M
A
300

